

FEB 0 8 1977

MEMORANDUM FOR: Karl R. Goller, Assistant Director for Operating Reactors, DOR

FROM: Darrell G. Eisenhut, Assistant Director for Operational Technology, DOR

SUBJECT: OCONEE - PROPOSED TECHNICAL SPECIFICATION CHANGE (TAC 06390)

PLANT NAME: Oconee, Units 1, 2 and 3  
DOCKET NUMBERS: 50-269, 270, 287  
RESPONSIBLE BRANCH: ORB-1  
PROJECT MANAGER: D. Neighbors  
REQUESTED COMPLETION DATE: 1/30/77  
REVIEW STATUS: EEB - Complete

The Environmental Evaluation Branch has reviewed Item 5 of Duke Power Company's November 1, 1976 letter requesting changes to the Appendix A Technical Specifications of Oconee Units 1, 2 and 3. Item 5 pertains to the reporting requirements of anomalous measurements of radioactivity in environmental samples. The request as originally submitted was unacceptable since it did not provide for adequate reporting when potentially significant levels of radioactivity in the aquatic environment are detected at downstream population center locations. In a telephone conversation with Duke Power on this item, the licensee agreed to our proposed changes to provide adequate reporting requirements.

A safety evaluation to support an amendment to the Oconee Technical Specifications is enclosed.

Darrell G. Eisenhut, Assistant Director  
for Operational Technology  
Division of Operating Reactors

Enclosure: As stated

cc: V. Stello  
W. Kreger  
D. Neighbors  
B. Grimes  
L. Barrett  
E. Adensam  
A. Schwencer

DISTRIBUTION:

Central Files  
EEB Reading  
D. Eisenhut  
D. Davis  
S. Bland

269  
MEMO  
4

Contact: J. S. Bland, EEB/DOR

OFFICE →	EEB/OT/DOR	EEB/OT/DOR	EEB/OT/DOR	EEB/OT/DOR		
SURNAME →	JSBland	LBarrett	BGrimes	DEisenhut		
DATE →	1/3/77	2/1/77	2/2/77	2/2/77		

7912300 223 P