

Docket

MAY 26 1976

K. R. Goller, Assistant Director for Operating Reactors, DOR
SAFETY EVALUATION OF TECHNICAL SPECIFICATION CHANGE REQUEST

PLANT NAME: Oconee Units 1, 2 and 3
DOCKET NOS: 50-269/270/287
PROJECT MANAGER: Gary G. Zech
REQUESTED COMPLETION DATE: May 24, 1976

Attached is the Operational Technology, Plant Systems Branch evaluation of the Duke Power Company's April 16, 1976 technical specification change request to permit the dry storage of unirradiated fuel assemblies in the Oconee Unit 3 spent fuel pool.

The Engineering Branch, Division of Operating Reactors, has also completed its evaluation of Duke Power Company's technical specification change request and finds that no structural or mechanical hazards should arise due to dry storage of new fuel in the Oconee Unit 3 spent fuel pool. We have also reviewed the applicants original quality assurance commitment during construction and installation of the new fuel storage racks as stated in Duke Topical Report No. 1 and suggest that the licensee adhere to this quality assurance program in order to preclude any hazards during the installation of the remaining fuel racks.

We have concluded that the Licensee's request is acceptable.

Original signed by
Darrell G. Eisenhut

D. G. Eisenhut, Assistant Director
for Operational Technology
Division of Operating Reactors

Attachment:
As stated

- cc w/attachment:
- V. Stello
- R. Purple
- G. Zech
- A. Schwencer
- B. Buckley

5/25
BC Buckley
RETYPE PER LSHAO - SEE PREVIOUS CONCURRENCE

OFFICE →	E. Lantz	DOR:PSB-B	DOR:PSB/C	DOR:AO/OT	DOR:EB/C
SURNAME →		ELantz:ph	ASchwencer	DEisenhut	LShao
DATE →		5/24/76	5/25/76	5/25/76	5/25/76

7912300261 P

MAY 26 1976

Distribution:

- ✓ Docket File (3)
- PSB File
- ELantz Reading
- DGEisenhut

K. R. Goller, Assistant Director for Operating Reactors, DOR

SAFETY EVALUATION OF TECHNICAL SPECIFICATION CHANGE REQUEST

Plant Name: Oconee Units 1, 2 and 3
 Docket Nos: 50-269/270/287
 Project Manager: Gary G. Zech
 Requested Completion Date: May 24, 1976

Attached is the Operational Technology, Plant Systems Branch evaluation of the Duke Power Company's April 16, 1976 technical specification change request to permit the dry storage of unirradiated fuel assemblies in the Oconee Unit 3 spent fuel pool.

We have concluded that the licensee's request is acceptable.

D. G. Eisenhut, Assistant Director
 for Operational Technology
 Division of Operating Reactors

Attachment:
As stated

- cc w/attachment:
- V. Stello
 - R. Purple
 - G. Zech
 - A. Schwencer
 - B. Buckley
 - E. Lantz

OFFICE →	DOR:PSB-B	DOR:PSB/SL-B	DOR:PSB/C	DOR:AD/OT	DOR:ER/C
SURNAME →	ELantz:ph	BBuckley	ASchwencer	DGEisenhut	SHA0
DATE →	5/18/76	5/ /76	5/18/76	5/ /76	5/ /76