

Docket File
NRR Rdg. File
RSB File

JAN 16 1975

DOR

Docket No. 50-269

Karl R. Goller, Assistant Director for Operating Reactors,

ECCS REANALYSIS FOR OCONEE UNIT 1

Plant Name:
Docket Number:
Responsible Branch
and Project Manager:
Technical Review Branches
Involved:

Oconee Unit 1
50-269
ORB-1
G. Zech

Reactor Systems Branch
Containment Systems Branch
Core Performance Branch
Electrical, Instrumentation and
Control Systems Branch
Complete

Review Status:

The enclosed evaluation of the ECCS performance reanalysis for Oconee 1 reflects the consolidated contributions of Reactor Systems Branch, Containment Systems Branch, Core Performance Branch, and the Electrical, Instrumentation and Control Systems Branch. The Oconee re-evaluation was submitted by Duke Power Company on July 9, 1975 (Reference 1) in response to the Commission Order for Modification of License (Reference 2) issued on December 27, 1974.

The Oconee 1 ECCS re-evaluation, based upon an acceptable evaluation model was modified in accordance with the changes described in the staff Safety Evaluation Report for Oconee dated December 27, 1974, is found to conform with the provisions of 10 CFR Part 50, Section 50.46, contingent on the changes noted in the enclosed SER.

Original signed by
D. F. Ross

POOR ORIGINAL
D. F. Ross, Assistant Director
for Reactor Safety
Division of Systems Safety

Enclosure:
Oconee SER

- cc: S. Hanauer D. Ross W. Lanning
- R. Heineman T. Ippolito R. Baer
- F. Schroeder J. D. Smith G. Zech
- K. Boyd G. Lains L. Engle
- V. Stello W. Jenson K. Parczewski
- R. Purple G. Mazetis (3) W. Brooks
- T. Novak

TR:RSB
RBAer
12/15/75 1/6/76 12/7/75

OFFICE	TR:RSB	TR:RSB
SURNAME	TNovak	DRoss
DATE	1/12/75	12/15/75

7912300 284 P