

APR 20 1976

John Collins, Chief
Effluent Treatment Systems Branch
Office of Nuclear Reactor Regulation

ENVIRONMENTAL SURVEYS PERFORMED NEAR OCONEE NUCLEAR STATION (F20135H2)

Enclosed is a report from Region II in which it is noted that flow proportional annual average concentrations of several nuclides discharged from the Oconee Nuclear Station exceed the calculated annual averages contained in the Oconee FES. We recognize that annual average concentrations may vary from the life-of-the-plant calculated values. This report is being transmitted for your information.

Original signed by
L. B. Higginbotham

Leo B. Higginbotham, Chief
Safety and Environmental Programs
Office of Inspection and Enforcement

Enclosure:
As stated

cc: J. G. Whiteaker
J. T. Sutherland, IE:II

OFFICE →	TE:SEB	IE:SEB			
SURNAME →	LJ Cunningham	mrl BHigginbotham			
DATE →	4/16/76	4/19/76			

8001020 833 Q