



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
230 PEACHTREE STREET, N. W. SUITE 818
ATLANTA, GEORGIA 30303

February 18, 1976

L. B. Higginbotham, Chief, Safety and Environmental Programs Branch,
Headquarters

EVALUATION OF LIQUID EFFLUENT DATA AND RADIOLOGICAL ENVIRONMENTAL SAMPLE
RESULTS FROM OCONEE NUCLEAR PLANT, DUKE POWER COMPANY

A brief evaluation of liquid effluent data and radiological environmental sample results related to Oconee Nuclear Station are attached to this memorandum. The evaluation indicates that annual average concentrations of certain radioisotopes were greater than predicted in the Final Environmental Statement. Region II requests that lead responsibility for follow-up of this matter be transferred to the Office of Nuclear Reactor Regulation.

A handwritten signature in cursive script, reading "J. T. Sutherland".

J. T. Sutherland, Chief
Fuel Facility and Materials
Safety Branch, Region II

cc: S. E. Bryan, IE:HQ

8001020 834