

DISTRIBUTION
 Docket File
 ORB#1 Reading
 Subj File
 RAPurple
 KRgoller

OCT 6 1975

Steve Varga, Technical Assistant to Director, DRL
 THRU: Karl R. Goller, Assistant Director for Operating Reactors

REQUEST FOR REVISION OF OCONEE UNIT 1 ECCS EVALUATION SCHEDULE
 (DOCKET NO. 50-269)

It is requested that the target date for the Reactor Systems Branch input for the ECCS evaluation of Oconee Unit 1 be changed from January 30, 1976, to November 28, 1975. This change is necessary due to the estimated date, December 12, 1975, at which Oconee Unit 1 will reach 250 EFPD of operation on its current cycle. The present technical specifications do not include a curve for Control Rod Group Withdrawal Limits for 4-pump operation after this point because it was determined during the evaluation of the Cycle 2 amendment request that the ECCS IAC were not met for this pump combination beyond 250 EFPD. Rod withdrawal limit curves appropriate for operation beyond 250 EFPD have been included in the licensee's July 9, 1975, ECCS FAC submittal. Thus, the ECCS review must be completed sooner than presently scheduled in order to prevent facility power reductions.

Original Signed by
 Karl Goller

Robert A. Purple, Chief
 Operating Reactors Branch #1
 Division of Reactor Licensing

cc: G. Zech
 S. Sheppard
 D. Eisenhut
 T. Carter

OFFICE	RL:ORB#1	RL:ORB#1	RL:OR <i>KRG</i>		
SURNAME	<i>GGZech:dc</i>	RAPurple	KRGoller		
DATE	10/6/75	10/6/75	10/6/75		