

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505
Telephone: (804) 384-5111

November 18, 1974

Dr. Donald F. Knuth, Director
Directorate of Regulatory Operations
Office of Regulations
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Dr. Knuth:

Attached please find ten copies of the report on the generic evaluation of the Significant Deficiency identified in the design of the attachment of the Control Rod Drive AC Breaker Cabinets to the floor for seismic excitation loadings. This deficiency has been reported to the affected utilities and remedial action has been initiated through field change packages. The attachment modifications described in the report are being factored into the design for later plants.


Plants affected by this deficiency are as follows:

Duke Power Company	Oconee Units 1, 2, & 3
Metropolitan Edison Company	Three Mile Island Unit 1
Jersey Central Power & Light	Three Mile Island Unit 2
Florida Power Corp.	Crystal River Unit 3
Sacramento Municipal Utilities District	Rancho Seco Unit 1
Toledo Edison Company	Davis-Besse Unit 1

Should you require additional information on the subject, please feel free to contact R. P. Williamson, the cognizant Licensing Engineer for Significant Deficiencies.

Very truly yours,

BABCOCK & WILCOX COMPANY
Nuclear Power Generation



James F. Mallay
Manager, Licensing

JFM/fe
Attach.

8001081014