



DIRECTORATE OF REGULATORY OPERATIONS
REGION II - SUITE 818
230 PEACHTREE STREET, NORTHWEST
ATLANTA, GEORGIA 30303

TELEPHONE: (404) 526-4503

October 3, 1974

W. C. Seidle, Chief, Facilities Test and Startup Branch
Directorate of Regulatory Operations, Region II

OCONEE TS CHANGE REQUEST ON REACTOR BUILDING - TS 3.6
DATED SEPTEMBER 4, 1974

I believe a corrective action period should be included in this
Technical Specification and the time periods requested are
acceptable.

Arkansas 1 TS allows 48 hours to repair isolation valves and
nothing for door repairs.

It would be better if a Standard could be developed for this
situation.

I would suggest adding words to 3.6.4.a. to require the remaining
operable door of the affected hatch to be closed during the repair
period.

F. Jape
Reactor Inspector
Facilities Test and Startup Branch

RO:II:FJ

8001031019