

DEC 1 1972

NOTE FOR FILES

CONFERENCE CALL - AEC, DUKE POWER COMPANY AND BABCOCK AND WILCOX
ECCS DATA - NOVEMBER 30, 1972

A conference call was held among H. Sullivan (RS), I. Peltier (L:PWR-4), P. Barton and K. Canady (Duke), G. Kulynych and R. Straube (B&W) for the purpose of Regulatory Standards requesting technical information from B&W. The following pieces of information were requested and will be provided by B&W on December 1, 1972.

1. The scram point on pressure setting for small breaks assumed by B&W in CRAFT code.
2. Rod worth versus time curves (including time shift) used in analysis.
3. Density coefficient used in RELAP.
4. Flow versus pressure for high and low head pumps.
5. Containment pressure used in CRAFT code.

I. A. Peltier
I. A. Peltier, Project Manager
Pressurized Water Reactors Branch No. 4
Directorate of Licensing

cc: R. C. DeYoung
A. Schwencer
H. Sullivan

8001060028 A