

TELECON WITH DUKE - OCONEE SURVEILLANCE CAPSULE WITHDRAWAL PROGRAM
NOVEMBER 6, 1972

In response to our guidance on the withdrawal schedules for Oconee 1 & 2 surveillance capsules, Jim Ansell (Duke) questioned the 2, 11, 20, 30 year withdrawals because the Oconee capsules lead the vessel wall by a factor of 1.8, meaning that the corrosion would exceed 40 year life on the vessel.

Duke was asked to informally submit what it felt to be a reasonable schedule and we would review it and advise Duke accordingly.

I. A. Peltier
I. A. Peltier, Project Manager
Pressurized Waters Reactor Branch No. 4
Directorate of Licensing

cc:

R. DeYoung
A. Schwencer
M. Fairtile
I. Peltier

8001060 035 A