

*files*

JUN 9 1972

Note to Files

TELECON WITH KEN CANADY, DUKE POWER COMPANY - June 7, 1972

I discussed the subject of anti-corrosion lubricant for containment tendons with Franz Schauer, Structural Engineering Branch, and informed Jim Henderson of RO that Duke was forced to make a substitution for this product prior to ordering shipment of the Oconee Unit 3 tendons. Schauer felt that Duke would have no problems in making a suitable selection for a substitute product for No-Ox-Id (R) 500 which had been specified in the FSAR. He advised that Duke amend the FSAR, however, Henderson advised that Duke maintain a record of its selection for the benefit of the field inspector in the interim until the FSAR is revised.

I advised Canady of the above discussion. The tendons will be slipped (at Duke risk) using Visconorust 1601 manufactured by Viscosity Oil Company as the substitute product.

*JAP.*

I. A. Peltier

- cc: I. Peltier (2)
- A. Schwencer
- R. C. DeYoung
- J. Henderson
- F. Schauer

8001070 651 A