

Distribution:
 Docket file!
 PWR-2 Reading
 S. B. Kim
 D. Davis
 R. Lobel

07-267

3/23/73

POOR ORIGINAL

D. F. Ross, Chief, Core Performance Branch, L

CLAD COLLAPSE TIME CALCULATIONS FOR OCONEE 1

B&W told us in Lynchburg that for Oconee 1 fuel, they calculate a time to collapse of 26850 hrs using their CRECOL code. We calculated 19200 hrs with BUCKLE using the same assumptions. Both values are based on an increase of internal pressure due to gas release during that period. Using a constant BOL pressure of 775 psi throughout the operation, we calculate 15000 hrs, which probably will reduce to about 14500 hrs if we use as wall thickness = average - 2.

At present, we are looking at Oconee 1 first cycle only (about 7500 hrs). I think we can conclude that no collapse will occur. However, the next B&W cores we have to look at (Oconee 2, TMI-1) have a first cycle of 460 days (11000 hrs), which the applicants would present at about 15000 hrs to allow for uncertainties. B&W is considering this operating time, also, for Oconee 1; not necessarily as a first cycle, but as a method to get it reviewed by us now and avoid delays for upcoming reviews. The approach seems reasonable. However, 15000 hrs is about what we calculate with BUCKLE. That calculation is based on the conservative assumption of no pressure increase, and we could conclude that no collapse will occur during 12000 hrs of operation for Oconee 1 cladding and for other plants with similar cladding.

This conclusion, however, would solely be based on our BUCKLE calculation since Sang finds the B&W CRECOL code at present not acceptable. He, also, has reservations on the use of BUCKLE exclusively, particularly for predicted collapse times greater than about 12000 hrs. He feels that if we conclude no collapse for 12000 hrs, B&W will not exert a major effort in revising CRECOL or developing a new code.

I propose (1) that we find the first cycle of Oconee 1 with 7500 hrs acceptable, (2) that we find the cladding of the Oconee 1 type acceptable for a maximum of 12000 hrs, and (3) that we request B&W to revise CRECOL or develop a new code that is acceptable to us. For the last item, we should initiate action to get B&W moving.

Attached is a comparison of collapse times calculated for various conditions.

OFFICE ▶	PWR-2			
SURNAME ▶	HSchierling:bn		Hans Schierling PWR Project Branch No. 2 Directorate of Licensing	H.M.M.
DATE ▶	3/ /73			

8001090660

<u>CODE</u>	<u>t (wall)</u>	<u>T (clad)</u>	<u>P (internal)</u>	<u>t (collapse)</u>
CRECOL	.0265	657°F	775 BOL ⁽¹⁾	26850 hrs
BUCKLE	.0265	657°F	775 BOL ⁽¹⁾	19200 hrs
BUCKLE	.0265	657°F	775 Const	15000 hrs
BUCKLE	.02612 ⁽²⁾	657°F	775 Const	14500 hrs
BUCKLE	.024 ⁽³⁾	657°F	775 Const	9300 hrs

(1) increased P internal over core life due to gas release

(2) $.02612 = .0265 - 2\sigma \cdot .00019$
 $.0265 = \text{mean wall thickness}$
 $.00019 = \text{standard deviation,}$

(3) $.024 = \text{minimum wall, specified}$