

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER  
INCIDENT REPORT

TO: Mr. Norman C. Mosley

FROM: Duke Power Co.  
Charlotte, N.C. 28242  
Wm. O. Parker, Jr.

DATE OF DOCUMENT  
9-10-76

DATE RECEIVED  
9-27-76

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED  
1 signed

DESCRIPTION Ltr re their 6-23-76 ltr, their 8-16-76 ltr...furn addl info on RO-50-269/76-9 involving transmission lines....  
  
PLANT NAME: Oconee Units 1-2-3

ENCLOSURE  
  
NOTE: IF PERSONNEL EXPOSURE IS INVOLVED SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

DHL 9-29-76

BRANCH CHIEF: Schweseda  
W/3 CYS FOR ACTION  
LIC. ASST.: Sheffner  
W/1 CYS  
ACRS 13 CYS SENT TO LA

INTERNAL DISTRIBUTION

<del>REG FILE</del>				
NRC PDR				
I & E (2)				
MIPC				
SCHROEDER/IPPOLITO				
HOUSTON				
NOVAK/CHECK				
GRIMES				
CAGE				
PUTLER				
HAMAUER				
TRIBICO/MACCARY				
EISENHEIT				
PAER				
SHAO				
VOLLMER/HUNCH				
KRUEHR/J. COLLINS				

EXTERNAL DISTRIBUTION

TO: WATKINS, S.C.  
TIC:  
NSIC:

CONTROL NUMBER

9696

8001090 750

5

DUKE POWER COMPANY  
POWER BUILDING  
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

TELEPHONE: AREA 704  
373-4083

Regulatory Docket File

September 10, 1976

Mr. Norman C. Moseley, Director  
U. S. Nuclear Regulatory Commission  
Suite 818  
230 Peachtree Street, Northwest  
Atlanta, Georgia 30303




Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, 287

Dear Mr. Moseley:

Reportable Occurrence Report RO-269/76-9, which was submitted by our letter of June 23, 1976, described an incident in which Keowee Hydro Station Unit 2 was inadvertently separated from the underground and overhead transmission lines. A supplemental response to this report, submitted by our letter of August 16, 1976, stated that additional corrective action involving the electrical termination of control wiring would be completed by September 13, 1976. This corrective action is being performed, but due to problems encountered with material procurement and qualification, and due to an unanticipated large number of manhours required, this work is now scheduled to be completed no later than October 15, 1976.

Very truly yours,

  
William O. Parker, Jr.

EDB:vr

cc: Director, Office of Management Information  
and Program Control



5096