

JUN 3 1975

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Lowell E. Roe
Vice President
Facilities Development
300 Edison Plaza
Toledo, Ohio 43652

Gentlemen:

DISTRIBUTION

Docket File
Local PDR
VAMoore
kDeYoung
FSchroeder
AKenneke
MWilliams
RKleeker
OELD
OI&E (3)
LEngle
ASchwencer
EGoulbourne
ACRS (14)

NRC PDR
LWR 2-3 Rdg
JRBuchanan, ORNL
TBAbernathy, DTIE

We have concluded that the electrical drawings for the Davis Besse Nuclear Power Station, Unit 1 as submitted by you on March 12, 1975, are not acceptable as a final design document.

During the course of our evaluation, many cases have been identified where the electrical drawings do not conform with the criteria as specified in the PSAR. The general nature of the drawings make it impossible to evaluate the point by point identification from actuating system to actuator for safety grade equipment.

We request that you re-issue the electrical drawings after an audit has been made which will assure that the information presented constitutes a final design, and contains the necessary cross references, functional description and logics which will allow us to complete our review.

We are prepared to meet with you to discuss this matter. Please call us if you have any questions concerning the contents of this letter.

Sincerely,

[Redacted Signature]

Original Signed by
A. Schwencer

A. Schwencer, Chief
Light Water Reactors Branch 2-3
Division of Reactor Licensing

POOR
ORIGINAL

cc: See next page

8001150 817

RM
A

Toledo Edison Company

- 2 -

JUN 9 1975

cc: Donald H. Hauser, Esquire
The Cleveland Electric Illuminating Co.
P. O. Box 5000, Room 610
Cleveland, Ohio 44101

Gerald Charnoff, Esquire
Shaw, Pittman, Potts, Trowbridge
and Madden
910 - 17th Street, NW
Washington, D. C. 20006

Leslie Henry, Esquire
Fuller, Seney, Henry & Hodge
300 Madison Avenue
Toledo, Ohio 43604

POOR
ORIGINAL

OFFICE	x7886/LWR2-3	RL: S LWR 2-3				
SURNAME	L ^{GE} Englemer	ASchwencer				
DATE	6/9/75	6/9/75				