



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

AUG 10 1978

Docket No. 50-346

Toledo Edison Company  
ATTN: Mr. James S. Grant  
Vice President - Energy  
Supply  
Edison Plaza  
300 Madison Avenue  
Toledo, OH 43652

**IE FILE COPY**

Gentlemen:

This refers to the inspection conducted by Mr. L. R. Greger of this office on July 17-21, 1978, of activities at Davis-Besse Nuclear Power Station, Unit 1, authorized by NRC Operating License No. NPF-3 and to the discussion of our findings with Mr. T. Murray and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in noncompliance with NRC requirements, as described in the enclosed Appendix A.

This notice is sent to you pursuant to the provisions of Section 2.201 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations. Section 2.201 requires you to submit to this office within twenty days of your receipt of this notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further non-compliance; and (3) the date when full compliance will be achieved.

Based on discussions with your representatives at the site, we understand that you will define, in your procedures, the calibration techniques and frequencies for specific process and effluent monitors. Such definition will include the use of discrete sealed source linearity checks and fluid calibrations as appropriate.

78-18  
8001270 233

AUG 10 1978

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter, the enclosures, and your response to this letter will be placed in the NRC's Public Document Room, except as follows. If the enclosures contain information that you or your contractors believe to be proprietary, you must apply in writing to this office, within twenty days of your receipt of this letter, to withhold such information from public disclosure. The application must include a full statement of the reasons for which the information is considered proprietary, and should be prepared so that proprietary information identified in the application is contained in an enclosure to the application.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

A. B. Davis, Chief  
 Fuel Facility and  
 Materials Safety Branch

Enclosures:

1. Appendix A, Notice of Violation
2. IE Inspection Report No. 50-346/78-18

cc w/encs:

Mr. T. D. Murray, Station  
 Superintendent  
 Central Files  
 Reproduction Unit NRC 20b  
 PDR  
 Local PDR  
 NSIC  
 TIC  
 U. Young Park, Power  
 Siting Commission

OFFICE	RIII <i>W.F.</i>	RIII <i>W.F.</i>	RIII <i>ada</i>	RIII <i>AK</i>
SURNAME	Greger/bk	Fisher	Davis	Tambling <i>AK</i>
DATE	8/9/78		8/10/78	