

DISTRIBUTION:  
 Docket File (iron) ←  
 L. Reading  
 EP-1 Reading  
 EP-1 File  
 RP Reading  
 G. Knighton  
 H. Thompson

Docket No. 50-346

JAN 4 1973

Richard C. DeYoung, Assistant Director for Pressurized Water Reactors, L

DAVIS-BESSE, NUCLEAR POWER STATION, UNIT 1 - ACCEPTANCE REVIEW

Plant Name: Davis-Besse Nuclear Power Station, Unit 1  
 Licensing Stage: PCP  
 Docket Number: 50-346  
 Responsible Branch: PWR Branch No. 4  
 Project Manager: I. Peltier  
 Requested Completion Date: January 3, 1973  
 Description of Response: Acceptance Review Evaluation Report  
 Review Status: Complete

We have reviewed the "Environmental Report - Operating License Stage" and Section 16, Technical Specifications of the proposed Davis-Besse Final Safety Analysis Report. Since the "Environmental Report - Operating License Stage" is unchanged from the construction stage report, it is acceptable and its deficiencies have been identified in the Draft Environmental Statement. Although Section 16 does not contain any non-radiological environmental technical specifications, it is acceptable since the present regulations do not presently require these specifications in Section 16. The applicant should be notified that approved non-radiological technical specifications will be required prior to issuance of an operating license. The applicant should also forward results of preoperational monitoring activities as these results are available.

Original signed by Daniel R. Muller

Daniel R. Muller, Assistant Director  
 for Environmental Projects  
 Directorate of Licensing

- cc: A. Giambusso
- H. Denton
- R. Tedesco
- W. McDonald
- S. Hansauer
- J. Hendrie
- A. Schwener

OFFICE ▶	I. Peltier							
	H. Faulkner							
SURNAME ▶								
DATE ▶								

8001290605 A