

Docket No.: 50-346

NOV 21 1975

Toledo Edison Company  
ATTN: Mr. Lowell E. Poe  
Vice President, Facilities  
Development  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

DISTRIBUTION: w/o encl.

Docket File

NRC PDR w/encl.

L PDR - w/encl.

LWR 2-3 Rdg

TIC

VMoore

RKlecker

MWilliams

LEngle

EGoulbourne

ACRS (16) w/l encl.

ELD

IE (3)

Centlemen:

The purpose of this letter is to inform you of a potential safety question which has been raised regarding the design of reactor pressure vessel support systems for pressurized water reactors (PWR's).

On May 7, 1975 the NRC was informed by a licensee that certain transient loads on the reactor vessel support members that would result from a postulated reactor coolant pipe rupture immediately adjacent to the reactor vessel had been underestimated in their original design analyses.

It is the NRC staff's opinion that the question related to the treatment of transient loads in the design of reactor vessel support systems may apply to other PWR facilities, especially those for which the design analyses were performed some time ago. We have therefore initiated a systematic review of this matter to determine how these loads were taken into account on other PWR facilities, and what, if any, corrective measures may be required for specific facilities.

The results of licensee studies reported to date indicate that, although the margins of safety may be less than originally intended, the reactor vessel support system would retain sufficient structural integrity to support the vessel and that the ultimate consequences of this postulated accident which could affect the general public are no worse than originally stated. We have not completed our independent evaluation of these studies. However, based on the results of our evaluation of this phenomenon to date and in recognition of the low probability of the particular pipe rupture which could lead to additional transient loads on the support systems, we conclude that continued reactor operation and continued licensing of facilities for operation are acceptable while we conduct our generic review.

We request that you review the design bases for the reactor vessel support system for your facility(ies) to determine whether the transient loads described in the enclosure were taken into account appropriately in the design. Please inform us of the results of your review within 30 days.

OFFICE →

SURNAME →

DATE →

RA

The attachments to the enclosure are provided to indicate the information that could be needed, should we determine, on the basis of your review, that a reassessment of the vessel support design is required.

We are continuing to evaluate and review the methodology for calculating the subcooled blowdown loads with the nuclear steam system suppliers. You should contact your nuclear steam system supplier for information regarding these calculations if necessary to complete your review.

This request for generic information was approved by GAO under a blanket clearance number B-180225 (P0072). This clearance expires July 31, 1977.

Sincerely,

Original signed by

A. Schwerner, Chief  
Light Water Reactors Branch 2-3  
Division of Reactor Licensing

Enclosure:

Statement of the Problem

cc w/encl:

Donald F. Hauser, Esq.  
The Cleveland Electric Illuminating  
Company  
P. O. Box 5000, Room 610  
Cleveland, Ohio 44101

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts and  
Trowbridge  
910 17th Street, N.W.  
Washington, D.C. 20006

Leslie Henry, Esq.  
Fuller, Seney, Henry & Dodge  
300 Madison Avenue  
Toledo, Ohio 43604

OFFICE ➤	x788 6/LWR2-3 LWR 2-3:RL	C-LWR2-3:RL		
SURNAME ➤	E.Gould	ASchwerner		
DATE ➤	11/18/75	11/14/75		

## U.S. ATOMIC ENERGY COMMISSION

APRIL 1, 1971 - DECEMBER 31, 1975

4. SOURCE AND SNM

APRIL 1, 1971 - DECEMBER 31, 1975

## A. EXPLANATION OF AMENDMENT CODES

NEW LICENSEE	<input type="checkbox"/> NEW & LICENSE	<input type="checkbox"/> NEW & LICENSE	<input type="checkbox"/> CLERICAL CHANGE	<input type="checkbox"/> VOID	CONTROLLER	MAIL CONTROL	CHARGE
NEW LICENSE AND NEW LICENSEE	<input type="checkbox"/> OTHER AMENDMENT	<input type="checkbox"/> NO AMENDMENT			EDTA-10 [REDACTED]	22562	NAME ADDRESS

2151

## B. INDICATIVE INFORMATION:

NAME LAST FIRST MIDDLE	NAME LAST FIRST MIDDLE
NAME LAST FIRST MIDDLE	NAME LAST FIRST MIDDLE
NAME LAST FIRST MIDDLE	NAME LAST FIRST MIDDLE

ORGANIZATION NAME (ALPHABETIC SEQUENCE)
<b>Toledo Edison Company</b>
DEPARTMENT OR BUREAU

BUILDING, STREET	CITY	STATE	ZIP CODE
200 Madison Ave.	TOLEDO	OH	43652

TYPE OF APPLICANT	<input type="checkbox"/> U.S. GOVERNMENT AGENCY <input type="checkbox"/> INDIVIDUAL LICENSEE <input checked="" type="checkbox"/> ORGANIZATIONAL LICENSEE	DATE REQUEST RECEIVED	INSTITUTION CODE	PENDING PROG. CODE	ACTUAL PROG. CODE
		11-14-75	16538	23100	

SECONDARY PROGRAM CODES AS REQUIRED:					
#1	#2	#3	#4	#5	

LICENSE NUMBER	DATE LICENSE ISSUED OR ACTION COMPLETED	EXPIRATION DATE	
----------------	--	-----------------	--

APPLICANT'S COMMUNICATION DATED	CLASSIFICATION	ASSIGNED TO	RESULTING AMD. NO.
11-7-75	U		

ENCLOSURES:	Appl. for a SNM Lic. for Davis-Besse Nuclear Power Station Unit 1		
-------------	---	--	--

UNCLASSIFIED DESCRIPTION:			
Same as Above			

reg filecy (2) 50-346 ✓

EPA

IE (2)

Page

P.R.

I extra

11-10-75

POOR ORIGINAL