

UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

February 28, 1973

Toledo Edison Company  
ATTN: Mr. Glenn J. Sampson  
Vice President, Power  
Edison Plaza  
300 Madison  
Toledo, Ohio 43652

Docket No. 50-346

Gentlemen:

The attached Directorate of Regulatory Operations Bulletin No. 73-1, "Faulty Overcurrent Trip Delay Device in Circuit Breakers for Engineered Safety Systems", is sent to you to provide you with information we received from the Wisconsin Electric Power Company and the Rochester Gas and Electric Corporation concerning the Point Beach and Ginna pressurized water reactor facilities. This information may relate to the design, fabrication and performance of certain equipment at your facilities.

Action requested on your part is identified in Section B of the Bulletin. The information requested should be provided to this office, in writing, within forty-five days of your receipt of this letter.

Should you have any questions concerning this matter, we will be pleased to discuss them with you.

Sincerely yours,

Boyce H. Grier  
Regional Director


Attachment:  
RO Bulletin No. 73-1

bcc: RO Files  
DR Central Files  
PDR  
Local PDR

8001300 703

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) A 0240		See me about this. Note and return.	For con-ference. For sig-nature.	For action. For information.
TO (Name and unit) RO Chief, FS&EB RO:HQ (4) Licensing (4) DR Central Files Region I	INITIALS	REMARKS TOLEDO EDISON COMPANY <i>Files</i> 50-346		
	DATE			
TO (Name and unit) Region II PDR Local PDR NSIC DTIE	INITIALS	REMARKS		
	DATE			
TO (Name and unit)	INITIALS	REMARKS		
	DATE			
FROM (Name and unit) W. E. Vetter RO:III	REMARKS Attached is applicant's adequate reply dtd 3-12-73 to RO Bulletin No. 73-1.			
PHONE NO.	DATE 5-16-73			

USE OTHER SIDE FOR ADDITIONAL REMARKS



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

May 16, 1973

LOCAL PUBLIC DOCUMENT ROOMS

Enclosed are copies of documents listed below relating to  
Toledo Edison Company \_\_\_\_\_, Docket

No(s). 50-346

Letter dtd 3-12-73 fm G. J. Sampson to B. H. Grier.

This correspondence is submitted pursuant to arrangements made by  
the Public Proceedings Branch, Office of the Secretary, for use by  
the public.

Where possible, these materials should be punched and filed in a  
folder labeled as follows:

CORRESPONDENCE TO AND FROM APPLICANT OR LICENSEE  
(Excluding Environmental and Antitrust)

*Boyce H. Grier*  
Boyce H. Grier  
Regional Director

Enclosures:  
As noted above

cc: Washington Public Document Room, w/encl  
Central Mail & Files Unit, Document Room Clerk, w/o encl