

Docket File

AUG 1 1975

V. A. Moore, Assistant Director for Light Water Reactors, Group 2, RL

HYDROLOGIC ENGINEERING SUMMARY (SER)

PLANT NAME: Dvais-Besse 1
LICENSING STAGE: OL
DOCKET NUMBER: 50-346
MILESTONE NUMBER: 24-32
RESPONSIBLE BRANCH: LWR 2-3
REQUESTED COMPLETION DATE: July 14, 1975
REVIEW STATUS: Hydrologic Engineering Section, SAB - Awaiting Information

Enclosed is the hydrologic engineering summary (SER), prepared by G. Staley and E. Hawkins. The Ultimate Heat Sink (UHS) will remain as an unresolved issue until the applicant can resolve the calculated excess temperatures which could occur about 4 days after the design basis accident. We have been involved in informal discussions with the applicant and his consultant over the past two weeks in an effort to resolve the questions on the UHS. However, we have not reached any agreement and the UHS remains an unresolved issue.

Original Signed by
M. R. Denton

Harold R. Denton, Assistant Director
for Site Safety
Division of Technical Review
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: w/o encl.
A. Giambusso
W. McDonald
J. Panzarella

w/encl.
S. Hanauer
R. Heineman
H. Denton
SS Branch Chiefs
A. Schwencer
L. Engle
G. Staley

E. Hawkins
R. Klecker
D. Eisenhut
S. Varga
V. Benaroya
J. Fairbent
L. G. Hulman

POOR ORIGINAL

MEMO

OFFICE	TR: SAB	TR: SAB	TR: SAB	TR: SAB	TR: AD:SS
SURNAME	G. Staley:dr	E. Hawkins	L. G. Hulman	W. Gammill	H. Denton
DATE	7-30-75	7-30-75	7-30-75	7-31-75	8-1-75

8002040766