

AUG 5 1975

V. A. Moore, Assistant Director,  
for LWRs, Group 2, RL

SAFETY EVALUATION REPORT INPUT - METEOROLOGY

PLANT NAME: Davis-Besse Unit 1  
LICENSING STAGE: OL  
DOCKET NUMBER: 50-346  
MILESTONE NO.: 24-32  
RESPONSIBLE BRANCH: LWR 2-3  
REQUESTED COMPLETION DATE: June 30, 1975  
REVIEW STATUS: Meteorology Section (SAB) - Complete

Enclosed is the meteorology input to the Safety Evaluation Report on the subject plant. Two open items remain: 1) submittal and evaluation of the full year of data from the new onsite meteorological program; 2) submittal of additional information per R. G. 1.27 of the design basis meteorological conditions for the Ultimate Heat Sink. Resolution of these items will appear in a supplement to the SER.

This input was prepared by J. E. Fairbent and E. H. Markee, Jr., Site Analysis Branch, TR.

Original Signed by  
N. R. Denton

Herold R. Denton, Assistant  
for Site Safety  
Division of Technical Review  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated

DISTRIBUTION:  
DOCKET FILE  
NRR RDG  
SAB RDG

cc: w/o encl:  
A. Giambusso  
W. McDonald  
J. Panzarella

cc: w/encl:  
S. Hanauer  
F. Schroeder  
H. Denton  
SS Branch Chiefs  
A. Schwencer  
L. Engle  
J. Fairbent  
R. Klecker  
D. Eisenhut  
S. Varga  
C. Ferrell  
G. Staley

*WAS*

OFFICE	TR:SAB	TR:SAB	J. Levine TR:SAB	TR:AD/SS	
SURNAME	JFairbent:km	EMarkee	WGammill	HDenton	
DATE	7/15/75	7/15/75	7/1/75	7/17/75	