

Appendix A

NOTICE OF VIOLATION

Toledo Edison Company

Docket No. 50-346

Based on the inspection conducted on August 21-23, 1978, it appears that certain of your activities were in noncompliance with NRC requirements, as noted below. Both are infractions.

1. Section 2.3.1 of the Appendix B Environmental Technical Specifications limits "total residual chlorine in the effluent from the collection box . . ." to "A daily average concentration of 0.2 mg/l free available chlorine and a daily maximum concentration of 0.5 mg/l free available chlorine."

Contrary to the above, the 0.5 mg/l limit was exceeded between July 7, 1978 and July 10, 1978.

2. Section 5.1.1 of the Appendix B Environmental Technical Specifications requires in part that the Station Review Board's review responsibility will include . . . results of the Environmental Monitoring Programs prior to their submission in each Environmental Operating Report.

Contrary to the above, the Station Review Board did not review the first Annual Environmental Operating Report for the Davis-Besse Nuclear Power Station Unit 1.

80020407845