

*Docket Files*

JUL 2 1975

Docket No. 50-346

G. W. Knighton, Chief, Environmental Projects Branch 1, RL

REVIEW OF DAVIS-BESSE UNIT 1 TECHNICAL SPECIFICATIONS ON RADIOACTIVE EFFLUENTS

We have reviewed the Davis-Besse Unit 1 proposed technical specifications for radioactive releases. Based on our review, we find that the limiting conditions for operation are not based on the dose design objectives of Appendix I to 10 CFR Part 50, as required by 50.36a(b), amended May 5, 1975. We consider the licensee's submittal to be unacceptable for interim technical specifications.

In view of the requirements of Section IV and V of Appendix I, we recommend deferral of any action on these technical specifications until such time as the licensee provides information as to how he intends to comply with the requirements of Appendix I and submits plans and proposed technical specifications for keeping releases of radioactive material as low as practicable.

Original signed by:

John T. Collins, Chief  
Effluent Treatment Systems Branch  
Division of Technical Review

- cc: R. Tedesco
- W. Burke
- H. Thompson
- F. Cardile
- J. Boegli

bcc: ~~Docket Files~~  
ETSB Reading

8002050599

OFFICE		TR:ETSB	TR:ETSB			
SURNAME		WHewitt:lw	J Collins			
DATE		7/2/75	7/2/75			