

Appendix A

NOTICE OF DEVIATION

Toledo Edison Company

Docket No. 50-346

Based on the inspection conducted on February 13-16, 1978, it appears that certain of your activities were not in accordance with commitments, codes, standards, guides or acceptable practices, as noted below.

Table 6.1-2 of the "Davis-Besse Nuclear Power Station, Unit 1, Supplement to Environmental Report Operating Stage" commits the licensee to the collection of airborne particulate samples weekly at prescribed sampling stations.

Contrary to this commitment, the licensee collected airborne particulate samples intermittently during the period September 20, 1976 through December 13, 1976, at several sample locations.

8002050600