

POOR ORIGINAL

JUL 23 1976

Docket No. 50-346

R. C. Knop, Chief, Reactor Projects Section 1, Region III

THRU: J. H. Sniezek, Chief, Light Water Reactor Programs Branch, IE

SENSOR CALIBRATION REQUIREMENTS: DAVIS-BESSE 1, MEMORANDUM DATED JUNE 15, 1976

As discussed with R. Martin on July 22, 1976, the recommended action described in the subject memorandum is consistent with Item 4.0.4, Surveillance Requirements of the Standard Technical Specifications for B & W facilities. Item 4.0.4 states that "Entry into an operational mode or other specified applicability conditions shall not be made unless the surveillance requirement(s) associated with the limiting condition for operation have been performed within the stated surveillance interval or as otherwise specified."

As a result, sensor calibrations must be performed within the surveillance interval described in the Technical Specification prior to fuel loading or recalibration is necessary. This requirement applies to both certified and noncertified calibrations.

Original Signed by
P. J. Nolan

P. J. Nolan
Light Water Reactor Programs
Branch, IE

cc: R. D. Martin, NRC-III

F30200H1
RIP-770

8002050628

OFFICE	IE:LWB	IE:LWB				
SURNAME	FJNolan:jr	JHSniezek				
DATE	7/23/76	7/23/76				