

6.4

Control Room Habitability and Chlorine Protection

As stated in our SER, we required that remote chlorine detectors and additional breathing air be provided for the protection of the control room personnel against accidental release of chlorine. The response from the applicant indicated that such provisions have been made. We conclude that these safety measures plus the isolation capability of the control room ventilation system provide acceptable protection for the control room against accidental release of chlorine.

8002050654