

CONTROL BLOCK: | | | | | | | ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1	L	6	0	5	0	-	0	3	4	6	7	0	3	2	8	7	8	3	0	4	1	9	7	8	9											
7	8	60	61	62										69	74					75	80																
REPORT SOURCE		ROCKET NUMBER																										EVENT DATE					REPORT DATE				

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 3/28/78 at 1635 hours, it was discovered that during performance of a Surveillance  
0 3 | Test, personnel had inadvertently placed SFAS Channel 3 in test trip bypass and reset  
0 4 | the trip module. SFAS Channel 3 had been placed in the tripped condition due to the  
0 5 | inoperability of Radiation Monitor RE 2006. This placed the unit in excess of Action  
0 6 | Statement 9(a) of T.S. 3.3.2.1. The unit was then placed in L.C.O. 3.0.3. Three other  
0 7 | SFAS Channels were still operable during the few minutes that Channel 3 was removed  
0 8 | from the tripped condition. (NP-33-78-39)

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
I	B	A	C	I	N	S	T	R	U	E	Z				
9	10	11	12	13	14	15	16	17	18	19	20				
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TY		REVISION NO.							
7	8	0	3	2	0	3	L	1							
21	22	23	24	25	26	27	28	29							
ACTION FUTURE TAKEN ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRO-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E	H	Z	Z	0	0	0	0	Y	N	Z	Z	Z	Z		
30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this occurrence is personnel error. A technician inadvertently removed  
1 1 SFAS Channel 3 from the tripped condition. The unit was removed from L.C.O. 3.0.3  
1 2 and returned to Action Statement 9 of T.S. 3.3.2.1 at 1638 hours on 3/28/78, when  
1 3 Channel 3 was again placed in the tripped condition. Personnel will be made aware of  
1 4 recent changes to SFAS calibration procedures by circulating required reading lists.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (1) 5 (E) (28) % POWER (0) 4 7 (29) NA OTHER STATUS (30) METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) Surveillance Test ST 5031.14

ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (Z) (33) AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0 0 0	37 Z	38 NA					

PERSONNEL INJURIES				
NUMBER			DESCRIPTION	
0	0	0	(40)	NA

7 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE DESCRIPTION

1 3 2 (42) NA

8002050771

7 8 9 10  
PUBLICITY (45)  
ISSUED DESCRIPTION (44) NA  
10 68 69 80  
NRC USE ONLY