

MAY 12 1978

DISTRIBUTION

→ Docket File
EPB Reading File

Docket No. 50-346

MEMORANDUM FOR: D. B. Vassallo, Assistant Director for Light Water Reactors, DPM

FROM: Donald J. Skovholt, Assistant Director for Quality Assurance and Operations, DPM

SUBJECT: FIRE PROTECTION EMERGENCY PLANNING -
DAVIS BESSE NUCLEAR POWER STATION UNIT 1


Enclosed is an additional finding for inclusion in Section 13.3 of the Safety Evaluation Report in connection with the subject review.

R. W. Houston

Donald J. Skovholt *OK*
Assistant Director for Quality Assurance and Operations
Division of Project Management

Enclosure:
As stated

cc: w/enclosure
R. Boyd
R. DeYoung
R. Houston
L. Higginbotham, IE (3)
R. VanNiel
V. Leung
J. Stolz
L. Engle



OFFICE →	DPM;QA0:EPB	DPM;QA0:EPB	DPM;AD;QA0			
SURNAME →	RVanNeil;pv	RWHouston	DJskovholt			
DATE →	05/12/78	05/12/78	05/12/78			

DAVIS BESSE NUCLEAR POWER STATION UNIT 1

ADDITIONAL INFORMATION FOR SER

The staff performed an additional review of the Davis Besse Emergency Plan in conjunction with the Fire Protection Program review. The applicant has responded to the staff's concerns by letter dated May 3, 1978. We now find that the applicant's emergency plans include measures for coping with fire emergencies that conform with the applicable provisions of Regulatory Guide 1.101. In particular, a satisfactory written agreement is in effect with the Oak Harbor Fire Department which assures the availability of additional trained personnel and equipment for fire fighting support when called upon. In addition, the applicant has provided for annual training of these personnel to assure their necessary familiarity with the plant, access procedures, and radiation protection precautions, and for their participation in an annual drill or test exercise.