

Distribution: Docket File
 NRR Rdg. File
 RSB File
 T. Novak
 Mazetis chron

Docket No. 50-346

APR 11 1977

MEMORANDUM FOR: T. A. Ippolito, Chief, Instrumentation and Control
 Systems Branch, DSS

FROM: T. M. Novak, Chief, Reactor Systems Branch, DSS

SUBJECT: DAVIS BESSE Unit No. 1 PRESSURIZER HEATER INTERLOCKS

Your electrical review and comments are invited on the enclosed applicant's proposal to interlock the status of the DHR suction isolation valves with the pressurizer heaters. The intent of this modification is to preclude heatup to power operation should one or both of the DHR valves inadvertently be left open. Some of the electrical descriptions have been provided to you earlier in draft form.

Original Signed By
 T. M. Novak

Thomas M. Novak, Chief
 Reactor Systems Branch
 Division of Systems Safety

Enclosure:
 Applicant's Proposal

cc: D. Ross
 A. Szukiewicz
 G. Mazetis

Contact: G. Mazetis, NRR
 49-27341

OFFICE →	DSS- <i>RSB</i>	DSS- <i>RSB</i>				
SURNAME →	G. Mazetis:cj	T. Novak				
DATE →	04/08/77	04/11/77				