

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

CENTRAL FILES

AUG 26 1976

The Toledo Edison Company  
ATTN: Mr. Lowell E. Roe  
Vice President  
Facilities Development  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

Docket No. 50-346

Gentlemen:

Thank you for your letter dated August 6, 1976, pursuant to 10 CFR 50.55(e) regarding possible failure of zenor diodes used in the power sensor system of General Electric AK circuit breakers. We are looking forward to receipt of your final report on this matter.

Your cooperation is appreciated.

Sincerely yours,

E. L. Jordan, Acting Chief  
Reactor Construction and  
Engineering Support Branch

cc: Dr. Ernst Volgenau  
Director  
Office of Inspection  
and Enforcement

bcc w/encl:  
Central Files  
Reproduction Unit NRC 20b  
PDR  
Local PDR  
NSIC  
TIC  
U. Young Park, Power Siting  
Commission



8002060 728

S