Dochet Tile

AARR 8 1977

Docket No. 50-346

MEMORANDUM FOR: Domenic B. Vassallo, Assistant Director for Light

Water Reactors, DPM

FROM: Robert L. Tedesco, Assistant Director for Plant

Systems, DSS

SUBJECT: DAVIS RESSE UNIT 1 SAFETY EVALUATION REPORT

SUPPLEMENT # 3

Plant Name: Davis Besse Unit 1

Docket **umber: 50-346
Licensing Stage: 0L
Milestone Number: 27-22
Responsible Branch LWR 2
and Project Manager: L. Engle

Requested Completion Date: N/A

The DSS:PS, Instrumentation and Control Systems Branch supplemental input # 2 to the Davis Besse Unit I Safety Evaluation Report (SER) dated December 1976, was transmitted by memorandum to you on March 2, 1977. That input was based on our review of the FSAR through Amendment 43. Some, but not all, of the items identified in the previous transmittal have been resolved. The following items are those that have not been satisfactorily resolved and remain as outstanding items. We will report on our evaluation of these open items in the next supplement to the Safety Evaluation Report.

1. Final approval of the routing of Class IE wiring with non-Class IE wiring within Class IE logic cabinets and panels. Resolution subject

1) Review and approval of "noise test" procedures yet to be submitted and 2) Completion of the fault tests and submit test results for our review, prior to the first refueling (i.e. as stated in SSER # 3 Section 7.2). To ensure that these matters are acceptably resolved, we believe that it may be necessary to include them as licensing conditions. We are available to discuss this aspect with you.

Contact:

A. J. Szukiewicz

X27387

OFFICE*

SURNAME*

DATE*

FORM AEC-318 (Rev. 9-53) AECM 0240

\$\frac{2}{3} \text{ U. S. GOVERNMENT PRINTING OFFICE: 1974-326-166}

2. Final approval of the Class 1E electrical distribution system (i.e., the Millstone 2 concerns). Resolution subject to receipt of the applicant's complete analysis, yet to be submitted. See memorandum from A. J. Szukiewicz to L. Engle dated March 30, 1977, regarding the current status of this item (i.e. Item 3 of the reference memo). An acceptable response is required before power operation is permitted.

Ozerland depend by:

Robert L. Tedesco, Assistant Director for Plant Systems Division of Systems Safety

DISTRIBUTION:
DOCKET FILE
NRR READING FILE
ICSB READING FILE
PS READING FILE
A. SZUKIEWICZ

Enclosure: As Stated

cc: S. Hanauer

R. Heineman

R. Boyd

W. McDonald

T. Ippalito

J. Stolz

L. Engle

C. Miller

11. Srinivasan

F. Jablonski (Region III)

F. Rosa

PSTICSB(15 PS: 1587 PS-1088) DSS:PS 9

A: Szukiewicx: pob C. Miller T. Topolito R. Tedesco
4/6/77 4/6/77 4/7/77 4/2/77