

DISTRIBUTION:
 IE File
 IE Reading
 ROI Reading
 ADFC Chron
 GRKlingler
 Central File
 ADFC Facility

November 8, 1977

MEMORANDUM FOR: Domenic B. Vassallo, Assistant Director for
 Light Water Reactors, NRR

FROM: J. H. Sniezek, Assistant Director for Field
 Coordination, DROI, IE

SUBJECT: TOLEDO EDISON - DAVIS BESSE UNIT NO. 1
 (DN 50-346)

Region III has informed us that based on their inspection efforts, they have verified that Toledo Edison Company has modified the protective circuitry to provide breaker coordination and isolation of the onsite electrical system to permit the required Class IE equipment to operate in the event of offsite grid degradation in accordance with their submittal of July 18, 1977 (Serial Number 293) to J. E. Stoltz from L. E. Roe. This submittal to NRR was made in accordance with the requirement of Facility Operating License No. NPF-3 condition 2.C.(3)(q).

J. H. Sniezek, Assistant Director
 for Field Coordination
 Division of Reactor Operations
 Inspection, IE

cc: H. D. Thornburg, IE
 E. L. Jordan, IE
 N. M. Haller, IE
 N. C. Moseley, IE

OFFICE ▶	FC:ROI:IE	ADFC:ROI:IE			
SURNAME ▶	GRKlingler:LD	JHSniezek			
DATE ▶	11/8/77	11/9/77			

8002060 846

14

Q