

OCT 19 1976

POOR ORIGINAL

Docket No . 50-346
MS 27-12

MEMORANDUM FOR: J. J. Passallo, Assistant Director
for Light Water Reactors
Division of Project Management

FROM: J. P. Knight, Assistant Director
for Engineering

SUBJECT: TOLEDO EDISON, DAVIS-BESSEE NUCLEAR POWER STATION,
UNIT NO. 1 (OL), DOCKET NUMBER 50-346

Plant Name: Davis-Besse Nuclear Power Station, Unit No. 1
Suppliers: Babcock & Wilcox; Bechtel Associates
Docket Number : 50-346
Licensing Stage: OL
Responsible Branch and Project Manager: LWR 1; L. Engle
Reviewer: M. R. Hum
Requested Completion Date: October 26, 1976
Description of Response: Technical Specifications SB2 view
Best response Complete

Information submitted in the Proof and Review Copy of the Davis-Besse Nuclear Power Station, Unit No. 1, Technical Specifications has been reviewed by the Materials Integrity Section, Materials Engineering Branch, Office of Nuclear Reactor Regulation. Comments on our sections of the Technical Specifications are enclosed. The Technical Specifications for the reactor vessel material surveillance program are not complete since the applicant has not finalized a decision to implement the proposed integrated surveillance program nor has he provided documentation of the technical basis for review.

Distributions

JRR READING FILE
MTEB READING FILE
DOCKET FILE (50-346)

J. P. Knight, Assistant Director
for Engineering
Division of Systems Safety
Office of Nuclear Reactor Regulation

OFFICE →	DSS:MTEB <i>MRH</i>	DSS:MTEB <i>UP</i>	DSS:MTEB <i>WP</i>	DSS:AD <i>PK</i>		
SURNAME →	MRHum;Ja	UPotapovs	SSP <i>WP</i> Wicki	JPKnight		
DATE →	10/15/76	10/18/76	10/19/76	10/19/76		

8002060858

A

D. B. Vassallo

- 2 -

cc w/encl:

R. E. Heineman, SS
D. Eisenhut, OR
J. Miller, RR
J. P. Knight, ASS
J. Stolz, DPM
R. J. Losnak, DSS
S. P. Pawlicki, DSS
U. Potapovs, DSS
H. F. Conrad, DSS
W. Hazelton, DOR
V. Noonan, DOR
L. Angle, PM
J. H. McGough, OR
J. Roe, DOR
M. Polotsky, DSS
M. W. Hum, SS

cc w/o encl:

R. S. Boyd, PM
W. G. McDonald, IPC

OFFICE ➤						
SURNAME ➤						
DATE ➤						

Comments On The Proof And Review Copy of Davis-Besse Nuclear Power Station, Unit No. 1, Technical Specifications

ITEM	TECHNICAL SPECIFICATION REFERENCE	REQUIRED DATA OR REVISIONS
1	PG 3/4 4-28	Table 4.4-5 "Reactor Vessel Material Irradiation Surveillance Schedule" should be identified as "Open Pending Receipt of Information From Applicant." Specifically, the location and withdrawal of Capsule A-2 is subject to changes depending on the applicant's decision on the proposed integrated surveillance program.
2	PG B 3/4 4-10 and B 3/4 4-11	Additional documentation may be required from the applicant in order to establish the technical basis for the proposed reactor vessel material surveillance program and the degree of compliance with 10 CFR Part 50, Appendix H.
3	PG B 3/4 7-3	The data in Section 3/4.7.2 on the RT ^{NDT} of the steam generator should be provided by the applicant.