

Distribution:

- IE Files
- Central Files
- IE Reading
- RIP Reading
- LWRPB Chron

DEC 01 1976

John F. Stolz, Chief, Light Water Reactors
 Branch No. 1, Division of Project Management, NRR

DELETION OF NATURAL CIRCULATION TEST - TOLEDO EDISON CO. (DAVIS-BESSE 1)

The enclosed memorandum (with attachment) from R. C. Knop, dated November 10, 1976, states that the Toledo Edison Company has deleted the Natural Circulation Test planned for performance during the startup testing phase of Davis-Besse 1. The Natural Circulation Test is listed as a required test in Regulatory Guide 1.68.

We recommend that the Natural Circulation Test be included in the startup test program for Davis-Besse 1.

If your staff has any questions regarding this matter, G. R. Klingler is the cognizant IE contact (492-7451).

Original signed by
 JHS Sniezek

James H. Sniezek, Chief
 Light Water Reactor Programs Branch
 Division of Reactor Inspection
 Programs, IE

Enclosure:
 As stated.

cc: R. C. Knop, NRC:III
 G. Fiorelli, NRC:III
 G. R. Klingler, IE

F3 0233 H1
 RIP 996

POOR ORIGINAL

50-246
 Mem. 2

OFFICE ▶	IE:LWRPB	IE:LWRPB			
SURNAME ▶	GRKlingler	JHSniezek			
DATE ▶	11/30/76	1 / /76			

8002070545

Q