

MAY 26 1977

Distribution  
Docket File  
LWR 1 File  
J. Stolz  
L. Engle

Docket No. 50-346

MEMORANDUM FOR: Charles Miller, Section Leader, Instrument and Control Systems Branch, Division of Systems Safety

THRU: John F. Stolz, Chief, Light Water Reactors Branch  
Division of Project Management

Original Signed by  
John F. Stolz

FROM: Leon Engle, Project Manager, Light Water Reactors Branch  
No. 1, Division of Project Management

SUBJECT: NOISE TESTING ON THE REACTOR PROTECTION SYSTEM PER MIL.  
STANDARD 19900, SECTION 4.6.11 FOR DAVIS BESSE, UNIT 1

As you know, a part of the condition to Paragraph 203(K) to operating license NPF-3 for Davis Besse, Unit 1 requires that within four (4) months from issuance of the operating license, Toledo Edison Company shall provide acceptable noise test procedures in accordance with Mil. Standard 19900, Section 4.6.11 (or equivalent) for tests to be conducted on the non-Class IE circuits that interface with the Reactor Protection System, in order to satisfy the objectives of Section 4.6 of IEEE Standard 279-1968.

By letter (Serial No. 282) dated May 25, 1977, the applicant has submitted their noise test procedures for meeting the conditions as stated above.

We request that you review the applicant's submittal at this time in order that we may verify the acceptability of the applicant's submittal for the above stipulated licensing conditions. We request that the review be completed no later than June 18, 1977. This schedule date will allow us to ask additional questions, if required; allow the applicant to expedite contractual requirements required for conducting the noise tests; and allow us to verify in an appropriate amendment to the license that the conditions required to be met within the four months from issuance of the operating license have been met (August 22, 1977).

15/  
Leon Engle, Project Manager  
Light Water Reactors Branch No. 1  
Division of Project Management

cc: R. Hejneman  
R. DeYoung  
R. Tedesco  
D. Vassallo  
T. Ippolito  
A. Szukewicz  
G. Lear  
P. Wagner

OFFICE →	LWR 1	LWR1			
SURNAME →	L Engle	J Stolz			
DATE →	5/25/77	5/26/77			