

Docket File

MAR 21 1978

DISTRIBUTION
Docket File
EPB R/F
RWHouston

Docket File

Docket No. 50-346

MEMORANDUM FOR: John F. Stolz, Chief, Light Water Reactors Branch
No. 1, DPM

FROM: R. Wayne Houston, Chief, Emergency Planning Branch, DPM

SUBJECT: DAVIS BESSE 1 NUCLEAR PLANT - FIRE PROTECTION REVIEW

We have performed an additional review of the Davis Besse Emergency Plan in conjunction with the ongoing Fire Protection Program review. We find that the information provided in the Emergency Plan, through Revision 26 dated January 22, 1977, and the Fire Hazard Analysis Report, Revision 1 (submitted by letter dated January 11, 1978) does not fully conform to those fire protection elements found in Regulatory Guide 1.101, Emergency Planning for Nuclear Power Plants. The enclosed report contains position statements relative to our review for transmittal to the applicant.

Original Signed *RWH*
R. Wayne Houston

R. Wayne Houston, Chief
Emergency Planning Branch
Division of Project Management

Enclosure:
Position Statements

cc: w/enclosure
R. Boyd
R. DeYoung
D. Vassallo
D. Skovholt
C. Van Niel
L. Engle
V. Leung

OFFICE	EPB:DPM	DPB:DPM				
SURNAME	CVanNiel:kb	RWHouston				
DATE	3/19/78	3/2/78				

8002 120 858 F

EMERGENCY PLANNING BRANCH

1. The letter of agreement with the Oak Harbor Fire Department states that they will respond to requests for assistance from the Davis Besse plant. The letter does not provide sufficient evidence of the arrangements and agreements reached with this offsite agency. It is requested that this agreement be revised to more clearly describe the responsibility and authority of the fire department when fighting fires at the site (Regulatory Guide 1.101, Annex A, Section 5.3.2).

2. The Fire Hazard Report, Revision 1, at Table 4-1, (Sheet 9) identifies the training and drills provided for the onsite fire brigades and the Oak Harbor Fire Department. It does not state that the Fire Department will participate in a fire emergency drill at least annually. In addition, the Emergency Plan at sections 3.2.6, 8.5, and 9 is neither specific as to the frequency of the drills to be conducted, nor the training provided. Revise the Emergency Plan, at Sections 8 and 9 to include this information and conform to Regulatory Guide 1.101, Annex A, Sections 8.1.1 and 8.1.2.