

JUN 25 1975

POOR ORIGINAL

L. Engle  
LWR Branch 2-3  
Division of Reactor Licensing  
THRU: H. BRAISER

DAVIS BESSE 1, DOCKET NO. 50-346

A telephone conversation between R. Bosnak and S. Hou of NRC, T. Wilks and J. Vogle of Bechtel and E. Novak of TECO was held on June 24, 1975 to discuss the outstanding issues still remaining on Davis Besse #1 as listed in our letter of June 10, 1975. Items 2a and 2b on that list referring to the dynamic analysis for pipe whip restraint design will require further study on the part of the applicant to estimate the time required to address our concerns. All other items on the list seemed capable of satisfactory resolution but several do involve B & W input and they were not participants in the discussion. TECO estimated that with the exception of 2(a) and 2(b) the next revision (scheduled for July 14) to the FSAR could probably address all other issues, hopefully to our satisfaction. In view of the situation, it is recommended that the SER scheduled for submission to you by 6/30/75 be deferred until the applicant has responded, and his response can be evaluated by MEB.

Original signed by

R. J. Bosnak, Section Leader  
Mechanical Engineering Branch  
Division of Technical Review

cc: R. R. Maccary, TR  
A. Schwencer, RL  
J. P. Knight, TR  
S. H. Hou, TR  
R. J. Bosnak, ER

Docket File 50-346  
NRR Reading File  
TR:MEB File

OFFICE →	TR:MEB				
SURNAME →	RJBosnak:ju				
DATE →	6/27/75				

8002140864 A