

DAVIS BESSE 1

REVISED SER INPUT FOR

SECTION 3.5 - TORNADO MISSILE PROTECTION

We have reviewed the protection provided by the Davis Besse No. 1 Unit against tornado missiles and found that additional information is required. We have requested that the applicant provide information regarding the protection provided for the primary coolant makeup system. In view of the poor structural response estimated for the Arkansas Unit 2 plant we are also requesting that the applicant provide an estimate of the Davis Besse 1 capability to withstand the impact of tornado missiles from the standpoint of structural response. We will present, upon receipt of this information, the final results of our evaluation in a future supplement to the SER.

8002190 860