Docket File

JAN 2 2 13/4

Docket No. 50-346

Voss A. Moore, Assistant Director for LWR's Group 2, L

RESPONSE TO STANDARD REVIEW ASSIGNMENT - DAVIS-BESSE NUCLEAR POWER STATION, REVIEW OF FSAR CHAPTERS 13 & 14

Applicant: Toledo Edison Company Licensing Stage: OL Branch & Project Manager Requesting Assistance: LWR 2-3, I. A. Peltier Technical Review Branch Involved: L:OSB Requested Completion Date: January 1974 Review Status: Q2

The attached report contains information requests and/or position statements relative to our review of the subject SAR for transmittal to the applicant in accordance with the review schedule. The applicant recognizes that the following information requests, forwarded January 18, 1973, are still outstanding: 13.1.3.2 (resume for fifth Shift Foreman only), 13.7 (submission of the Industrial Security Plan), and 14.1 (test sequence schedule for preoperational, startup, and power ascension tests).

> Original Signed By Victor Stello

Victor Stello, Jr., Assistant Director for Reactor Safety Directorate of Licensing

8002190874 F

Enclosure: As stated

cc:

- S. Hanauer
- J. Hendrie
- A. Giambusso
- M. McDonald
- S. Varga
- A. Schwencer
- 1. A. Peltier
- R. W. Houston
- C. R. Van Niel

DISTRIBUTION: Docket, L Rdg., OSB Rdg., Elva Leins

OFFICE	L:658	L:0SB	LIAUINS	plan
SURNAME -	CRVanNTel: Td	RWHOUSton	ASCELLO	
	1/7/74	1/ 7/74	1/1//74	
	h	***		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~

Form AEC.31# (Rev. 9-53) AECM 0240

GPO CA3 16 81445-1 448-678

Davis-Besse Nuclear Power Station

Docket No. 50-346

13.0 Conduct of Operations

Information Requests

- Has an arrangement in writing been reached with the Ottawa County Sherift's Department? If so, provide a copy in Appendix C of the Emergency Plan.
- Do each of the Shift Foremen have a high school diploma or equivalent as required by ANSI N18.1?
- Will a written charter be provided for the Company Nuclear Review Board as required by ANSI N18.7, Section 4.2?

Position Statement

4. The answer to part C of Question 13.3.5 is unacceptable. Offsite support groups should be at least alerted when a Site Emergency occurs. If the Site Emergency should then degrade into an Offsite Emergency, the alerted offsite support groups would be better prepared to immediately provide an / measures required to protect the public. Revise Section 2.2.2 of the Emergency Plan to include such notification.