Docket File

DISTRIBUTION:

Docket File
L: Reading File
Branch Reading File
L: Administrative Assistant

ORIGINAL

DEC 5 1973

Docket No. 50-346

Richard C. DeYoung, Assistant Director for PWR's, L

FSAR FIRST-ROUND REVIEW

Plant Name: Davis- Besse Licensing Stage: OL Docket No: 50-346

Responsible Branch and Project Manager: I. Peltier, PMR-4
Technical Review Branch Involved: Reactor Systems Branch

Description of Review: Final Raview

Review Status: Not Complete

Our memorandum of July 3, 1973 identified several areas of the Davis-Desse FSAR which were incomplete to the extent that our First-Round Technical Neview Schedule was affected. Among these areas was the absence in the FSAR of LOCA analyses. At that time, we indicated that completion of First-Round Questions must therefore be delayed until the applicant had submitted the material.

Amendment 16, recently submitted on the Davis-Sesse docket, provides a number of FSAR Revisions in the areas of LOCA analysis and ECCS design. We have examined this material and the attached list provides the required additional information which we are able to identify at this time. We have noted your letter to J. M. Hendrie, dated October 19, 1973, in which you indicated that although the Davis-Besse facility completion has slipped, it may be prudent to review immediately material such as Amendment 16 to avoid packlooming these items. However, the LOCA analysis is not complete. The applicant has provided an analyses of one large break in Amendment 16, in accordance with present ECCS performance criteria, and indicates that other large break analyses will be provided to the revised AEC Acceptance Criteria at a later date. We accept this position and we further note that certain portions of the analyses presented for Davis-Besse are inconsistent with referenced BSW topical reports or other BAW SAR's. Therefore, the LOCA analysis is an open item on the docket which must be given First-Round review after receipt of analyses in accordance with the new ECCS rule. Should the new rule be published within the near future, then a complete ECCS analysis using the current Interim Acceptance Criteria will be required. With regard to small pipe breaks, for the second time the applicant has delayed submittal of these analyses. Again, we will not be able to complete our First-Round Duestions without this material.

OFFICE ▶	1: RSR /WAL	V L:RSB	L:RSB	L:RS	Many
SURNAME N	J. Mazetis	R. J. Mattson	T.M. Novak	V. Stello	
DATE	12/4 /73	12/4/73	12/4/73	12/5/73	

Form AEC-318 (Rev. 9-53) AECM 0240

GPO 043-10-81468-1 445-678

8002200934 A

Richard C. DeYoung

Please note the Staff positions now being taken for Davis-Besse on questions 3a, 3b, and C.

Original signed by:

Victor Stello, Jr., Assistant Director for Reactor Safety Directorate of Licensing

cc w/o encl. A. Giambusso, L W. G. McDonald, L

cc w/encl.
S. H. Hanauer, DRTA
J. M. Hendrie, L
V. Stello, L
T. Novak, L
I. Peltior, PYR-4

R. J. Mattson, L. J. Mazetis, L.

POOR
ORIGINAL

OFFICE ▶	
SURNAME >	
DATE >	