

Docket No. 50-302

NOV 11 1971

Agbabian-Jacobsen Associates  
8939 South Sepulveda Boulevard  
Los Angeles, California 90045

Contract No. AT(49-5)-3013

Application: Florida Power Corporation  
Crystal River Nuclear Generating Plant - Unit 3

Gentlemen:

The following information pertinent to the subject application is enclosed for your use in performing the services outlined in the Work Directive dated February 25, 1971:

Amendment No. 13

The action taken by this letter is considered to be within the scope and cost ceiling of existing Work Directives on this project.

Sincerely,

R. R. Maccary  
Assistant Director for Engineering  
Division of Reactor Standards

Enclosure:  
As stated

DISTRIBUTION:

Docket File  
EGCase, DRS  
RRMaccary, DRS  
AWDromerick, DRS  
DDandois, DR  
NHDavison, DRS  
Kathy Yorro, DRS  
PWR-4, DRL (2)  
FKaras, DRL (2)  
DRS 9.4.9

POOR ORIGINAL

+CRESS 1DRS Fm OFFICE ▶ 11/10/71 SURNAME ▶ DATE ▶	DRS:SEB <i>[Signature]</i> Davison:bv 11/11/71	DRS:SEB <i>[Signature]</i> Dromerick 11/11/71	DRS:AD/E <i>[Signature]</i> Maccary 11/11/71			
---	---	--	---	--	--	--

8. Page 8, Item 13--Change wording in the first sentence to read "Environmental qualification should be demonstrated by test for that electrical equipment required to function in the steam-air environment resulting from a high energy fluid line break."