

Docket File

JUN 11 1976

Docket No. 50-302

J. Stoiz, Chief, Light Water Reactors Branch No. 1, DPM

ACCEPTANCE REVIEW OF THE APPENDIX I INFORMATION FOR CRYSTAL RIVER, UNIT NO. 3

We have completed our acceptance review of the information provided by the applicant for Crystal River Unit No. 3, dated May 28, 1976, to meet the requirements of Section V.8 of Appendix I to 10 CFR Part 50. The applicant has provided information that will permit evaluation of Section II.D under the Annex to Appendix I of 10 CFR Part 50. The Radiological Assessment and Hydrology-Meteorology Branches find that the information provided is satisfactory for their evaluation; however, the Effluent Treatment Systems Branch requires additional information on release points. The questions are enclosed.

ORIGINAL SIGNED BY
JOHN T. COLLINS

John T. Collins, Chief
Effluent Treatment Systems Branch
Division of Site Safety and
Environmental Analysis

Enclosure:
Acceptance Review Questions

- cc: R. DeYoung
- M. Williams
- R. Vollmer
- L. Hulman
- W. Kregger
- W. Regan
- E. Markee
- S. Bajwa
- L. Engle
- W. Burke
- J. Boegli

POOR ORIGINAL

Distribution:
Docket File 50-302
NRR Reading File
DSE Reading File
ETSB Reading File
J. T. Collins

8003160294 1

OFFICE → X27775	DSE:ETSB JSBoegli:lw	DSE:ETSB WCBurke	DSE:ETSB JTCollins			
SURNAME →						
DATE →	06/11/76	06/11/76	06/11/76			

ACCEPTANCE REVIEW QUESTIONS
ON APPENDIX I ANALYSES FOR
CRYSTAL RIVER NUCLEAR UNIT
DOCKET NO. 50-302

1. Table 6 of NUS-1721 (May 1976) refers to Figure 2-48 (FSAR). This figure does not provide sufficient detail to show relative location of the release points to adjacent structures. Provide plan and elevation figures that will permit scaling relative distances and directions.
2. In addition to our enclosure 2, request 6.d provide information on the shape of release point flow orifice. A drawing or description of each release point should indicate if there are diffusers or spreaders.

POOR ORIGINAL