

NOV 2 2 1973

locket

DOCKET NO.: 50-302

APPLICANT : FLORIDA POWER CORPORATION (FPC)

FACILITY : CRYSTAL RIVER, UNIT 3

SUMMARY OF MEETING HELD ON OCTOBER 18, 1973

A meeting was held in the Bethesda office on October 18, 1973, to discuss FPC's responses on Quality Assurance (QA). The staff emphasized the need for FPC to describe how they comply with 10 CFR 50, Appendix B. We reiterated that FPC must provide more definitive responses regarding their commitments on the eighteen QA criteria, the QA manager's responsibilities and how FPC will implement the above. FPC agreed to resubmit additional information on these issued by November 3, 1973.

A list of attendees is enclosed.

POOR ORIGINAL

Two additional points discussed are general help:

Quality Assurance

Discussions centered on deficiencies in FPC's responses to our request for additional information on QA matters. Principal areas of concern were:

1. The need for FPC to better describe FPC policy commitments on QA matters.
 2. FPC should enumerate on its responses to more clearly define how it meets the eighteen QA criteria and how it intends to implement such a program.
 3. FPC needs to fully describe the responsibilities of the QA manager.

FPC agreed to provide additional information on the above three items by November 3, 1973.

B. C. Buckley, Project Manager

~~Pressurized Water Reactors Sr. No.~~
Directorate of Licensing

OFFICE		Pressurized Water Reactors Div. No. 4 Directorate of Licensing	Check
SURNAME	Enclosures		
DATE	Attendance List	8008 170 682	A

NOV 26 1973

ENCLOSURE 1

CRYSTAL RIVER UNIT 3

DOCKET NO. 50-302

MEETING - OCTOBER 18, 1973

Atomic Energy Commission

B. Buckley

J. Costello

A. Garland

J. Gilray

E. Vallish (RO:II)

Florida Power Corporation

B. DuBois

B. Griffin

M. Kleinman

J. Rodgers