

50-302

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: D.A. Butler

FROM: Florida Power Corp.
St. Petersburg, Florida
J.T. Rodgers

DATE OF DOCUMENT

5-4-76

DATE RECEIVED

5-7-76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

3

DESCRIPTION

Ltr. trans the following.....

ENCLOSURE

Introduction of Clad-Creep-Collapse Analysis

(3 Originals Received)

PLANT NAME: Crystal River # 3

SAFETY

FOR ACTION/INFORMATION

ENVIRO

SAB 5-10-76

ASSIGNED AD :

D. Young

ASSIGNED AD :

BRANCH CHIEF :

Butler

BRANCH CHIEF :

PROJECT MANAGER:

Engle

PROJECT MANAGER :

LIC. ASST. :

Rushbrook

LIC. ASST. :

INTERNAL DISTRIBUTION

REG FILE

SYSTEMS SAFETY

PLANT SYSTEMS

ENVIRO TECH

NRC PDR

HEINEMAN

TEDESCO

ERNST

I & E (2)

SCHROEDER

BENAROYA

BALLARD

OELD

LAINAS

SPANGLER

GOSSICK & STAFF

ENGINEERING

IPPOLITO

MIPC

MACCARY

SITE TECH

CASE

KNIGHT

OPERATING REACTORS

GAMMILL (2)

HANAUER

SIHWEIL

STELLO

STEPP

HARLESS

PAWLICKI

HULMAN

OPERATING TECH

PROJECT MANAGEMENT

REACTOR SAFETY

EISENHUT

SITE ANALYSIS

BOYD

ROSS

SHAO

VOLLMER

P. COLLINS

NOVAK

BAER

BUNCH

HOUSTON

ROSZTOCZY

SCHWENCER

J. COLLINS

PETERSON

CHECK

GRIMES

KREGER

MELTZ

HELTEMES

AT & I

SITE SAFETY & ENVIRO

SKOVHOLT

SALTZMAN

ANALYSIS

RUTBERG

DENTON & MULLER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Crystal River, E1

NATL LAB

BROOKHAVEN NATL LAB

TIC

REG. V-IE

ULRIKSON (ORNL)

NSIC

I.A. PDR


ASLB

CONSULTANTS

ACRS /6 HOLDING/SENT

4611

8003 170 702



Regulatory

File Cy.

**Florida
Power**
CORPORATION



May 4, 1976



Dr. D. A. Butler, Chief
Light Water Reactors Branch #4
Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

In Re: Florida Power Corporation
Crystal River Unit #3
Docket No. 50-302

Dear Dr. Butler:

Supplementing the report on our replacement Fuel Assembly 3A33 dated 3/26/76, we are forwarding to you the attached two pages titled, "Introduction".

With this submittal, we will have supplied all information requested of us or B&W on this subject for your review and acceptance.

We have been verbally so informed of your acceptance and all necessary clearances have been obtained leading to shipment of this element to Crystal River this week.

Very truly yours,

J. T. Rodgers
J. T. Rodgers
Asst. Vice President

JTR/iw
Attachments.

4402

INTRODUCTION

The following information further describes the clad creep-collapse and fuel clad interaction evaluations referenced in the Mechanical Section of the Report on Replacement Fuel Assembly 3A33, dated March 26, 1976.

Clad Creep-Collapse Analysis

The clad creep-collapse analysis was performed in accordance with material properties and design procedures set forth in Topical Report BAW-10084P-A, entitled "Program to Determine In-Reactor Performance of B&W Fuels". The evaluation was completed using the NRC approved CROV creep ovalization analysis code as described in Section 3. of the above referenced report. In addition, the following input conservatisms were introduced:

1. The fuel rod is assumed to contain only 90.9 % TD fuel.
This decreases the prepressure level due to densification.
2. The minimum specification prepressure level is used.
3. The mean plus 2σ cladding ovality and mean minus 2σ cladding thickness were used, as determined from manufacturing as-built dimensions.

Results of the analysis indicate a time to collapse $>14,000$ hours. This is sufficiently greater than the required $10,320$ hours associated with the single cycle burn of assembly 3A33.

Fuel Clad-Interaction Analysis

The fuel-clad interaction and fuel swelling affects are addressed in the clad strain analysis. Of the pellet densities used in assembly 3A33, the slightly larger nominal diameter, 90.9% TD pellets represent the limiting fuel clad interaction case at the peak pellet burnup seen by the assembly. ($22,600$ MWD/MTU with uncertainty included.) This is consistent with the fact that the peak pellet burnup is less than the transition from the $0.16\% \Delta V/V / 10^{20}$ f/cc rate for the other pellet designs of this assembly. (See Table 1 of the March 26th Report.)

Accordingly, clad strain analyses were performed on the 90.9% TD fuel corresponding to the worst-case specification dimensions and the as-built, two sigma dimensions.

The analyses were performed in accordance with material data and design models set forth in Section 3 of Topical Report BAW-10054, Revision 2, entitled "Fuel Densification Report". This represents the same approach as used in the Crystal River SAR analysis except that the following additional conservatisms were introduced for the 3A33 analyses:

1. Input pellet diameter was set as the nominal OD plus tolerance value (worst case specification analysis).
2. Input clad ID was set as the nominal ID minus tolerance value (worst case specification analysis).
3. Input pellet diameter was set as the mean OD plus the 2σ value (as-built analysis).
4. Input clad ID was set as the mean ID minus the 2σ value (as-built analysis).

The results of the above analyses indicate that the total circumferential strain resulting from fuel clad interaction for the worst-case-specification analysis and the as-built dimensions analysis are 0.80% and 0.48% respectively. This is well below the allowable value of 1.42%.