

Central Files

B20002

JUL 17 1978

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

Docket Nos. 50-329/330

MEMORANDUM FOR: Stephen A. Varqa, Chief, LVR Branch #4, DPM

FROM: Paul F. Collins, Chief, Operator Licensing Branch, DPM

SUBJECT: RESPONSE TO REVIEW PLAN ASSIGNMENT - MIDLAND, UNITS 1/2, REVIEW OF CONDUCT OF OPERATIONS (SECTIONS 13.2 AND 13.5)

PLANT NAME: MIDLAND UNITS 1/2

APPLICANT: Consumers Power Company

LICENSING STAGE: OL

BRANCH AND LPM REQUESTING ASSISTANCE: LVR-4, D. Hood

REVIEW BRANCH INVOLVED: OLB:DPM

DESCRIPTION OF REVIEW: Review of Conduct of Operations, Sections 13.2 and 13.5

REVIEW STATUS: Second Round Questions

We have reviewed Sections 13.2 and 13.5 of the FSAR. Based on our review, we have determined that the additional information, indicated in Attachment A, is necessary for us to complete our review. We will be able to discuss the item, should the applicant so desire.

ORIGINAL SIGNED BY  
P. F. COLLINS  
Paul F. Collins, Chief  
Operator Licensing Branch  
Division of Project Management

8006120 556  
A

Enclosure:  
Attachment A

cc: with enclosures  
D. J. Skovholt  
W. P. Haass  
D. B. Vassallo  
R. A. Hartfield

DISTRIBUTION:  
OLB R/F PDR  
OLB Facility File JJ Buzy  
PF Collins RC DeYoung  
RJ Campbell  
Central Files

M 4  
60

OFFICE	D. Hood	OLB:DPM /	OLB:DPM		
SURNAME		RJCampbell:jb	PF Collins		
DATE		7/17/78	7/17/78		

ATTACHMENT A

MIDLAND UNITS 1/2

Docket Nos. 50-329/330

440.0 Operator Licensing Branch

441.8 Amend FSAR Section 13.2 to include fire protection training  
(13.2) as required by revision 1 of Standard Review Plan 13.2. The applicable sections of SRP 13.2 that pertain to fire protection training are I.5, II.2, II.6, III and IV.