FS&EB ACTION CONTROL FORM

A.	Action Code CDR #228
	Name of Licensee and Facility Consumers Power Company - Midland
	Docket No. or License No. 50-329/330
	TitleCDR Evaluation and Followup
	Origin Date Rec'd
3.	FS&EB Branch Coordinator:
	Bryan X Dreher
	Ellis Paulus
	Completion Requested by
	Action Requested of:
	DREMP M&PPOB EPB RPB ADCO
	B CB TAB OOE Region III
	Pate Requested 2/13/74 Completion Requested by Routine Handl:
	eference Letter dated Jan. 28, 1974 from Stephen H. Howell to Knuth
	ction Requested
	a accordance with PI 0600/6, "Construction Deficiency Reporting",
t	he Consumers Power Company's Midland deficiency report of January 28,
1	974 covering design control-prototype testing is being assigned to
	egion III for evaluation of the technical adequacy of the corrective
	ate Action Completed
C	ose-out (Date & Method)
C	mments: If completion date is not consistent with your work schedule,
P	ease let us know.

J. G. Davis, Deputy Director for Field Operations Directorate of Regulatory Operations

8006100 288

Concumers Partier Company

Stephen H. Howell Vice President


General Offices 212 West Michigan Avenue, Jackson, Michigan 49201 - Area Code 517 788-0550

January 22, 1974

MIDIAND PLANT
Safety Analyses
Docket Nos 50-329 and 50-330

Mr. A. Giambusso, Deputy Director Reactor Projects Directorate of Licensing Office of Regulation US Atomic Energy Commission Washington, DC 20543

Dear Mr. Giambusso:



The studies necessary to quantify the impact that this revision may have on the safety analyses reported in the Preliminary Safety Analysis Report are under way. The general effect will be a change in the level of stored energy of fuel as well as in the time response of some transients. Based on Babcock & Wilcox's present evaluation, this revision will not affect the steady state analysis because the basic data from which the curve is derived are valid. It is these basic data that are used for the steady state calculations. The particular effect on kinetic behavior is determined only by an evaluation of the safety analyses. To indicate the magnitude of this revision, preliminary calculations on Oconee 2 show that a reduction in the maximum linear heat rate of less than 1.0 kM/ft should offset the effects of this change in the specific heat.

We will revise the safety analyses to reflect these changes and submit the revised analyses with the Final Safety Analysis Report. We understand that Babcock & Wilcox will be discussing this information with you on a generic basis in an effort to keep you fully informed of further developments.

Yours very truly,

SHH/sib

8006090630

720