

D & MORRIS

UNITED STATES OF AMERICA
ATOMIC ENERGY COMMISSION

In the Matter of
CONSUMERS POWER COMPANY
(Midland Plant)

)
)
)

Docket No. 50-329
Docket No. 50-330

SUMMARY OF APPLICATION

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

October 30, 1970

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE _____

RECORDS FACILITY BRANCH

8006180644

A

TABLE OF CONTENTS

- 1.0 INTRODUCTION
- 2.0 BACKGROUND
 - 2.1 Consumers Power Company
 - 2.2 Applicant's Participation in the Development of Nuclear Power
 - 2.3 Need for This Plant
 - 2.4 Considerations Entering Into Selection of This Plant
 - 2.5 Process Steam To Be Supplied to Dow Chemical Company
- 3.0 THE EVOLUTION OF DESIGN OF THE MIDLAND FACILITY
 - 3.1 Reactors
 - 3.1.1 Shippingport - The First Commercial PWR
 - 3.1.2 Indian Point I - An Early Large Commercial PWR
 - 3.1.3 Connecticut-Yankee - A Subsequent Large PWR
 - 3.1.4 Robert Emmett Ginna - A Large PWR Which Recently Began Operation
 - 3.1.5 Oconee 1 - A Modern Large PWR
 - 3.1.6 Midland Units 1 and 2
 - 3.2 Evolution of Engineered Safeguards
 - 3.3 Reactor Buildings
- 4.0 ENVIRONMENTAL QUALITY
 - 4.1 Introduction
 - 4.2 Air Quality
 - 4.3 Water Quality
 - 4.4 Solid Wastes
 - 4.5 Land Use and Aesthetics
 - 4.6 National Environmental Policy Act
- 5.0 OTHER GOVERNMENTAL AGENCIES
- 6.0 SITE CHARACTERISTICS
 - 6.1 Location
 - 6.2 Population
 - 6.3 Land Use
 - 6.4 Meteorology
 - 6.5 Surface Water Hydrology
 - 6.6 Groundwater Hydrology
 - 6.7 Site Geology
 - 6.7.1 General
 - 6.7.2 Salt Solution Cavities
 - 6.8 Seismology
 - 6.9 Foundations
- 7.0 DESCRIPTION OF MIDLAND PLANT
 - 7.1 Introduction
 - 7.2 Reactor and Reactor Coolant System
 - 7.3 Reactor Building
 - 7.4 Engineered Safety Features
 - 7.5 Instrumentation and Control

TABLE OF CONTENTS (Contd)

7.6 Electrical Systems
7.7 Auxiliary Systems
7.8 Steam and Power Conversion Systems
7.9 Process Steam System
7.10 Cooling Pond
7.11 Radioactive Waste System
7.12 Shielding

8.0 SAFETY ANALYSIS

9.0 COMPARISON WITH OTHER PWR

10.0 ENVIRONMENTAL MONITORING PROGRAM
10.1 General Radiological Surveillance
10.2 Aquatic Ecological Surveillance
10.3 Aquatic Radiological Surveillance

11.0 TECHNICAL QUALIFICATIONS
11.1 Consumers Power Company
11.2 Bechtel
11.3 The Babcock & Wilcox Company

12.0 QUALITY ASSURANCE AND QUALITY CONTROL
12.1 Introduction
12.2 Consumers Power Company
12.3 Bechtel
12.4 The Babcock & Wilcox Company

13.0 COMMENTS ON ACRS REPORTS

14.0 FINANCIAL QUALIFICATIONS

15.0 COMMON DEFENSE AND SECURITY

16.0 CONCLUSION

APPENDICES

A COMPARISON OF PWR DESIGN PARAMETERS

B FIGURES

C RESEARCH AND DEVELOPMENT PROGRAMS OF INTEREST TO ACRS
FIRST IDENTIFIED IN EARLIER CASES

1 1.0 INTRODUCTION

2 This document, prepared and filed by Consumers Power Company
3 (hereinafter sometimes called "applicant"), is a summary of the
4 application filed by the Company for permits from the Atomic Energy
5 Commission to construct a two unit nuclear power plant, on a site
6 in Midland Township, Midland County, Michigan.

7 This document has been prepared in accordance with the provisions
8 of 10 CFR, Part 2, Appendix A, Section II (e), as a summary of the
9 Company's *application, including a summary description of the re-
10 actors, an evaluation of the considerations important to safety and a
11 comparison of the proposed reactor design with the design of the re-
12 actors previously approved or built. To assist interested members of
13 the public in understanding the complex technical material dealt with
14 in this report, applicant has endeavored to use nontechnical language
15 whenever possible.

16 To enhance the usefulness of this summary, applicant has included
17 within it summaries of reports rendered by the Advisory Committee on
18 Reactor Safeguards on the application pursuant to Section 29 of the
19 Atomic Energy Act of 1954 as amended (42 USC Section 2039), and infor-
20 mation incorporated in the docket in accordance with the National Environ-
21 mental Policy Act of 1969, P.L. 91-190.

*The application and other pertinent documents currently in the record
of this proceeding may be examined at the Grace Dow Memorial Library,
1710 W St Andrews Road, Midland, Michigan.

1 In addition to a summary of the application, this document contains
2 a summary of applicant's program to consult with and obtain comments of
3 interested Federal, state and local government officials in planning for
4 the Midland Plant. In cases where applicant is required to obtain
5 state and local approvals or permits in connection with the design or
6 construction of the plant, or approvals from other Federal agencies, this
7 summary describes the status of applicant's efforts to obtain such approvals.

8 Some of the information in this summary with regard to applicant's
9 programs to consult with or obtain regulatory approvals of government agen-
10 cies other than AEC is not in the record of this proceeding, or is based
11 on more recent information. Applicant is prepared to establish such in-
12 formation by appropriate evidence at the hearing to whatever extent is
13 determined to be appropriate in the course of this proceeding.

14 Applicant is prepared also to substantiate any other information
15 summarized in this summary, or in the application as amended, by appro-
16 priate testimony in the hearing as may be appropriate for determination
17 of any issues before the Atomic Safety and Licensing Board.

18 As set forth more fully in the ensuing sections of this summary,
19 two nuclear units and appurtenant facilities, which have been designated
20 as the Midland Plant (hereinafter sometimes called "the plant"), will
21 occupy an 1190.38-acre site on the southerly shore of the Tittabawassee
22 River opposite the industrial complex of The Dow Chemical Company at
23 Midland. The units are presently scheduled to begin commercial operation
24 in November 1974 and November 1975. Both units are conventional pressurized

1 water reactors (PWR) designed together to generate about 1,300,000 kW
2 of electricity. They are similar to many other pressurized water
3 reactors which are in operation or under construction.

4 The plant will provide a base load electrical capacity which will
5 be needed by the applicant and by the Michigan Power Pool to meet pro-
6 jected electricity requirements. The plant will also provide the process
7 steam requirements of The Dow Chemical Company.

8 The plant is being designed and all planning is being carried out,
9 with preservation and enhancement of the environment as important con-
10 siderations. Assurance of safety has been of paramount consideration
11 in selecting a design for the Midland Plant. The plant is being de-
12 signed to keep radioactivity in plant effluents at the lowest practi-
13 cable level and far below concentrations which independent government
14 authorities find to be satisfactory. The small quantities of radio-
15 active waste materials in liquid effluents will be well below concen-
16 trations which such authorities find to be satisfactory for drinking
17 water. The cooling pond will protect against discharge of deleter-
18 ious heat. All aspects of plant design, construction and operation
19 will be carried out in accordance with applicable requirements of
20 Federal, state and local government agencies.

21 One important environmental consideration in planning for the
22 plant is the fact that operation of the plant will enable the Michigan
23 Power Pool to shut down a number of older plants which consume
24 fossil fuel. The new plant will also enable The Dow Chemical Company to
25 shut down all of its existing steam plants which now burn fossil fuel.

1 As stated in the September 23, 1970 letter from the Federal Power Commission
2 to the Atomic Energy Commission concerning the applicant's proposed Midland
3 Plant:

4 "Under the prevailing fuels situation, if the Company had
considered a fossil-fueled plant as a substitute for the
two Midland nuclear units, the plant would of necessity have
been a coal-fired plant and, as such, its operation would
have added particulate and gaseous pollutants to the atmos-
phere. The nonpolluting characteristics of nuclear generation
can be expected to aid in maintaining air quality in the
Company's service area."

5 Construction of additional electric generating capacity to meet
6 projected increased requirements is a responsibility of Consumers
7 Power Company as a public utility under the laws of the State of
8 Michigan. Fulfillment of that responsibility is essential to the
9 health and economic well-being of the citizens of Michigan and surround-
10 ing areas, as well as to the national defense. The Midland Plant is
11 important in meeting these goals and applicant believes it will do so in a
12 manner which is consistent with the highest environmental and ecological
13 considerations.

1 2.0 BACKGROUND

2 2.1 Consumers Power Company

3 Applicant is a combination electric and natural gas utility
4 serving more than 1,000,000 electric customers in the lower peninsula
5 of Michigan. Applicant's electric service area covers approximately
6 27,100 square miles and contains a population of approximately
7 3,200,000. Principal cities receiving electrical service are Battle
8 Creek, Bay City, Flint, Grand Rapids, Jackson, Kalamazoo, Midland, Muskegon,
9 Pontiac and Saginaw. Industries in the territory served by applicant
10 include automobile and automobile equipment, primary metals, chemicals,
11 fabricated metal products, pharmaceuticals, machinery, oil refining,
12 paper and paper products, food products and a diversified list of other
13 industries.

14 The maximum net demonstrated capability of applicant's intercon-
15 nected system, which system is shown in Appendix B, Figure 2, exceeds
16 3,700,000 kilowatts. The net maximum demand on the interconnected sys-
17 tem was 3,377,275 kilowatts on December 15, 1969. In order to serve
18 this load, applicant presently operates ten fossil fuel steam-electric
19 plants, one nuclear steam-electric plant, fourteen hydroelectric plants,
20 seven gas turbine peaking plants and one internal combustion plant. In
21 addition, applicant and The Detroit Edison Company are the principal
22 members of the Michigan Power Pool. Applicant is directly or indirectly
23 interconnected with other utilities in Michigan, Indiana, Illinois
24 and Ohio as a member of the MIIO group. The MIIO group consists in
25 varying capacities of applicant, The Detroit Edison Company, Indiana &
26 Michigan Electric Company, The Toledo Edison Company, Northern
27 Indiana Public Service Company, Ohio Power Company and Commonwealth

1 Edison Company. There are several agreements among various of
2 the companies in regard to operations, facilities and coordination.
3 The agreements provide for the construction of interconnection
4 facilities and for the terms and conditions on which power is inter-
5 changed. Applicant is interconnected through The Detroit Edison
6 Company with The Hydro-Electric Power Commission of Ontario. Applicant
7 is also a party to the East Central Area Reliability Coordination Agree-
8 ment along with eighteen other parties. The purpose of this agreement
9 is to augment reliability of the parties' bulk power supply through
10 coordination of planning and operation of generation and transmission
11 facilities. Applicant sells electric energy at wholesale to a number of
12 municipalities, rural electric cooperatives and investor-owned public
13 utilities.

14 Applicant and The Detroit Edison Company operate under an agreement
15 which provides for pooled operation of their systems, coordination of
16 systems planning, design and construction, the rendering of mutual assist-
17 ance during emergencies, and the effecting of maximum economy of produc-
18 tion in providing the electric power requirements of each system. Each
19 system is thus dependent on the other system, as well as on its own,
20 having new generation available on schedule. In addition, both The
21 Detroit Edison Company and applicant must be concerned with the construc-
22 tion programs of utilities in neighboring states and such utilities in
23 turn are concerned with and affected by their construction programs. To
24 this end, the Michigan Power Pool has made interconnection with utilities
25 in Indiana and Ohio and is coordinating its construction and operation
26 through the MIIO group and the East Central Area Reliability Agreement.

1 The advantage of interconnection and coordinated construction and
2 operation is that savings can be made in investment for reserve
3 capacity; additional energy supplies can be obtained during time of
4 emergency; at times, more economical energy can be obtained from
5 neighboring systems; advantage can be taken of the fact that peak loads
6 occur at different times on different systems; required maintenance
7 can be carried out at more convenient times and economies of scale
8 can result because of the ability to construct larger plants.

9 2.2 Applicant's Participation in the Development
10 of Nuclear Power

11 Applicant owns and operates the Big Rock Point Nuclear Plant
12 located near Charlevoix, Michigan. This plant is a boiling water
13 reactor with a nameplate capacity of 75 MWe. Applicant received a con-
14 struction permit for the Big Rock Point Plant dated May 31, 1960, a
15 provisional operating license, dated August 30, 1962, permitting opera-
16 tion at power levels up to 157 MW_t, and a final operating license dated
17 May 1, 1964, permitting operation at power levels up to 240 MW_t. Since
18 startup in 1962, the Big Rock Point Plant has produced net in excess
19 of 2,423,164 MWe. This reactor was one of the early privately owned
20 reactors for the production of electric power.

21 Applicant has constructed the Palisades Nuclear Plant located near
22 South Haven, Michigan and is presently engaged in a public hearing on
23 its application for an operating license for that plant. The Palisades
24 Plant is designed to have an initial capacity of about 700 MWe with an
25 ultimate capacity of about 821 MWe.

1 Applicant has been a pioneer in the use of nuclear power for elec-
2 tric generation and has participated in the design, construction and
3 operation of nuclear plants for over ten years. It has a large and ex-
4 perienced body of personnel that have operated nuclear plants and have
5 overseen the design and construction of nuclear plants.

6 2.3 Need for This Plant

7 The demands on applicant's system have doubled over the last ten
8 years and are expected to more than double over the next ten. It is neces-
9 sary for an electric utility to forecast its demand well in advance and to
10 start planning and building new generation long before it is needed. It is
11 estimated that applicant's peak loads will be 5,130 megawatts in the winter
12 of 1974-75 and 5,600 megawatts in the winter of 1975-76. In order to meet
13 this projected demand and to provide the 17-18* percent reserve margin
14 which applicant considers desirable, applicant is planning additions to its
15 present net demonstrated capability of 3,731 megawatts. These addi-
16 tions to capacity, in addition to the Palisades Plant, include an
17 1,800 megawatt pumped storage project for operation in 1973 which
18 is jointly owned with The Detroit Edison Company; the two-unit
19 1,300 megawatt Midland Plant for operation of one unit in 1974 and
20 the other in 1975, and two approximately 660 megawatt oil-fired in-
21 termediate load units for operation, respectively, in 1975 and
22 1976. Of the units planned for this time period, only the Palisades
23 and Midland Plants are base load units, ie, designed to operate

*This 17-18 percent margin is an increase from the 15.5 percent margin previously considered desirable by Consumers Power Company. The increase results from the increased outage problems experienced by large generating units and difficulties of scheduling maintenance of such large units with only a 15.5 percent reserve margin.

1 more than 50 percent of the time. Both the pumped storage plant and
2 the oil-fired units are designed to operate less than 50 percent of the
3 time to meet various levels of peak demand. Both Midland units are
4 needed on schedule if applicant's system is to maintain an adequate
5 margin of reserves to assure reliable electric service to the State of
6 Michigan.

7 While the Federal Power Commission's (FPC) comment to the AEC on
8 the environmental aspects of the Midland Plant, dated September 23, 1970,
9 does not reflect the latest data available to applicant or the current
10 construction schedules available to applicant, FPC's assessment of the
11 need for the Midland Plant is accurate:

12 ". . . , the load supply situations in the Pool . . .
should be judged in the light of recent experience
with availability of large new generating units.
During the period of October 1973 and February 1975,
the Pool is planning to place on the line two fossil-
fuel steam units with capacities in excess of 650
megawatts and a nuclear unit with a capacity in ex-
cess of 1,000 megawatts [in addition to the Midland
Plant]. The indicated reserve margins assume avail-
ability of these units as planned. The recent history
of large fossil and nuclear steam generating units,
however, reveals that during the first few years of
initial operation, the availability of large units
can be highly uncertain. On this account, we feel
that the indicated reserve margins of the Michigan
Power Pool are not excessive and that prudence dic-
tates the need of the Midland Units 1 and 2 as a
bulwark against the possible unavailability of
existing capacity."

13 In addition, the Federal Power Commission stated:

14 "It is evident, therefore, that if Consumers Power
is to meet expected loads . . . , reliance cannot be
placed on import of required firm power in lieu of
construction of Midland Nuclear Units 1 and 2."

1 The Federal Power Commission, also, recognized the unavailability of
2 practical fossil-fired and hydroelectric alternatives to the Midland
3 Plant.

4 The Midland Plant is, therefore, necessary to meet peak loads and
5 to help assure a reliable supply of electric power. In addition, the
6 plant is necessary to assure continued growth and development in the
7 State of Michigan. The addition of the Midland Plant will enable
8 applicant to provide electricity for industrial, commercial and residen-
9 tial development and will aid the applicant in maintaining a rate
10 structure which is competitive with the cost of energy in other states.
11 This in turn will aid the state in attracting and retaining industry.
12 Also, low cost process steam will enable Dow to maintain its growth in
13 Michigan. In addition, the availability of electric power in Michigan
14 will enable applicant to aid utilities in other states during short-term
15 emergencies. Operation of the Midland Plant will enable the Michigan
16 Power Pool and Dow Chemical Company to retire older, less efficient
17 fossil-fueled units with resulting economies and with resulting benefits
18 to the environment. For all of these many reasons, the Midland Plant is
19 a desirable and necessary addition to the applicant's system and to the
20 electric supply system of the State of Michigan.

21 2.4 Considerations Entering Into Selection of the Plant

22 The Midland Plant features, including the location, grew out of a
23 mutual need of The Dow Chemical Company and Consumers Power Company to
24 meet their respective and increasing energy demands. Dow, which had
25 traditionally generated all of its own process steam and electrical

1 requirements at Midland with dual-purpose generating plants, was
2 becoming less competitive for the manufacture of energy intensive
3 products due to prohibitive fossil-fuel cost escalation. In order
4 to take advantage of the fuel economies of a large nuclear plant
5 but lacking the projected load to utilize the full capacity of such
6 a plant, Dow requested Consumers Power Company to consider an allo-
7 cation of Dow's process steam requirements as part of a Consumers
8 Power Company facility. Consumers Power Company's system energy
9 capacity forecast for 1974-75 indicated a need for increased gener-
10 ating capacity in the Midland-Bay City-Saginaw load center area.
11 It was thus natural for Dow and Consumers Power Company to look
12 toward a dual-purpose nuclear facility to meet their respective
13 energy needs.

14 Inherent in the considerations given to the general features
15 of the plant, was the long-time Dow experience with steam extraction
16 which in turn gave promise of minimizing the plant waste heat. This
17 feature gave rise to a plant efficiency similar to the most efficient
18 fossil-fueled plants, and thus appreciably reduced the normal nuclear
19 plant heat rejection.

20 The air pollution resulting from the current Dow generating
21 plants will be eliminated. The use of standard components to enhance
22 reliability was a requisite in the Midland Plant.

23 By considering the mutually compatible energy needs of Dow and
24 Consumers Power Company, a nuclear-fueled steam extraction plant using
25 a cooling pond designed to dissipate the total plant heat rejection is
26 the most appropriate means of meeting these needs.

1 2.5 Process Steam To Be Supplied to Dow Chemical Company

2 The steam to The Dow Chemical Company will be supplied from the
3 secondary side of tertiary system heat exchangers. A complete system
4 of shell and tube evaporators will be installed for both the high-
5 pressure and low-pressure steam supplies. The design flows to Dow
6 are 400,000 lb/hr of the high-pressure and 3,650,000 lb/hr of the
7 low-pressure steam.

8 The feedwater in the tertiary loop from which the process steam
9 will be produced comes from Lake Huron. At any given time, the feed-
10 water stream will consist of condensate return from Dow, and makeup
11 water from the lake which is demineralized before being transmitted
12 to applicant.

13 It is a criterion for the process steam that no radioactivity be
14 added to the feedwater by the process of transforming it to steam in
15 the tertiary system heat exchangers. To meet this criterion, the
16 process steam will be separated from the reactor coolant water, which
17 contains radioactivity, by two barriers: a steam generator and a
1 tertiary system heat exchanger. In addition, the radioactivity in
19 the process steam will be compared with the radioactivity in the makeup
20 water. If the activity level in the steam indicates radioactivity
21 leakage to the steam from the secondary system, the flow of process
22 steam from the specific tertiary heat exchanger producing the steam
23 will be terminated.

1 3.0 THE EVOLUTION OF DESIGN OF THE MIDLAND FACILITY

2 As suggested in Appendix A, 10 CFR Part 2, this portion of the
3 applicant's summary is a "discussion of the evolution of the proposed
4 reactor design, including associated engineered safety features, from
5 the design of reactors which have previously been approved or built."
6 As will appear from this discussion and the information set forth in
7 other sections of this summary, the principal design features of the
8 Midland Plant are based upon designs incorporated in earlier plants.*

9 3.1 Reactors

10 3.1.1 Shippingport - The First Commercial PWR

11 The first nuclear reactor constructed to generate electricity for
12 commercial uses was Shippingport. Design of the plant began in 1951
13 and it first produced electricity for commercial use in 1957.

14 Shippingport is a four-loop PWR. Its initial core was about
15 6 feet high and 6-1/2 feet in diameter, was composed of zirconium-clad
16 fuel plates and rods and produced approximately 335 MW_t. It employed
17 32 cruciform rods for control and was contained in a reactor vessel
18 approximately 32 feet tall and 9 feet in diameter. Each coolant loop
19 contained one reactor coolant pump and one steam generator. This
20 reactor operated at a pressure of approximately 2000 psia and an average
21 temperature of 520°F and produced sufficient steam at approximately 600
22 psia to generate approximately 90 MWe.

*For a comparison of important parameters for the Midland Plant
with those for a number of other PWR, see Section 9.0 and
Appendix A of this summary.

1 The Shippingport reactor at the time of its design was a reason-
2 able extension of known reactor technology which had been obtained
3 principally from the Navy nuclear program. The plant demonstrated
4 that commercial generation of electricity by nuclear power plants was
5 feasible and it pointed the way for the design of future PWR. Speci-
6 fically, it showed that:

- 7 1. A light water-cooled and moderated nuclear reactor fueled
8 with slightly enriched uranium could be used to reliably
9 produce steam to generate electricity.
- 10 2. Normal central station-type turbine generator equipment
11 could be coupled with a nuclear reactor.
- 12 3. Fuel element burnups of 3000 to 4000 MWD/MTU were obtainable.
- 13 4. The use of concrete for shielding was practical.
- 14 5. The use of 600 psi saturated steam in a turbine generator
15 was practical.

16 3.1.2 Indian Point I - An Early Large Commercial PWR

17 A construction permit was issued by the Atomic Energy Commission
18 to Consolidated Edison for Indian Point I in May of 1956. This reactor
19 began commercial operation in 1962.

20 Indian Point I is also a four-loop PWR. Its original core was
21 composed of 120 box-type fuel elements, each of which was 6 inches
22 square, 8 feet long and contained stainless steel-clad thorium dioxide
23 fuel rods. It produces approximately 585 MW_t, employs 21 cruciform
24 rods for control and is contained in a 9-foot, 9-inch diameter
25 stainless-clad, carbon steel reactor vessel. Each coolant loop

1 contains two reactor coolant pumps, and one steam generator. The
2 reactor operates at a nominal pressure of approximately 1550 psia
3 and an average temperature of 495°F and produces sufficient steam
4 at approximately 420 psia such that after it is superheated to 1000°F
5 by oil-fired superheaters approximately 275 MWe are generated.

6 3.1.3 Connecticut-Yankee - A Subsequent Large PWR

7 Construction of this plant began in May of 1964 and commercial
8 operation was achieved in 1967.

9 Connecticut-Yankee, also a four-loop PWR, has a multiregion core
10 composed of 157 fuel assemblies of 204 stainless steel-clad uranium
11 dioxide fuel rods each. The core is arranged in three concentric fuel
12 regions. At the end of each fuel cycle of approximately one year's
13 length, one-third of the fuel assemblies is removed, the remaining
14 two-thirds is rearranged and a fresh one-third is inserted. The fuel
15 cycle management program permits the achievement of high average fuel
16 burnups of approximately 25,000 MWD/MTU.

17 The reactor produces approximately 570 MWe and employs 45 cluster
18 rod assemblies for control. The design of these assemblies is sig-
19 nificantly different from that of the bladed cruciform rods used in
20 previous reactors. It consists of twenty neutron absorber rods joined
21 together at the top by a spider-like bracket. The absorber rods travel
22 in guide tubes located within the fuel assemblies. This cluster control
23 rod significantly decreased the neutron power peaking that was exper-
24 ienced with the use of cruciform control rods. To further improve the
25 reactor fuel cycle and decrease neutron power peaking, chemical shim

1 control is also employed in the Connecticut-Yankee reactor. This
2 shim control consists of adding a small quantity of boric acid to
3 the reactor coolant. The boric acid serves two functions: (1) It
4 increases the subcritical margin of the core on shutdown, and (2) it
5 gradually and precisely compensates for the thermal activity changes
6 due to fuel depletion and fission product accumulation as it is slowly
7 removed over the course of one fuel cycle.

8 The highly successful operation of the Connecticut-Yankee PWR and
9 also the similar San Onofre plant have been significant factors in es-
10 tablishing the confidence that utilities now have with regard to nuclear
11 power plants being able to produce electrical power safely and efficiently.

12 3.1.4 Robert Emmett Ginna - A Large PWR Which Recently
13 Began Operation

14 Ginna achieved commercial operation in early 1970. It is a two-
15 loop PWR with a core power rating of 1455 MW_t and is capable of a gross
16 output of approximately 496 MWe. Its 12-foot long core is made up of
17 121 fuel assemblies, each having 179 Zircaloy-4-clad fuel rods arranged
18 in 14 x 14 arrays and containing uranium dioxide pellets. Sixteen of
19 the rod positions in each fuel assembly are occupied by control rod
20 guide tubes and one position is occupied by an instrument tube.

21 The initial core loading was divided into three roughly concentric
22 regions. New fuel will be loaded into the center region at each yearly
23 refueling.

24 Reactor control is provided by a combination of cluster rod assem-
25 blies and chemical shim. Of the 33 control rods, 29 are full-length and

1 4 are part-length. The full-length rods have a total reactivity worth
2 sufficient to shut the reactor down from any operating condition even
3 with the highest worth rod stuck in its fully withdrawn position. The
4 four part-length control rods are provided to flatten axial neutron flux
5 variations and to dampen out any spatial xenon oscillations that may re-
6 sult from power changes.

7 The plant is designed to accept a step-load change of 10 percent
8 and ramp-load changes of 5 percent per minute between 15 percent and 100
9 percent of full power. The plant is designed for automatic load following,
10 and partial load rejection without, trip.

11 In-core instrumentation in the form of remotely positioned ion
12 chambers provides neutron flux distribution information to the plant
13 operator.

14 3.1.5 Oconee 1 - A Modern Large PWR Not Yet in Commercial Operation

15 Duke Power Company's Oconee Units 1, 2 and 3 received construction
16 permits in 1967. In September 1970, Oconee 1 received favorable ACRS
17 review to commence operation and is scheduled to produce commercial
18 power by mid-1971.

19 Midland Units 1 and 2 are the ninth and tenth reactors of a series
20 of Babcock & Wilcox Company (B&W) reactors of essentially identical
21 design.* Oconee Unit 1 is the first of this series. It is a two-
22 loop PWR with an ultimate core power rating of 2568 MWe and a net
23 electrical output of 886 MWe. Each loop contains a straight tube once-
24 through steam generator and two reactor coolant pumps. A pressurizer

*The 8 prior units are listed on Lines ⁶⁻¹⁰~~10-11~~ on Page 11-3.

1 connected to one of the two loops maintains the reactor coolant in a
2 subcooled state. Each of the two reactor coolant outlet pipes contains
3 a calibrated flow tube which is used to measure the reactor coolant flow
4 rate during operation. The reactor will operate at a nominal pressure
5 of 2200 psia with an average coolant temperature of 580°F. The reactor
6 has a 12-foot long core made up of 177 fuel assemblies, each of which
7 contains Zircaloy-4-clad fuel rods. The fuel rods contain uranium di-
8 oxide pellets and are arranged in 15 x 15 arrays. Sixteen of the rod
9 positions in each fuel assembly are occupied by control rod guide tubes
10 and one position (the center one) can accept an instrument tube.

11 The reactor vessel consists of an 171-inch ID cylindrical shell
12 approximately 8-1/2 inches thick.

13 Reactor control is provided by a combination of cluster rod assem-
14 blies and chemical shim. Of the 69 control rods, 61 are full-length and
15 8 are part-length. In-core instrumentation consists of an assembly of
16 self-powered neutron detectors and a thermocouple.

17 3.1.6 Midland Units 1 and 2

18 An application for construction permits for Midland Units 1 and 2
19 was filed with the AEC in January 1969. Unit 1 is expected to produce
20 commercial power and process steam in 1974.

21 The reactors for these units are essentially identical to those of
22 the eight B&W units scheduled to precede them into operation. The Mid-
23 land units are described in Section 7 of this document.

24 The basic design of the fuel assemblies, control rod assemblies,
25 control rod drives, steam generators, and instrumentation has been

1 confirmed by proof-testing performed by B&W and the actual components
2 will be proven in operation on earlier B&W designed plants.

3 3.2 Evolution of Engineered Safeguards

4 Engineered safeguards systems are defined as that equipment, of
5 either static or dynamic design, which is utilized in the event of a
6 reactor accident to limit the environmental consequences of that
7 accident.

8 The history of engineered safeguards features for commercial pres-
9 surized water power reactors began when the Shippingport project was
10 authorized in July 1953. Seventeen years of design experience have
11 been accumulated in safeguards design and the current engineered safe-
12 guards equipment installed on present-day plants is the result of design
13 evolution and extensive research and development. During the course of
14 these years, the improvements and capabilities of engineered safeguards
15 features have maintained or increased the protection provided the public
16 against the potential releases of fission products resulting from postu-
17 lated reactor accidents.

18 Today there are about 60 commercial pressurized water power reactors
19 that have been designed, constructed or are in operation. All of these
20 plants have engineered safeguards systems to provide protection to the
21 public against radiation hazards.

22 Shippingport Engineered Safeguards Features

23 The Shippingport plant⁽¹⁾, which was designed for 335 MW_t, contained
24 some of the engineered safeguards features presently utilized in current
25 designs. A brief summary discussion of these is as follows:

1 1. The reactor system was housed in a steel container designed
2 to withstand the energy release from a loss-of-coolant accident.
3 The resultant design pressure was 52.8 psia. This building was
4 leak tested and showed that the leakage rates of a fraction of
5 1 percent per day were achievable.

6 2. The reactor plant had a safety injection system to supply
7 emergency core coolant in the event of a loss of integrity
8 of the reactor coolant system.

9 This system contained two 1500 gpm pumps that were automatically
10 actuated when the reactor coolant system pressure decreased to 500 psia
11 and was designed to reflood the core, thereby preventing significant
12 melting or release of fission products.

13 Engineered Safeguards at Later Plants

14 With the advent of higher performance reactors, the single safety
15 injection system concept of the Shippingport plant was supplanted by a
16 combination of high-pressure injection systems and low-pressure injection
17 systems to provide emergency coolant to the core in the event of the loss
18 of reactor coolant system integrity. These systems provided a wider range
19 of coolant replacement capability in both flow and pressure to insure
20 adequate core cooling for a complete range of rupture sizes. Typical of
21 such designs was the Yankee plant⁽²⁾ which had a 770 psia high-pressure
22 injection system and a 300 psi low-pressure injection system, utilizing
23 boric acid for criticality control.

24 The inability of the natural heat sinks within the reactor building
25 to absorb sufficient quantities of heat to prevent overpressurization of

1 the reactor building structure required the use of supplemental cooling
2 as plant size increased. Both emergency building cooling equipment and
3 spray systems were utilized to prevent overpressurization during the
4 course of the postulated accident. Typical plants which have utilized
5 these concepts during this evolutionary period are Connecticut-Yankee
6 plant and the Ginna plant.

7 To meet the AEC's siting criteria (10 CFR 100) as plants became
8 larger, either greater exclusion distance or engineered safeguards
9 systems capability must be extended to include reduction of iodine con-
10 centration within the post-accident reactor building atmosphere to within
11 acceptable limits defined by the site characteristics.

12 Two basic types of iodine and particulate fission product removal
13 systems have been incorporated in past designs. One of these is a
14 filter system which removes particulates and absorbs iodine on charcoal
15 as the reactor building air is recirculated through the filtering system.
16 The second employs the reactor building spray droplets to impact par-
17 ticulate matter and wash the iodine from the steam-air atmosphere. The
18 washing is accomplished by a chemical reaction between the iodine and
19 the chemicals contained in the spray droplets.

20 A typical plant design which included filters for removal of par-
21 ticulate material and iodine absorption was Connecticut-Yankee, which was
22 licensed for construction in 1964.

23 Spray removal systems using a sodium thiosulfate reagent for iodine
24 removal were first incorporated on Metropolitan Edison's Three Mile
25 Island Plant⁽³⁾.

1 The most recent engineered safeguards feature incorporated to pro-
2 vide core protection during the postulated loss-of-coolant accident is
3 the static core flooding system. Thus, the dynamic injection systems
4 were supplemented with fast-acting core flooding systems. These systems
5 contain emergency coolant in pressurized tanks directly connected to the
6 reactor coolant system. These tanks of coolant are separated from the
7 reactor coolant system by check valves that open when the reactor coolant
8 pressure decreases below the pressure in the tanks. The net effect is a
9 rapid insurge of coolant to the core that is proportional to the system
10 demand for coolant replacement. Thus, a large leak would cause rapid
11 reactor coolant system depressurization and maximum flow from the flooding
12 system. Smaller ruptures have lower rates of depressurization and lower
13 flow rates from the core flooding tanks. These static devices respond
14 rapidly to the needs of the reactor for coolant makeup and do not require
15 an external source of power.

16 This type of engineered safeguards feature was first incorporated
17 on the Consolidated Edison Indian Point II⁽⁴⁾ and Duke Power Company
18 Oconee plants⁽⁵⁾ and has also been incorporated in applicant's Palisades
19 Plant.

20 Engineered Safeguards Features of Midland Plant

21 The Consumers Power Company's Midland Plant Units 1 and 2 incor-
22 porate engineered safeguards features that have been the result of plant
23 design improvements over the past several years. Those features which
24 are incorporated to satisfy the siting requirements for the Midland plant
25 are described in detail in applicant's Preliminary Safety Analysis Report.

1 The reactor is housed in a low leakage (0.1 percent by volume per
2 day) steel-lined prestressed concrete reactor building. Automatic iso-
3 lation of lines entering the reactor building is effected in the event
4 of an accident requiring isolation. The reactor core is protected
5 against fuel melting during loss-of-coolant type accidents by emergency
6 core cooling systems. These systems are the core flooding system, the
7 high-pressure injection system, and the low-pressure injection system.
8 Radioactive iodine released into reactor building during a postulated
9 loss-of-coolant accident is removed by a building spray system that
10 utilizes a sodium thiosulfate solution to rapidly and irreversibly react
11 with the iodine before it can leak to the environment.

12 Supplemental reactor building cooling is provided by two independent
13 systems, a reactor building cooling system and the reactor building spray
14 system. These prevent post-accident building overpressurization and pro-
15 vide for rapid depressurization of the building, thus reducing the leakage
16 rate to the environment.

17 Summary

18 The evolution of the reactor designs to larger sizes since
19 Shippingport has prompted the development of improved engineered safe-
20 guards features to provide environmental protection against the conse-
21 quences of a major fission product release associated with a postulated
22 loss of reactor coolant. These have evolved from the orderly analysis of
23 design needs and the designs are based upon a wealth of experimental data
24 that verifies design requirements and achievable performance.

1 The engineered safeguards features incorporated on the Midland plant
2 are essentially identical to those used on other reactor plants presently
3 approved for construction. Accordingly, the engineered safeguards fea-
4 tures used for this plant represent fully engineered designs that have
5 been thoroughly evaluated and found to provide protection of the public
6 well within AEC guideline values.

7 3.3 Reactor Buildings

8 The Midland reactor buildings are posttensioned reinforced concrete
9 structures. In the design of these buildings, full advantage is being
10 taken of the experience gained in the review of similar designs with
11 the AEC for the Florida Power and Light Company's Turkey Point Plant,
12 Wisconsin-Michigan Power Company's Point Beach Plant, Duke Power
13 Company's Oconee Nuclear Station, Arkansas Power and Light Company's
14 Russellville Plant, the Sacramento Municipal Utilities District Rancho
15 Seco Plant and the Palisades Plant, as well as reactor building designs
16 by others which meet the same functional requirements. All the foregoing
17 plants which have similar posttensioned reactor buildings have received
18 construction permits. Further, the Palisades and Point Beach reactor
19 buildings have been successfully leak tested and pressure tested at
20 115 percent of their design pressure levels. The reactor building is
21 designed to contain in excess of the maximum pressure resulting from
22 the most severe postulated loss-of-coolant accident. The reactor building
23 integrity is assured by means of a 1/4-inch steel liner plate which com-
24 pletely encloses the interior of the reactor building. The liner plate
25 is provided with a leak chase system which consists of steel channels

1 welded over the liner plate seams. These channels are continuously
2 pressurized to assure that any leaks which may occur would be inward.
3 All liner plate penetrations are provided with a pressurized boundary
4 at a pressure greater than the building design pressure.

5 Table 3.3-1⁽⁶⁾ compares the principal differences of the Midland
6 reactor building with reactor buildings of other plants which received
7 construction permits. It should be pointed out that the 170-wire tendon
8 to be used for the Midland reactor building was developed for the pre-
9 stressed concrete reactor vessel for the Fort Saint Vrain plant and
10 stressing equipment has provided 1000 cycles of load applications, more
11 than sufficient to stress all tendons on this reactor building, in one
12 test series alone.

Table 3.3-1

Comparisons With Other Reactor Buildings

	<u>Consumers Power Co Midland Plant</u>	<u>Consumers Power Co Palisades Plant</u>	<u>Arkansas Power & Light Co Russellville Plant</u>
1 Diameter	116'-0"	116'-0"	116'-0"
2 Design Pressure	67 Psig	55 Psig	59 Psig
3 Wall Thickness	3'-6"	3'-6"	3'-9"
4 Dome Thickness	3'-0"	3'-0"	3'-3"
5 Level of Prestress	1.2P-1.5P(1)	1.5P	1.5P
6 Wires per Tendon	170 (Maximum)	90	186
7 Size of Wire	1/4"	1/4"	1/4"
8 Buttresses	3	6	3
	<u>Sacramento Municipal Utility District Rancho Seco</u>	<u>Florida Power & Light Co Turkey Point</u>	<u>Wisconsin Michigan Power Co Point Beach</u>
9 Diameter	130'-0"	116'-0"	105'-0"
10 Design Pressure	59 Psig	59 Psig	60 Psig
11 Wall Thickness	3'-9"	3'-9"	3'-6"
12 Dome Thickness	3'-0"	3'-3"	3'-0"
13 Level of Prestress	1.2P-1.5P(1)	1.5P	1.5P
14 Wires per Tendon	55 Strands	90	90
15 Size of Wire	1/2" (7 Wire)	1/4"	1/4"
16 Buttresses	3	6	6

References

1. The Shippingport Pressurized Water Reactor - 1958 - Addison-Wesley Publishing Co, Inc.
2. Part B License Application AEC Docket No. 50-29 "Technical Information and Final Hazards Summary Report."
3. Metropolitan Edison FSAR (Docket No. 50-289)
4. Indian Point No. 2 (Docket No. 50-247)
5. Oconee No. 1 (Docket No. 50-269)
6. FSAR, Section 5.1.

1 4.0 ENVIRONMENTAL QUALITY

2 4.1 Introduction

3 In designing the Midland Plant, applicant is making every effort
4 to consider its impact on the environment, having as a goal the preser-
5 vation and enhancement of environmental quality.

6 To help assure that this objective is met, air and water monitoring
7 programs are being established for the plant. These programs are des-
8 cribed in Section 10 of this summary.

9 4.2 Air Quality

10 Trace amounts of gaseous fission products, less than a few percent
11 of the AEC limits, will be released to the environment. The radioactive
12 waste gases will be held up in the waste gas decay tanks and filtered
13 to limit the off-site release to as low a level as practicable.

14 4.3 Water Quality

15 To reduce the heat load on the Tittabawassee River and comply
16 with Michigan water quality standards, an 880-acre cooling pond will be
17 constructed adjacent to the plant. The pond is designed to accept 100%
18 of the waste heat from the plant. It will be necessary to flush solids
19 from the pond to the river. However, this process merely returns to the
20 river solids present in the water drawn into the pond from the river which
21 have concentrated in the pond; and there will be no net addition of
22 solids to the river from the Midland Plant due to this process.

23 Due to evaporation of water from the pond, some water vapor will be
24 released to the atmosphere. Experience at similar facilities indicates

1 that fogging will occur only over the immediate vicinity of the pond.
2 There will be less release of water vapor from the pond than if
3 cooling towers were used to accept the entire waste heat load.

4 There will be a controlled release of radioactive nuclides to
5 the river from the plant's liquid radioactive waste system. This sys-
6 tem processes radioactive liquid waste through tanks, filters, de-
7 mineralizers and evaporators to reduce radioactivity to levels as low
8 as practicable within AEC limits prior to discharge. This release will
9 be less than a few percent of the AEC limits.

10 4.4 Solid Wastes

11 Radioactive solid wastes, such as demineralizer resins, spent
12 filter elements, clothing, rags, and other solid wastes will be packaged
13 in suitable containers and shipped offsite for disposal by an AEC-licensed
14 contractor. Spent fuel will similarly be shipped offsite to a fuel re-
15 processing facility.

16 4.5 Land Use and Aesthetics

17 The Midland Plant's functional design will be blended harmoniously
18 with the surroundings. The plant, which will occupy an 1190.38-acre
19 site along the south shore of the Tittabawassee River, is located directly
20 across the river from The Dow Chemical Company's industrial complex. The
21 plant structures will be located directly adjacent to the river. Dow
22 waste ponds are located nearby. The 880-acre cooling and storage pond
23 will occupy an area generally to the south of the plant structures, as
24 shown on Appendix B, Fig 4. Applicant will plant trees and shrubs along

1 the pond dike to screen it from a residential subdivision near the
2 western boundary and from a road along the south boundary. The
3 center of the pond dike will be set back from the site boundary a
4 distance of not less than 160 feet and a security fence will surround
5 the dike.

6 Because there will be no bulk fuel storage and handling facili-
7 ties or high stacks, the plant will be streamlined in appearance in
8 comparison to fossil-fired power plants, see Appendix B, Fig 1. Noise
9 from the plant during normal operation will be minimal and not detec-
10 table at the site boundary.

11 4.6 National Environmental Policy Act

12 The National Environmental Policy Act (NEPA) requires, among
13 other things, that all agencies of the Federal government include
14 in every recommendation or report on major Federal action signifi-
15 cantly affecting the quality of the human environment, a detailed
16 statement by the responsible official on the following:

- 17 "(i) the environmental impact of the proposed action,
(ii) any adverse environmental effects which cannot be
avoided should the proposal be implemented,
(iii) alternatives to the proposed action,
(iv) the relationship between local short-term uses of
man's environment and the maintenance and enhance-
ment of long-term productivity, and
(v) any irreversible and irretrievable commitments of
resources which would be involved in the proposed
action should it be implemented."

1 Prior to making such a detailed statement, the agency is required to
2 consult with and obtain comments of any Federal agency which has
3 jurisdiction by law or special expertise with respect to environmental
4 impact.

5 In compliance with the policy of the Atomic Energy Commission,
6 applicant has prepared and filed with the Commission an environmental
7 report providing information on the above five points. The Atomic
8 Energy Commission has circulated it for comments to Federal agencies
9 having jurisdiction or special expertise with respect to environmen-
10 tal impact and, by publication of notice in the Federal Register,
11 35 FR 12795, August 12, 1970, has made the report available to local
12 agencies. Comments have been received from the Federal Power Commis-
13 sion, the Department of Agriculture, the Department of Housing and
14 Urban Development, the Department of Defense and Michigan Department
15 of Natural Resources.

1 5.0 OTHER GOVERNMENTAL AGENCIES

2 Consumers Power Company intends to acquire all necessary regu-
3 latory approvals for construction and operation of the Midland Plant.
4 It has sought to fully cooperate with all governmental agencies having
5 an interest in the plant and has attempted to keep all agencies fully
6 informed. As part of this policy of cooperation, Consumers Power has
7 served copies of the application with all amendments as they were
8 filed on the Mayor of the City of Midland, on the Supervisor of
9 Midland Township, and on the Chairman of the Board of Commissioners
10 of Midland County and has served six copies on the State of Michigan
11 to be distributed to interested agencies.

12 Besides applying to the Atomic Energy Commission for a permit
13 to construct and a license to operate the Midland Plant, Consumers
14 Power on June 9, 1970 filed with the Michigan Water Resources Commis-
15 sion a Statement of New or Increased Use of Waters of the State for
16 Waste Disposal Purposes and on August 28, 1970 applied to the Michigan
17 Air Pollution Control Commission for authority to construct and operate
18 air pollution control equipment at the Midland Plant. Following a
19 public hearing held on August 10, 1970, the Water Resources Commis-
20 sion issued an Order of Determination, dated October 15, 1970, imposing
21 specific limits on the proposed use of the water of the Tittabawassee
22 River by Consumers Power. The Michigan Air Pollution Control Commission
23 is considering Consumers Power's application and is expected to act in
24 the near future.

1 Consumers Power received, following a public hearing, approval
2 for its proposed use of land in the pond area from the Midland Town-
3 ship Zoning Board of Appeals and received a building permit from
4 the Midland Township Building Inspector. Consumers Power has provided
5 information in relation to construction of the plant to the City Com-
6 mission of Midland, the Midland Township Board, the Midland County
7 Board of Commissioners, the Midland County Drain Commissioner, the
8 Midland County Road Commission, the Michigan Departments of Public
9 Health, Labor and Natural Resources, the Michigan Public Service
10 Commission, the Michigan Water Resources Commission, the Governor's
11 Study Committee on Atomic Energy, the US Coast Guard and the US Army
12 Corps of Engineers.

13 Consumers Power has received miscellaneous approvals relating to
14 the plant from several of these agencies and will work closely with
15 these and any other agencies having an interest in the plant in order
16 to secure all necessary approvals and to assure that these govern-
17 mental agencies are fully informed as to the status of the project.

18 The Midland Township Board by resolution on September 9, 1970
19 let it be known that it encouraged the installation of the Midland
20 Plant at the plant site located in Midland Township. The Midland
21 County Board of Commissioners by resolution on August 11, 1970 sup-
22 ported the location and development of the Midland Plant in Midland
23 County. On August 26, 1970, the Midland County Road Commission by
24 resolution supported the location and development of the Midland
25 Plant in Midland County.

1 6.0 SITE CHARACTERISTICS

2 6.1 Location

3 The Midland Plant is to be constructed on the south shore of
4 the Tittabawassee River adjacent to the southern limits of the City
5 of Midland, Midland County, Michigan. The site and immediate vi-
6 cinity are shown in Appendix B, Figures 3, 4 and 5⁽¹⁾.

7 All land comprising the site will be controlled by applicant⁽²⁾.
8 This includes all land bounded by the Tittabawassee River bank on the
9 north and east, on the south by Gordonville Road and on the west by
10 farmland and scattered residences.

11 6.2 Population⁽³⁾

12 The plant exclusion area has a minimum radius of 0.31 mile. The
13 exclusion distance to the south site boundary, encompassing the pond,
14 is 1.12 miles.

15 The distance to the boundary of the low population zone is 1 mile,
16 within which there is estimated to be 38 permanent residents plus
17 portions of The Dow Chemical Company industrial complex.

18 The population distribution is shown in Appendix B, Figure 6. The
19 siting and safeguards provisions of the plant are in accordance with
20 the AEC guidelines set forth in 10 CFR Part 20 ("Standards for Protec-
21 tion Against Radiation") and 10 CFR Part 100 ("Reactor Site Criteria").

22 6.3 Land Use

23 Generalized descriptions of the land use within five miles of
24 the site are given below⁽⁴⁾. Present use of land was determined by

1 examining geological survey maps and aeriels of the area. Future use
2 was based on past development, industrial trends and suitability of
3 land for various purposes

4 North - (0-1.5 miles) - Heavily industrialized. Dow's main industrial
5 complex lies in this area. Room for industrial
6 development in NNE section.

7 - (1.5-4 miles) - Contains the populated residential, commercial
8 community of Midland. Area is nearly saturated
9 with buildings. Little growth expected.

10 - (4-5 miles) - Primarily residential. This area is expected
11 to develop into a residential suburban community.

12 East - (0-1 mile) - Heavily industrial, area saturated.

13 - (1-5 miles) - Sparsely populated residential area. Many
14 forested acres, scattered farming. Expect
15 industrial growth 1-2 mile section. This is
16 another area for suburban development.

17 South - (0-1 mile) - Land contained within site.

18 - (1-3 miles) - Mostly forested lands, some farming. Poten-
19 tial area for industrial expansion.

20 - (3-5 miles) - Primarily farming, scattered nonfarming
21 residents, very few commercial establishments.

22 West - (0-1 mile) - Industrial property owned by applicant and Dow.

23 - (1-2 miles) - Mostly suburban residential, light farming.
24 Room for suburban residential development.

1 - (2-5 miles) - Primarily agricultural, sparsely populated.
2 Some forested land.

3 The area 5-50 miles from the site is primarily used for farming,
4 where not forested, except for the industrial communities of Bay City,
5 Flint, and Saginaw. A large portion of the area northeast of the
6 site is public land used for hunting and camping.

7 6.4 Meteorology

8 The site meteorology has been extensively investigated to provide
9 an assessment of environmental consequences of routine and accidental
10 releases of radioactivity. The topography at the site is comparatively
11 flat with elevations ranging from 600 to 634 feet above mean sea level.
12 It is estimated that there are no significant changes in the topography
13 greater than 50 feet within 50 miles. Thus, topographically induced or
14 altered winds should not be important at this site.

15 Temperatures of 90 degrees or higher occur on an average 14 times
16 per summer and of zero or lower on an average of 6 times during the
17 winter. Mean annual precipitation at Midland is 29.8 inches. Rainfall
18 is greatest in June, averaging 3.15 inches. Snowfall totals 33.3 inches
19 during an average winter. Cloudiness is greatest in the late fall and
20 winter. Prevailing wind direction is southwest and average hourly velo-
21 city is greatest in the early spring and lowest in late summer and early
22 fall. A study was made of the site atmospheric diffusion characteristics,
23 utilizing conservative meteorological conditions⁽⁵⁾. Extensive meteor-
24 ological data was available from the Tri-City Airport and Dow. A
25 meteorological program for the site will commence at least two years
26 before fuel loading.

1 6.5 Surface Water Hydrology

2 Surface water investigations were made in connection with the
3 safety aspects of the plant. These included the magnitude of pos-
4 sible floods and possible failure of upstream dams⁽⁶⁾.

5 The maximum recorded flood since 1907 reached a stage of 610.0
6 feet in 1916⁽⁶⁾.

7 The probable maximum flood discharge at the plant site has been
8 conservatively calculated to be about 270,000 cfs which includes the
9 effect of upstream dam failures. This discharge is calculated to re-
10 sult in a probable maximum flood level of 632 feet at the plant site
11 which level has been used as a basis for plant design.

12 The plant area will be filled to elevation 634 and thus the vital
13 installations are protected against water damage in the unlikely event
14 of a probable maximum flood.

15 6.6 Groundwater Hydrology⁽⁷⁾

16 The presence of a thick, impermeable clay member has produced two
17 hydrologic conditions at the site. They are:

- 18 1. A perched water table in the sand above the clay.
19 2. An artesian aquifer in the sand and gravel underlying the clay.

20 The perched water table is in the upper sand which generally is
21 less than 50 feet deep in the borings. The quantity of water in these
22 surface sands is limited and is not a source of domestic supply in the
23 site area. Small domestic supplies are obtained from the underlying
24 confined aquifer.

1 The thick, impermeable clay layer, which acts as the confining
2 media preventing the upward flow of the artesian water, also prevents
3 the downward percolation of surface water from the plant area.

4 Water wells located within the cooling pond area have been sealed
5 to insure that cooling pond water does not seep into the domestic supply
6 and that no artesian groundwater leaks into the cooling pond water.

7 6.7 Site Geology⁽⁸⁾

8 6.7.1 General

9 Site investigations were conducted to evaluate the geologic con-
10 ditions that are pertinent to the design, construction and operation of
11 the Midland Plant. These investigations indicate that the Midland area
12 is underlain by two types of glacial deposits. These are a loose glacial
13 lake deposit overlying a dense glacial till. The plant is founded on
14 the dense till. These deposits overlie bedrock which is the Pennsyl-
15 vanian Saginaw formation composed of nearly flat-lying shales, sand-
16 stones, and siltstones. The glacial deposits vary in thickness from
17 350 to 360 feet.

18 6.7.2 Salt Solution Cavities

19 Underlying the site are thin salt beds encountered in the
20 Devonian formation of the Detroit River sector at a depth between
21 4100 and 4300 feet. The Dow Chemical Company has mined these salt
22 beds for some time and has also extracted brine from the Devonian
23 Sylvania sandstone at a depth of 5100 feet. Overlying the area
24 mined are dense beds of limestone, dolomite, shale and sandstone.

1 The maximum surface subsidence has been investigated by two
2 separate consulting firms, Woodward-Clyde & Associates and General
3 Analytics, Inc. One firm is experienced in foundation investigations,
4 and the other is experienced in mine settlement investigations. Experts
5 with these firms reviewed the information from the Dow brine well mining
6 operations. The data include drilling records and drill corings of
7 the rock strata overlying the salt solution cavities, accurate records
8 of materials removed and records of ground surface elevations.

9 An independent calculation of surface subsidence was made by each
10 consultant. In one case, the consultant used an analytical approach
11 based on estimated cavity openings and the known elastic properties of
12 the surrounding rock strata. The other consultant used an empirical
13 method developed to predict surface subsidence of mines in England.
14 The conclusion reached by both consultants was that for the salt wells
15 in the area of the plant site, the maximum surface subsidence which
16 could be expected would be less than 1 inch⁽⁹⁾.

17 Furthermore, if subsidence were to occur, it would affect a
18 large area due to the spacing of the wells, their great depth and
19 the competency of the overlying flat-lying sedimentary rocks. Such
20 a broad regional subsidence would have no significant effect on sur-
21 face structures, which cover a small area compared to the probable
22 subsided area. The negligible predicted maximum subsidence has been
23 confirmed by the recorded surface elevations over the past 10 years.
24 The Dow Chemical Company has observed no measurable surface subsidence
25 due to the salt solution extraction. To further insure the safety of

1 the Midland Plant, Dow will not drill any new brine or salt wells
2 within one-half mile of the plant site.

3 6.8 Seismology⁽¹⁰⁾

4 The Midland site is located in a region of slight seismic ac-
5 tivity. Although earthquakes have been felt in this region of the
6 United States, Midland experienced all with low intensity. The maxi-
7 mum intensity experienced at the proposed Midland nuclear site as a
8 result of any historic earthquake is V on the Modified Mercalli scale.

9 Intensity V corresponds to a surface acceleration of 0.03 g on
10 Hersberger's (1956) curve. For design of the plant Class I structures,*
11 a conservative value of 0.06 g will be used for the operating basis
12 earthquake, and 0.12 g acceleration will be used for the design basis
13 earthquake for safe plant shutdown.

14 No faults are mapped in the surficial deposits of the southern
15 peninsula. The active Keweenaw fault exists approximately 325 miles
16 northwest of the site on the Upper Peninsula. This fault, however,
17 is not related geologically to the structural province of the Michigan
18 Basin and its activity is not important in the evaluation of the Midland
19 site. A less important fault zone about 240 miles northwest of the site
20 in the vicinity of the Menominee Range does not appear to be active.

*Class I structures, systems and equipment are those whose failure could
cause uncontrollable release of reactivity or those essential for
immediate and long-term operation following a loss-of-coolant accident.

1 6.9 Foundations

2 The reactor buildings and lower portions of the auxiliary building
3 are at elevations such that the foundations are established on the
4 stiff-to-hard cohesive soils which underlie the site. These soils
5 are considered to provide excellent foundation support without exces-
6 sive settlement under both static and dynamic conditions of loading⁽¹¹⁾.
7 These Class I structures are founded on earth-supported mat foundations.

8 The south portion of the auxiliary building has its base at el-
9 elevation 610 while the existing ground surface soils in this area vary
10 between elevation 605 and elevation 612. The surface soils in this
11 area are loose sands of variable thickness which do not provide suit-
12 able foundation support. Consequently, these soils are to be removed
13 down to the underlying very stiff-to-hard cohesive soils and will be
14 replaced with controlled compacted granular or cohesive fill. All
15 other Class I structures or components will also be founded on the
16 stiff, hard cohesive soils or on engineered compacted fill material.
17 Furthermore, in the area of the Turbine Building, all loose sands,
18 soft or compressible clay soils, and organic soils will be excavated
19 and replaced with suitable fill material.

References

1. PSAR, Sections 1.2.1 and 2.2.1
2. PSAR, Section 2.2.2
3. PSAR, Section 2.2.5
4. PSAR, Section 2.2.6
5. PSAR, Appendix 2A
6. PSAR, Appendix 2B
7. PSAR, Section 2.6
8. PSAR, Section 2.5.3
9. The Woodward-Clyde & Associates report is appended to Item 2.17 submitted by Amendment No 7; it follows Amendment No 5 in Volume II of the PSAR. The General Analytics, Inc report was submitted in Amendment No 10, PSAR Volume III.
10. PSAR, Section 2.7
11. PSAR, Section 2.8.4.3

1 7.0 DESCRIPTION OF MIDLAND PLANT

2 7.1 Introduction

3 A description of plant features and layout, as well as an eval-
4 uation of plant safety, is set forth in the application and its amend-
5 ments. The plant description emphasizes the concepts, guidelines and
6 criteria which will govern final design.

7 The station will consist of two reactor buildings, an auxiliary
8 building (including fuel storage, control room and radwaste area), a
9 turbine structure (housing two turbines), an administration building
10 (including offices, a shop and warehouse), a water storage and cooling
11 pond, a switchyard and various other auxiliary structures and equipment.
12 Arrangement of the Midland Plant is shown in Appendix B, Figure 3.
13 Section 9, together with Appendix A, presents a comparison of the
14 nuclear steam supply system design parameters of the proposed Midland
15 Plant with those of Duke Power Company's Oconee Unit 1; Commonwealth
16 Edison Company's Zion Plant and the Sacramento Municipal Utility
17 Company's Rancho Seco Unit 1 Plant.

18 The following subsections are a summary of the principal features
19 of the plant which are significant with respect to safety considerations.

20 7.2 Reactor and Reactor Coolant System

21 The reactors for the Midland Plant are of the pressurized water
22 type. They have an initial core rating of 2452 MW_t each and together
23 will produce approximately 21×10^6 lb/kW steam for production of elec-
24 tricity and process steam⁽¹⁾. The nominal operating pressure for the

1 reactor is 2185 psig, with an average core outlet temperature of 604°F⁽²⁾.
2 The reactor coolant system is designed for a pressure of 2500 psig at a
3 nominal temperature of 630°F⁽³⁾. The nuclear steam systems are essentially
4 identical to eight other B&W units which have previously received construc-
5 tion permits.

6 The reactor core is approximately 129 inches in diameter, with
7 an active height of 144 inches⁽⁴⁾. It is made up of 177 fuel assem-
8 blies, each consisting of a 15 x 15 array of fuel rods held in place
9 by mechanical spacer grids. The array of fuel rods consists of 208
10 zircaloy tubes containing uranium dioxide, 16 control rod guide tubes,
11 and a center tube available for an in-core instrumentation assembly⁽⁵⁾.
12 There are approximately 207,500 pounds of uranium dioxide in the
13 core⁽⁶⁾.

14 The thermal and hydraulic design limits of the core are conser-
15 vative, and are consistent with those of other pressurized water re-
16 actors currently in operation or under construction^(6,7).

17 Core reactivity is controlled by a combination of 49 movable
18 control rod assemblies, a neutron absorber dissolved in the coolant,
19 and burnable absorber rod assemblies⁽⁸⁾. The control rods are an
20 alloy of silver-indium-cadmium encapsulated in stainless steel. The
21 dissolved neutron absorber is boric acid. The burnable absorber rods
22 are sintered $\text{Al}_2\text{O}_3\text{-B}_4\text{C}$ encapsulated in stainless steel⁽⁹⁾.

23 Eight part length axial power shaping rod assemblies are pro-
24 vided to thwart any tendency toward axial power shifts resulting from
25 a redistribution of xenon^(8,10).

1 The control rods are used for short-term reactivity con-
2 trol associated with the changes in power level and also with
3 changes in fuel and burnable absorber burnup between periodic ad-
4 justments of dissolved boron concentration⁽¹¹⁾. The reactor can be
5 shut down by the movable control rods from any power level
6 at any time. Each movable control rod assembly and axial power
7 shaping rod assembly contains 16 control rods, and is actuated
8 by a separate control rod drive mechanism mounted on the top
9 head of the reactor vessel. Upon trip, all control rod assem-
10 blies fall into the core by gravity causing immediate reactor
11 shutdown.

12 The control rod drive and axial power shaping rod drive
13 mechanisms are sealed drives of the roller nut type in which a
14 lead screw coupled to the control rod assemblies is axially driven
15 by the rotary motion of a pair of roller nut segment arms.
16 The segment arms which are within the pressure housing are part of
17 the drive motor and are electrically driven by the motor stator
18 which is external to the pressure housing. The segment arms are
19 held in engagement with the lead screw whenever the drives
20 are electrically energized. The reactor trip signal or loss of
21 power to the control rod drives causes the roller nut segment
22 arms to disengage from the lead screw causing the rod assemblies
23 to fall into the core. The axial power shaping rod drive

1 mechanism is modified so that the roller nut assembly will not dis-
2 engage from the lead screw on reactor trip or loss of electrical
3 power⁽¹²⁾.

4 Seventy-two of the fuel assemblies will be utilized as locations
5 for burnable absorber rod assemblies⁽¹³⁾. Each assembly has 16 burnable
6 absorber rods, a stainless steel spider, and a coupling mechanism for
7 positive coupling with the fuel assembly hold-down latch⁽¹⁴⁾.

8 The concentration of dissolved neutron absorber in the
9 reactor coolant may be adjusted to control relatively slow
10 moving reactivity changes and to provide a safe shutdown margin
11 where a cooldown to reactor building ambient temperature is
12 required⁽¹⁵⁾.

13 The core is contained within a cylindrical reactor vessel having
14 internal dimensions of 14 feet 3 inches in diameter and 37 feet 4
15 inches in height. The vessel has a spherically dished bottom head
16 with a bolted removable spherically dished top head⁽¹⁶⁾. The re-
17 actor vessel is constructed of carbon steel with all interior surfaces
18 clad with austenitic stainless steel. The reactor vessel is manu-
19 factured under close quality control, and several types of nondestruc-
20 tive tests are performed during fabrication. These tests include
21 radiography of welds, ultrasonic testing, magnetic particle examin-
22 ation, and dye penetrant testing⁽¹⁷⁾. Specimens of reactor vessel
23 materials will be placed in the reactor adjacent to the inside surface
24 of the reactor vessel. During operation, these specimens will be

1 subject to irradiation similar to the shell of the reactor vessel. A
2 portion of the specimens will be removed periodically and tested to
3 ascertain the effects of radiation on the reactor vessel material⁽¹⁸⁾.

4 The two coolant loops are connected to the reactor vessel by
5 nozzles located near the top of the vessel. Each loop contains one
6 steam generator, two motor-driven coolant pumps, and the intercon-
7 necting piping. The reactor coolant piping is carbon steel clad on the
8 inside surface with austenitic stainless steel⁽¹⁹⁾. Reactor coolant
9 is pumped from the reactor through each steam generator and back to
10 the reactor inlet by two 88,000 gpm centrifugal pumps located near
11 the outlet of each steam generator⁽²⁰⁾. The reactor coolant pumps are
12 vertical, single-stage, shaft-sealed units having bottom suction and
13 horizontal discharge. Each pump has a separate, single-speed, top-
14 mounted motor, which is connected to the pump by a shaft coupling.

15 The steam generator is a vertical, straight-tube-and-shell heat
16 exchanger which produces superheated steam at constant pressure over
17 the power range. Reactor coolant flows downward through the tubes
18 and steam is generated on the shell side⁽²¹⁾.

19 The pressurizer, a vertical surge tank approximately half-filled
20 with reactor coolant and half-filled with steam, is connected to the
21 reactor coolant system. The operating pressure of the system is main-
22 tained by operating electric immersion heaters to increase pressure or
23 by spraying reactor coolant water into the steam within this pres-
24 surizer tank to reduce pressure. Self-actuated safety relief valves

1 connected to the pressurizer prevent overpressurization of the reactor
2 coolant system⁽²²⁾.

3 The reactor vessel, steam generator, and pressurizer will be de-
4 signed, manufactured and tested in accordance with Section III of the
5 ASME Code. The reactor coolant piping will conform to USASI B31.7 and
6 the reactor coolant pump casings will be manufactured in accordance
7 with Section III of the ASME Code, where applicable⁽²³⁾.

8 7.3 Reactor Building

9 The reactor building is designed to completely enclose the re-
10 actor coolant system and portions of the auxiliary and engineered
11 safeguards systems. It is a reinforced concrete structure with a
12 post-tensioned system in the shape of a cylinder with an elipsoidal-
13 domed roof and a flat foundation slab. The cylindrical wall and dome
14 are prestressed by a post-tensioning system, consisting of steel ten-
15 dons. The building will have three vertical and horizontal top and
16 bottom buttresses to which tendons will be anchored. The foundation
17 slab is conventionally reinforced with high-strength reinforcing
18 steel. The inner surfaces of the entire structure are lined with
19 welded steel plate, 1/4-inch minimum thickness, which functions as
20 a leak-tight membrane. The foundation mat will be bearing on the
21 hard, stiff blue clay and will be approximately nine feet thick.

22 The building is designed to sustain safely all internal and ex-
23 ternal loading conditions which may be expected to occur during the
24 life of the station or which could result from postulated accidents
25 to the reactor's primary coolant system⁽²⁴⁾. The tendon system used

1 in the structure is of the unbonded type with a protective compound
2 used to prevent corrosion.

3 The reactor building is so designed that, with the engineered
4 safeguards systems provided, any leakage of radioactive materials to
5 the environment will be well within the AEC's guidelines (10 CFR 100)
6 for any of the postulated accidents. The integrated leak rate at
7 design pressure will not exceed one-tenth of one percent by volume,
8 within 24 hours. Furthermore, the reactor building will be designed
9 to resist flotation due to the maximum probable flood.

10 Prior to operation, the reactor building will be subjected to
11 a structural integrity test and leak rate test. The structural in-
12 tegrity test will be conducted at 115 percent of design pressure.
13 Periodic leak rate tests will be performed to assure integrity of
14 the reactor building. A tendon surveillance program will provide
15 assurance that the tendons are free from harmful corrosion and that
16 excessive steel relaxation has not taken place⁽²⁵⁾.

17 Reactor building materials and workmanship will be inspected to
18 ensure compliance with appropriate codes, specifications, and standards.
19 Materials to be inspected and tested include concrete, liner plate,
20 prestressing system materials, hatches, penetrations, structural and
21 reinforcing steel⁽²⁶⁾.

22 Provisions have been included for in-service pressure testing of
23 personnel hatches and other penetrations⁽²⁷⁾.

1 7.4 Engineered Safety Features

2 Engineered safety features for each nuclear unit are provided
3 to prevent or mitigate the effects of accidents which result in
4 release of radioactivity.

5 The engineered safety features fulfill the following functions
6 in the unlikely event of a serious loss-of-coolant accident:

- 7 a. Protect the fuel cladding.
- 8 b. Maintain reactor building integrity.
- 9 c. Reduce the driving forces for reactor building leakage.
- 10 d. Remove fission products from the reactor building atmosphere.

11 The engineered safety features can be grouped into emergency
12 core cooling systems, reactor building cooling systems, and fission
13 product control systems⁽²⁸⁾.

14 The emergency core cooling systems contain both passive flooding
15 systems and pumping systems. The passive flooding system consists
16 of two pressurized core flooding tanks which automatically discharge
17 borated water into the reactor vessel in the event that the reactor
18 system pressure drops below 600 psi. The pumping system consists
19 of two completely independent subsystems. Each subsystem contains
20 both a high-pressure and a low-pressure injection pump. Either sub-
21 system, in conjunction with the core flooding tanks, is capable of
22 protecting core integrity for any size leak up to and including a
23 double-ended rupture of the largest reactor coolant pipe. Either
24 subsystem can supply coolant directly from the borated water storage
25 tank or by recirculation from the reactor building sump through heat
26 exchangers which cool it before it is returned to cool the core⁽²⁹⁾.

1 The reactor building cooling system, which is made up of two
2 separate and independent heat removal systems, limits the pressure
3 in the reactor building following a loss-of-coolant accident. One
4 system contains four separate air cooling units. The other system
5 contains redundant spray headers which spray low temperature borated
6 water into the reactor building to cool it. The spray water also
7 contains chemical additives as described below. Each of these sys-
8 tems without the other has the heat removal capability to maintain
9 the reactor building pressure below its design pressure level⁽³⁰⁾.

10 The primary control of released fission products following a
11 postulated loss-of-coolant accident is provided by the reactor build-
12 ing. A second means for controlling released fission products is the
13 iodine removal spray system which consists of redundant subsystems
14 which utilize chemicals mixed in the reactor building spray water
15 to absorb the iodine released from the reactor coolant system and
16 render it unavailable for leakage from the reactor building. For the
17 postulated maximum hypothetical accident the reactor building and
18 either one of the two redundant reactor building spray systems will
19 limit radiation exposures at the exclusion boundary and low population
20 zone boundary to values within AEC safety guidelines (10 CFR 100)⁽³¹⁾.

21 7.5 Instrumentation and Control

22 Redundant networks of instrumentation and controls will be pro-
23 vided to ensure the safe operation of the Midland Plant. The reactor
24 protection system and the engineered safeguards actuation system are
25 designed to meet the requirements of the proposed "Standard for Nuclear
26 Power Plant Protection Systems," IEEE-279, Rev 10. The engineered

1 safety features actuation system monitors plant conditions and
2 automatically initiates operation of the engineered safety features
3 systems, if required⁽³²⁾. This system initiates emergency core
4 cooling systems on signal of high reactor building pressure or low
5 reactor coolant system pressure. The reactor protection system
6 monitors parameters related to safe operation and shuts down the
7 reactor if an operating limit is reached⁽³³⁾. The operating limits
8 are well below the safety limits. Shutdown will be accomplished by
9 interrupting power to the control rod drive mechanisms and allowing
10 the control rods to drop into the reactor core. Alarms⁽³⁴⁾ are pro-
11 vided to alert the operator to abnormal operating conditions, and
12 interlocks⁽³⁵⁾ are provided to prevent operations which could lead
13 to potentially hazardous conditions.

14 The nuclear instrumentation system monitors reactor power
15 from start-up level through 125 percent of full power operation.
16 There are separate overlapping instrumentation channels for the
17 source range, the intermediate range, and the power range⁽³⁶⁾.

18 Following proven power station design philosophy, all control
19 stations, switches, controllers, and indicators necessary to start
20 up, operate, and shut down the nuclear unit will be placed in the
21 centrally located control room. There will be sufficient information
22 display and alarm monitoring to ensure safe and reliable operation

1 under normal and accident conditions. Special emphasis will be given
2 to maintaining control room integrity during accident conditions⁽³⁷⁾.

3 For the unlikely contingency that occupancy of the control room
4 may be temporarily denied, the capability will be available for taking
5 the plant to, and maintaining the plant in a safe shutdown condition
6 from other locations in the plant⁽³⁸⁾.

7 The instrumentation signals sent to control and safety circuits
8 from common transmitters are made fully independent by the use of iso-
9 lation amplifiers. The effectiveness of these isolation amplifiers
10 has been demonstrated by analysis and by actual test of prototype
11 equipment.

12 A radiation monitoring system monitors radiation levels in selected
13 plant areas and in plant effluent released to the environment, provides
14 an early warning of possible equipment malfunction or potential radiolog-
15 ical hazard. The radiation monitoring system includes continuous auto-
16 matic monitoring and is supplemented by periodic sampling⁽³⁹⁾.

17 7.6 Electrical Systems⁽⁴⁰⁾

18 The Midland Plant will generate electric power at 22 kV and 24 kV,
19 respectively. This power will be fed through separate isolated phase
20 buses to the unit main transformers where it will be stepped up to 345 kV
21 transmission voltage and delivered to the switchyard on separate over-
22 head lines. The units and associated switchyard are part of the
23 Consumers Power Company integrated electric system, which is described
24 in Section 2.1 of this summary.

25 The design of the electrical systems for the Midland Plant units
26 is based on providing the required electrical equipment and power

1 sources to ensure safe, reliable operation and safe, orderly shutdown
2 of the unit under any normal or emergency conditions. The following
3 sources of power are available to provide redundancy and to assure a
4 supply of electrical energy to the station safety systems under all
5 credible circumstances:

- 6 1. The five 345 kV transmission lines which terminate at the
7 Midland Plant switchyard provide start-up and standby power
8 through the 345-138 kV step-down substation, 138 kV Start-Up
9 Line and Start-Up Transformer No 1.
- 10 2. Start-Up Transformer No 2 provides an alternate off-site
11 power source via a separate 138 kV line from a Consumers
12 Power Company substation serving Dow.
- 13 3. Each unit will continue to supply power to its own auxil-
14 iary systems in the unlikely event of a trip separation
15 from the transmission system.
- 16 4. Upon loss of all sources of power described in 1, 2 and
17 3 above, power will be supplied from the two automatic,
18 fast start-up diesel engine generators. These are sized
19 so that either can carry the engineered safeguards load for
20 one plant plus the safe shutdown load for the other unit.
- 21 5. The station battery is sized to provide a safe and orderly
22 shutdown of each unit in the event that all a-c power is
23 lost.

24 These normal, standby and emergency sources of auxiliary elec-
25 trical power supply redundant plant auxiliary, engineered safeguards

1 and reactor protection systems through separate and independent
2 distribution systems.

3 7.7 Auxiliary Systems

4 Auxiliary systems are provided to supply reactor coolant make-
5 up and pump seal water, to cool the reactor during shutdown, to cool
6 components, to ventilate station spaces, to handle fuel, to cool spent
7 fuel, and to adjust the concentration of various chemicals in the re-
8 actor coolant⁽⁴¹⁾.

9 Reactor coolant makeup and seal water is supplied by the makeup
10 and purification system. This system, which also serves the engineered
11 safeguards function of providing high-pressure emergency core coolant,
12 maintains the proper coolant inventory in the primary system, maintains
13 the seal water flow, adjusts the concentration of dissolved neutron
14 absorber in the reactor coolant and maintains proper water chemistry⁽⁴²⁾.

15 The decay heat removal system cools the reactor when the reactor
16 system is depressurized for maintenance or refueling. This same sys-
17 tem serves the engineered safeguards functions of providing low-pressure
18 emergency core coolant and of recirculating borated water to cool the
19 core in the unlikely event of a loss-of-coolant accident⁽⁴³⁾.

20 The chemical addition system adds boric acid to the reactor coolant
21 system for reactivity control, potassium hydroxide for pH control, and
22 hydrogen and hydrazine for oxygen control⁽⁴⁴⁾.

23 The cooling water systems maintain temperatures throughout the
24 equipment and structures of the station⁽⁴⁵⁾. Appropriate normal and
25 emergency ventilation systems are provided in the plant⁽⁴⁶⁾.

1 A fuel handling system⁽⁴⁷⁾ provides the means for safe, reliable
2 handling of fuel until it is shipped from the station as used fuel.
3 Irradiated fuel is handled under water at all times until after it is
4 placed into a shipping cask. The water provides a radiation shield
5 as well as a reliable source of cooling for the irradiated fuel assem-
6 blies. A fuel pool cooling system maintains the temperature and purity
7 of the spent fuel storage pool water within acceptable limits⁽⁴⁸⁾.

8 7.8 Steam and Power Conversion System⁽⁴⁹⁾

9 The steam and power conversion system is designed to accept
10 steam from the nuclear steam system. One portion of this heat
11 energy is converted to electrical energy by the turbine generators.
12 A second portion of the heat energy is used in the process steam
13 reboilers to generate process steam for Dow. The circulating
14 water system, utilizing cooling pond water, will dissipate the
15 balance of the heat energy which is rejected by the turbine
16 condensers.

17 7.9 Process Steam System

18 Steam from the steam and power conversion systems is used in
19 indirect tertiary heat exchangers (reboilers) to generate process
20 (tertiary) steam for Dow. The function of the reboilers is to pro-
21 vide complete physical separation between the turbine plant cycle and
22 the process steam delivered to Dow⁽⁵⁰⁾.

23 7.10 Cooling Pond

24 Turbine condenser cooling water is stored in a cooling pond. The
25 pond is sized to allow for all water losses from the pond, without make-
26 up from the Tittabawassee River, during the three-month period when the

1 river flow is low⁽⁵¹⁾. The emergency service water pond is a depressed
2 area in the cooling pond, which will provide water storage for re-
3 actor decay heat removal in the unlikely event of a dike failure⁽⁵²⁾.

4 7.11 Radioactive Waste System

5 Radioactive gaseous, liquid and solid wastes in the station are
6 handled by the waste disposal systems. These systems contain the
7 equipment necessary to safely collect, process and prepare for dis-
8 posal or reuse of the radioactive wastes which result from reactor
9 operation. These systems are designed to minimize the release of
10 radioactive material from the plant to the environment and will main-
11 tain releases well below the limits of 10 CFR 20⁽⁵³⁾.

12 The gaseous and liquid radwaste releases from the plant are an-
13 ticipated to be as low or lower than other plants in operation or
14 under construction, except that the liquid radwaste release will not
15 be as low as that of the Rancho Seco Plant which is not situated near
16 a waterway and cannot discharge liquid wastes. The maximum expected
17 radwaste release rates from the plant are as follows:

18	Gaseous	88,600 Curies/Year (30-Day Holdup)
19	Tritium	6,300 Curies/Year
20	Other Liquid Wastes	0.1 Curies/Year

21 The above release rates are based upon 1 percent failed fuel, up to
22 1 gpm leakage into the turbine cycle and 30 percent tritium release from
23 the fuel⁽⁵⁴⁾. The quantities for failed fuel and steam generator
24 leakage are based upon current operating experience representing max-
25 imum levels that might be expected. The quantity level shown for tritium

1 release is a conservatively high assumed value pending further op-
2 erating experience with the current generation of chemical shim,
3 zircaloy fuel-clad PWR. Some estimates have been as low as 1 percent
4 with a corresponding decrease in the tritium waste discharge rate.

5 7.12 Shielding

6 Shielding throughout the plant, primarily in the form of heavy
7 concrete walls, insures that radiation exposures to the general public
8 and to operating personnel are within the limits prescribed by the
9 AEC (10 CFR 20)⁽⁵⁵⁾.

References

1. PSAR, Table 4-5
2. PSAR, Table 3-1
3. PSAR, Section 4.3.1
4. PSAR, Table 3-2
5. PSAR, Table 3-1
6. PSAR, Table 1-2
7. PSAR, Section 3.2.3
8. PSAR, Section 3.2.2; Table 3-2
9. PSAR, Section 3.2.4.3.7; Table 3-22
10. PSAR, Section 3.2.4.3.6; Figure 3-59
11. PSAR, Sections 3.2.2.1.2, 3.2.4.3.5; Figure 3-58
12. PSAR, Section 3.2.4.3.2
13. PSAR, Table 3-22; Figure 3-4
14. PSAR, Section 3.2.4.3.7
15. PSAR, Sections 3.2.2.1.2, 3.2.2.1.3
16. PSAR, Section 4.2.2.1 and Table 4-3

17. PSAR, Sections 4.5.1 and 4.5.2
18. PSAR, Section 4.4.3
19. PSAR, Table 4-12
20. PSAR, Section 4.2.2.4 and Table 4-7
21. PSAR, Section 4.2.2.3 and Table 4-5
22. PSAR, Section 4.2.2.2 and Table 4-4
23. PSAR, Section 4.5
24. PSAR, Section 5.1.1.2
25. PSAR, Section 5.1.4.3
26. PSAR, Sections 5.1.3 and 5.1.4
27. PSAR, Section 5.1.5.3
28. PSAR, Section 6
29. PSAR, Section 6.1.2
30. PSAR, Sections 6.2 and 6.3
31. PSAR, Section 14.2.2.4
32. PSAR, Section 7.1
33. Ibid
34. PSAR, Section 7.6.3
35. PSAR, Section 7.2.3.2
36. PSAR, Section 7.3.1
37. PSAR, Section 7.6.5
38. PSAR, Items 7.16 and 7.19 (Following Amendment No 5, Volume II)
39. PSAR, Section 7.5
40. PSAR, Section 8
41. PSAR, Section 9

42. PSAR, Section 9.1
43. PSAR, Section 9.3
44. PSAR, Section 9.2
45. PSAR, Sections 9.5, 9.6, 9.7 and 9.8
46. PSAR, Section 9.12
47. PSAR, Section 9.9
48. PSAR, Section 9.4
49. PSAR, Section 10
50. PSAR, Item 11.00 (Following Amendment No 9, Volume III)
51. PSAR, Section 10.2.5
52. PSAR, Section 9.7.2
53. PSAR, Section 11
54. PSAR, Item 11.1 (Following Amendment No 5, Volume II)
55. PSAR, Section 5.4.2

1 8.0 SAFETY ANALYSIS

2 Potential malfunctions or equipment failures have been analyzed
3 to provide a safety evaluation of the Midland Plant. The results of
4 these analyses show that the effects of the radioactivity released to
5 the environment, even in the very unlikely event that such an accident
6 should occur, are well within the guidelines established by the AEC
7 (10 CFR Part 100)⁽¹⁾.

8 Two categories of malfunctions or equipment failures have been
9 analyzed - those in which the fuel rods and reactor coolant system
10 pressure boundary are protected and those in which one of these bar-
11 riers to the release of fission products is not effective and engi-
12 neered safeguards are required. The core and coolant boundary pro-
13 tection analysis analyzes those abnormalities that are either inherently
14 terminated or require operation of the normal protection systems in order
15 to maintain the integrity of the fuel rods and/or the reactor coolant
16 system⁽²⁾. The standby safeguards analysis analyzes those accidents
17 in which one or more of the nominal protection systems are not effective
18 and therefore requires the operation of standby safety features⁽³⁾.
19 The results of these analyses show that the effects of radioactivity
20 releases to the environment for all credible malfunctions are well with-
21 in the AEC safety guidelines (10 CFR 100).

22 Of the numerous malfunctions evaluated, a loss-of-coolant accident
23 would be the most severe. Emergency core cooling systems are provided
24 to prevent clad melting for entire spectrum of reactor coolant system
25 failures ranging from the smallest leak to the complete severance of

1 the largest reactor coolant pipe. The core cooling systems insure
2 that core integrity will be maintained⁽⁴⁾. Either the reactor building
3 sprays or the air recirculation and cooling system will maintain the
4 integrity of the reactor building, assuring that the public will be
5 protected against potential radiation hazards from the postulated
6 accident⁽⁵⁾. Emergency electrical power is available on-site to
7 insure operation of these systems even if all external sources of elec-
8 tric power to the plant are assumed to be unavailable at the time of
9 the accident⁽⁶⁾.

10 Results of the safety analyses show that, even in the event of a
11 loss-of-coolant accident, no core melting will occur⁽⁵⁾. However, in
12 order to demonstrate that the operation of a nuclear power station at
13 the proposed site does not present a hazard to the general public, a
14 "maximum hypothetical accident" has been analyzed assuming a release
15 from the fuel of 100 percent of the noble gases, 50 percent of the halo-
16 gens and 1 percent of the solids in the fission product inventory. Fifty
17 percent of the halogens then further plate out. To have such a gross
18 release of fission products, one must postulate a multitude of failures
19 in the engineered safeguards systems⁽⁷⁾, therefore, the accident is
20 not regarded as credible. Even given these assumptions, however, the
21 low leakage rate of the reactor building and the iodine removal spray
22 system limit the potential radiation dose to the thyroid and the whole
23 body to well below the AEC safety guideline values (10 CFR 100)⁽⁸⁾.

References

1. PSAR, Section 14
2. PSAR, Section 14.1
3. PSAR, Section 14.2
4. PSAR, Section 6.1
5. PSAR, Section 14.2.2.3.2
6. PSAR, Section 8.2.3
7. PSAR, Section 14.2.2.4
8. PSAR, Table 14-1

1 9.0 COMPARISON WITH OTHER PWR

2 Appendix A is a comparative list of important design and operating
3 parameters of the Midland Plant and of several other nuclear units which
4 are scheduled to precede the Midland Plant into operation. The other
5 units are Oconee Unit 1, Rancho Seco Unit 1, and Zion Units 1 and 2.
6 The Midland, Oconee, and Rancho Seco units are being supplied by B&W;
7 the Zion units are being supplied by Westinghouse.

8 The initial core rated power, nominal operating pressure, operating
9 temperature, total coolant flow rate, average thermal output at rated
10 power, average heat flux at rated power, minimum departure from nucleate
11 boiling ratio (DNBR), and number of fuel assemblies are identical for
12 the B&W units. The lesser number of control rod assemblies in the Midland
13 units compared to the other B&W units is the result of a reduction in
14 requirements for inserted control rod assemblies for equilibrium and trans-
15 ient xenon control. The differences in fuel burnups among the B&W plants
16 is primarily the result of differences in plant operating requirements
17 specified by the utilities involved.

18 A comparison of the number of coolant loops, coolant pumps, steam
19 generators, and engineered safeguards features is also included. The
20 loop arrangements and emergency core cooling systems capabilities for the
21 B&W units are identical. Though the loop arrangements for the B&W and
22 the Zion units are basically different, the emergency core cooling systems
23 for all the units are generally similar.

24 The design of the Midland units compares favorably with the design
25 of the other units presented. Similarities with other reactor building
26 designs are compared in Section 3 of this summary. In addition, certain
27 safety features of the Midland units are similar to those of the Zion and

1 Indian Point units. These include chemical reagent sprays and pro-
2 vision for charcoal filters, failed fuel detection, provisions to
3 flood the reactor vessel cavity after a loss-of-coolant accident,
4 penetration pressurization equipment, equipment to handle radiolysis
5 of water after accidents and means to withstand mechanical forces and
6 pressure transients in the vessel cavity.

7 The design of each of the units is based on information developed
8 from operation of commercial and prototype pressurized water reactors
9 over a number of years. The Midland Plant designs are based on this
10 existing power reactor technology and have not been extended beyond the
11 boundaries of known information or operating experience.

12 Prior to the time Midland Unit 1 is scheduled to go into commercial
13 operation, more than ten operating years' experience is to be available
14 from the eight B&W units of essentially identical design which are
15 scheduled to precede it into operation.

16 In addition, the safety of the Midland units for operation at their
17 design power level is further attested to by the fact that the ACRS in its
18 letter to Chairman Seaborg of September 23, 1970, stated that the com-
19 mittee had completed its operating license review of Oconee Unit 1 and
20 concluded that there is reasonable assurance that Oconee Unit 1 can be
21 operated at power levels up to 2568 MW_t. The design of the Midland
22 reactors is essentially identical to the Oconee 1 reactor design.

1 10.0 ENVIRONMENTAL MONITORING PROGRAM

2 10.1 General Radiological Surveillance

3 A preoperational environmental radiation survey⁽¹⁾ will be con-
4 ducted to determine the existing levels of radioisotopes in the environ-
5 ment surrounding the plant, to note the use of the environment in the
6 area and to sample those substances that are either directly consumed
7 by man or involved in the ecological food chain of man.

8 Both the preoperational and the operational monitoring programs
9 will sample air, water, aquatic life, including fish, and river sediment.
10 External gamma exposure to man will be estimated by placing both film
11 and thermoluminescent dosimeters in the environment. Discharges will
12 be sampled and monitored before leaving the plant.

13 Gross beta analyses will be routinely performed on all samples.
14 When gross beta counts exceed predetermined levels for each type of
15 sample, however, additional specific isotope analyses will be performed.
16 All river water samples will be analyzed for tritium and all air samples
17 will be analyzed for I-131. Air samples will be collected on a weekly
18 basis, and other materials will normally be collected monthly.

19 A reference area method of general radiological surveillance
20 will be employed. This type of surveillance program utilizes a statis-
21 tical comparison between sample analysis results of two sets of sta-
22 tions. One set of eight stations, commonly called the inner ring,
23 will be located within about two miles from the plant, while another
24 set of three stations, called background stations, will be located
25 approximately 20 miles from the plant. Statistical differences between

1 the survey results at the inner and outer rings will permit a deter-
2 mination as to whether any increase in radioactivity is of plant origin,
3 and will permit an estimate to be made of any dose to man or buildup
4 in radioactivity in the food chain. The survey will be sufficiently
5 flexible to adjust to new environmental conditions and to take into
6 account knowledge gained from the sample collection and analyses.
7 Tentatively 5 additional air sampling stations and 12 additional
8 thermoluminescent dosimeter stations are planned to be added at the
9 time the plant goes into operation.

10 10.2 Aquatic Ecological Surveillance

11 An ecological survey is planned to detect possible effects of
12 the cooling pond discharge or other plant wastewaters on the Titta-
13 bawassee River. Preoperational surveys will be conducted to provide
14 baseline data for comparison with conditions after the plant is in
15 operation.

16 Fish and bottom organisms populations will be sampled at each
17 site as indices of ecological conditions, since they show not only
18 direct response to environmental change but also reflect variations
19 in productivity and other biotic parameters.

20 Sampling for the effects on the ecology of the Tittabawassee
21 River will be done twice a year; in spring and in late summer or fall.
22 These dates will probably be made to coincide with two of the dates
23 set for radiological sampling. The spring sampling period will
24 indicate the degree of change from the previous years and will sample
25 the fauna at a time when maximum seasonal benthic diversity is expected.

1 The late summer or fall sampling will be done immediately after the
2 most critical periods of low water and highest temperature and before
3 sufficient time has passed for recovery from previous summer weather
4 to mask the effects of these most adverse natural conditions.

5 To facilitate the ecological studies, ecological surveillance
6 sites are, with the exception of one additional station upstream of
7 the pond discharge, at sites which are designated for aquatic radio-
8 logical surveillance. Four stations are upstream of the pond dis-
9 charge and four stations are on the Tittabawassee River below the
10 point of discharge.

11 It is anticipated that at least two years of preoperational
12 data will be collected, and that the studies will be continued after
13 the plant is in operation. The operational surveys will essentially
14 be a continuation of the preoperational surveys in order to easily
15 compare data.

16 10.3 Aquatic Radiological Surveillance

17 A special aquatic radiological survey is planned to determine
18 (1) the background levels of radiation in the aquatic invertebrates
19 and fish in the Tittabawassee River and in Saginaw Bay before the
20 Midland Plant is in operation, (2) the sources, if any, of radionu-
21 clides discharged into the Tittabawassee River and Saginaw Bay before
22 the plant is in operation, (3) the amounts and types of radionuclides
23 in the Tittabawassee River and Saginaw Bay waters after the plant
24 is in operation, and (4) the concentration factors and types of
25 radionuclides found in aquatic invertebrates and fish in the Titta-
26 bawassee River and Saginaw Bay after the plant is in operation.

1 The radiological surveillance program will include analyses of
2 samples of water, bottom sediment, bottom organisms and fish at each
3 site. Except for the Saginaw Bay stations, samples will be collected
4 four times a year, approximately on a quarterly basis. In Saginaw Bay,
5 samples will be taken biannually (spring and fall) and will include, in
6 addition to the other parameters, samples of the various species of
7 resident waterfowl.

8 Three sampling stations are on tributaries above the Midland Plant,
9 to provide data on upstream conditions for the reference analysis; five
10 stations are on the Tittabawassee River below the plant; two stations are
11 on other tributaries to the Saginaw River, which would not be affected
12 by plant discharges, but are necessary to inventory radioactivity charac-
13 teristics further downstream; one station is on the mouth of the Saginaw
14 River, and approximately 15 stations are in Saginaw Bay. Samples will
15 also be collected within the plant cooling and storage pond.

16 If the preoperational survey reveals any significant pattern in
17 the radiological parameters, changes in the program, such as the elimina-
18 tion of particular samples or the inclusion of additional samples, may
19 be considered.

Reference

1. PSAR, Amendment No 5, Item 2.1

1 11.0 TECHNICAL QUALIFICATIONS

2 11.1 Consumers Power Company

3 Applicant has over 48 years of experience in the operation of
4 conventional electric generating plants. Applicant's General Office
5 staff includes a number of persons associated with the Midland Plant
6 project who have previous experience in the nuclear field, including
7 experience in the design, construction and operation of applicant's
8 75 megawatt boiling water nuclear plant at Big Rock Point near
9 Charlevoix, Michigan and the design and construction of applicant's
10 2,450 megawatt thermal Palisades Plant near Covert, Michigan.

11 The operating staff will consist of approximately 78 full-time
12 employees⁽¹⁾. The majority will come from existing generating
13 plants on the Consumers Power Company system.

14 The major training⁽²⁾ for supervisory personnel will take place
15 at the Big Rock Point and Palisades Plants. Consumers Power Company
16 personnel will participate in the design phases of the Midland Plant
17 and may also receive simulator training at a B&W training facility.

18 11.2 Bechtel

19 Bechtel Corporation and its affiliate, Bechtel Company, have
20 been retained by Consumers Power Company as Architect/Engineer and
21 Constructor for the Midland project.

22 Working under the overall direction of Consumers Power Company
23 and in close coordination with B&W, Bechtel will design or furnish,
24 or both, all portions of the plant except the turbine generators and
25 the equipment and fuel supplied by B&W. Bechtel will also construct
26 the entire plant.

1 Bechtel has been continuously engaged in construction or engi-
2 neering activities since 1898. For more than 20 years, Bechtel has
3 been active in the fields of petroleum, power generation and distri-
4 bution, harbor development, mining and metallurgy, and chemical and
5 industrial processing.

6 Since the close of World War II, Bechtel has been responsible
7 for the design of over 166 power generating units, representing
8 more than 43 million kilowatts of thermal generating capacity, which
9 includes units of the largest and most modern types. Of this number,
10 more than 15 million kilowatts are produced by nuclear-fueled units.

11 For over 20 years, Bechtel has been engaged in the study, de-
12 sign and construction of nuclear installations. Its experience in-
13 cludes design or construction, or both, of such facilities as accel-
14 erators, nuclear research laboratories, hot cells, experimental
15 reactors and nuclear fuel processing plants, as well as nuclear power
16 plants. A summary of experience is listed in the application⁽³⁾.

17 11.3 The Babcock & Wilcox Company (B&W)⁽⁴⁾

18 B&W's participation in the development of nuclear power dates
19 from the Manhattan project. B&W's nuclear activities include applied
20 research to develop fundamental data, design and manufacture of nu-
21 clear systems components, and design and manufacture of complete
22 nuclear steam generating systems. Through the B&W Company's several
23 divisions, a wide range of equipment for nuclear application is de-
24 signed and manufactured. The B&W Company's major nuclear contracts,

- 1 in addition to a substantial percentage of components for the nuclear
2 Navy, have included:
- 3 Indian Point Unit 1
 - 4 NS Savannah
 - 5 Advanced Test Reactor
 - 6 Oconee Nuclear Station Units 1, 2 & 3
 - 7 Three Mile Island Units 1 & 2
 - 8 Crystal River Unit 3
 - 9 Rancho Seco Unit 1
 - 10 Arkansas Nuclear One Station Unit 1
 - 11 Midland Units 1 & 2
 - 12 Davis-Besse Unit 1
 - 13 TVA Station (Undesignated) Units 1 & 2
- 14 With the exception of the last three contracts, all units have re-
15 ceived construction permits.

References

1. Midland Plant - Preliminary Safety Analysis Report, Section 12.1
2. Midland Plant - Preliminary Safety Analysis Report, Section 12.2
3. General Information, Appendix D
4. General Information, Appendix C

1 12.0 QUALITY ASSURANCE AND QUALITY CONTROL

2 12.1 Introduction

3 Applicant has initiated an extensive Quality Assurance (QA)
4 Program⁽¹⁾ to help assure that the Midland Plant is designed and
5 constructed so that it will operate efficiently and reliably and
6 without undue risk to the health and safety of the public and the
7 plant personnel. The QA Program encompasses all phases of the de-
8 sign, construction, and operation. A program plan⁽²⁾ has been
9 developed outlining how the QA Program will be implemented. Over-
10 all responsibility for the program rests with applicant.

11 Bechtel will perform Quality Assurance of plant engineering,
12 shop fabrication (including the nuclear steam system, except for
13 fuel), field fabrication and construction. Bechtel is also respon-
14 sible for providing Quality Control of receiving, storage, installation
15 and erection at the plant site.

16 The Babcock & Wilcox Company has a Quality Assurance Program
17 for the nuclear steam system. The scope of the B&W program includes
18 the design, fabrication, shop testing and shipment of the components
19 they furnish.

20 12.2 Consumers Power Company

21 Applicant will actively participate in a program or surveil-
22 lance to assure that Bechtel and B&W implement their respective QA

1 Programs during the design, procurement and construction phases
2 of this project. Applicant's surveillance program will include
3 audits, inspections and witnessing of tests at vendor shops. Audits
4 will also be performed on Bechtel home office activities and at
5 the plant site during construction.

6 The direction and coordination of applicant's QA Program from
7 design through construction is the responsibility of a Quality
8 Assurance Engineer (QAE). The QAE will conduct or supervise audits
9 and inspections of Bechtel home office, vendor shops and site audits.
10 Site surveillance is the responsibility of the applicant's Construc-
11 tion Department Field QAE who functionally reports to the QAE. The
12 Field QAE and QAE will be supported by engineers from the Engineering,
13 Construction and Operating Departments and other specialists within
14 the applicant's organization.

15 A comprehensive field testing program for the Midland Plant
16 will be conducted to insure equipment and systems perform in accord-
17 ance with design criteria. The applicant's Engineering Department is
18 responsible for preparing preoperational test procedures and its
19 Construction Department will be responsible for running the tests.
20 Quality Assurance of preoperational testing will be performed by
21 applicant's Field QAE and QAE.

22 Applicant is preparing written procedures containing internal
23 instructions to employees with respect to performance of their respon-
24 sibilities under applicant's QA Program.

1 12.3 Bechtel

2 The Bechtel Quality Assurance Program will be carried out
3 in accordance with Bechtel's Nuclear Quality Assurance Manual to
4 meet specific applicant requirements⁽²⁾. This manual describes
5 the overall program and identifies management and administrative
6 procedures and individual responsibilities. General instructions,
7 guidelines and checklists for inspections are contained in documents
8 developed for specific phases of the QA program.

- 9 1. Bechtel Procurement Department Inspection Manual.
- 10 2. Bechtel Field Inspection Manual.
- 11 3. Bechtel Field Procurement Procedures.

12 Several levels of design review and approval are applied to
13 significant design aspects of Bechtel work. These standard practices
14 include:

- 15 1. Checking and review of design work by members of the
16 Project Engineering team, other than those who originated
17 the work.
- 18 2. Review and approval by the Originating Engineer's
19 Design Group Supervisor.
- 20 3. Review and approval by the Project Engineer.
- 21 4. Review and/or approval by the appropriate Chief Engineer
22 of certain key designs and calculations.

23 A design control checklist is prepared which identifies
24 drawings, specifications and other data which shall be reviewed by

1 Chief Engineers or Technical Specialists under the Chief Engineers'
2 direction. The Design Control Checklist is agreed on by the Project
3 Engineer and the cognizant Chief Engineers soon after initiation
4 of the project. When the items identified in the Design Control
5 Checklist have been completed, the cognizant Chief Engineer will
6 have the final review performed and execute a design control approval
7 signifying that necessary review and monitoring work have been com-
8 pleted and the item is satisfactory from the standpoint of QA re-
9 quirements.

10 Structures, systems and components to be covered by the QA Program
11 are identified by a Q-List which is prepared by the Project Engineering
12 team and reviewed and approved by Chief Engineers. Additional design con-
13 trol measures are implemented for items on the Q-List. The specific level
14 of inspection and control afforded items on the Q-List are determined
15 by the Project Engineering team through consultation with the Chief
16 Engineers and Bechtel's Technical Specialists. Factors considered
17 in establishing the degree of control include nature of the item,
18 importance of the item to plant safety and reliability, previous
19 experience with this or comparable items, capabilities of potential
20 vendors or subcontractors, requirements of applicable codes or standards
21 and provisions of the PSAR. Where required, Bechtel Engineering docu-
22 ments include specific procedures or requisites for the production and
23 QA of the item or Bechtel will request their preparation by the organi-
24 zation responsible for manufacturing or erection.

1 In implementing the program in the construction phase, QA related
2 responsibilities are assigned to the following personnel:

- 3 1. The Project Field Engineer supervises Quality Control
4 (QC) inspection at the jobsite. In carrying out this
5 assignment, he assigns qualified Field Engineers to
6 perform QC inspections, he supervises the preparation
7 of inspection checklists, verifies accuracy and
8 completeness of inspection reports, ascertains that
9 defects are removed and insures that repairs are
10 carried out in accordance with applicable specifica-
11 tions, instructions and procedures.
- 12 2. The Quality Control Engineer reports to and assists the
13 Project Field Engineer in carrying out QC inspection
14 responsibilities. He normally is assigned responsibility
15 for review of inspection reports, coordination, training
16 and advising Field Engineers performing QC inspection
17 assignments, coordination of testing laboratories and
18 overall detailed execution of field inspection and
19 maintenance of the field QC/QA files.
- 20 3. Field Engineer-Inspectors carry out the inspection
21 assignments and are responsible for completing the
22 appropriate inspection forms. Field Engineer-Inspectors
23 function on a disciplinary basis, eg, mechanical equip-
24 ment, civil-structural, electrical-power, instrumentation
25 control, welding-metallurgy. The number of inspectors
26 assigned depends upon the requirements of the variable

1 QC inspection workload and construction schedule.
2 They have access to all design drawings, applicable
3 codes and sampling and testing procedures pertaining
4 to their inspection assignments.

5 4. The QA Engineer is the field representative of the
6 Project Engineering team and receives supervision and
7 technical support by the Project Engineer. However,
8 he is assigned by and administratively reports to the
9 Manager - Quality Assurance. He provides QA surveil-
10 lance of engineering, QC and construction activities in
11 the field. He reviews and accepts inspection reports,
12 audits the permanent field QA/QC documentation files
13 and monitors the overall QC program. The QA Engineer
14 has the authority to stop the work for which Bechtel
15 Corporation is prime contractor in the event of noncom-
16 formance with drawings, specifications and procedures
17 established for structures, system and units on the Q-List.
18 He serves as field contact with Applicant's Quality Assurance
19 organization and others concerned with Quality Assurance
20 in the field.

21 12.4 The Babcock & Wilcox Company

22 B&W has a comprehensive Quality Assurance Program covering the design,
23 procurement, fabrication and testing of nuclear steam systems and fuel for
24 the Consumers Power Company Midland Plant⁽¹⁾. The program is administered

1 by a separate Quality Assurance organization whose responsibility is
2 to assure the implementation of the program. The program establishes
3 and maintains standards of quality through the development and imple-
4 mentation of requisite methods and procedures. In addition, the pro-
5 gram is organized and administered so as to meet the provisions of
6 the AEC's Quality Assurance Criteria for Nuclear Powerplants⁽³⁾.

7 As a main contractor to Consumers Power Company, B&W is respon-
8 sible, through its project manager, for developing the necessary speci-
9 fications and/or associated purchase documents, which include Quality
10 Control requirements, and for insuring that such requirements are
11 followed for the shop fabrication of the nuclear components in B&W's
12 scope of supply. B&W will also develop recommendations for site
13 storage and installation of all such components.

14 The project manager is assisted in this effort by the manager of
15 B&W-Nuclear Power Generation Department (NPGD) Quality Assurance, who
16 reports directly to higher management to insure that he has sufficient
17 organizational freedom to identify problems affecting quality and to
18 insure that solutions are obtained. However, the project manager is
19 responsible for coordinating the planning and scheduling of the
20 B&W-NPGD Quality Assurance effort with other organizations and con-
21 tractors involved in the Midland Plant Project. Further, B&W will
22 provide erection consultation at the site throughout the period of
23 installation of the nuclear steam system. B&W will maintain a Quality
24 history file for the work that B&W and its subcontractors perform and,
25 soon after a component is shipped to the site, will furnish to applicant
26 copies of the portions of the file that apply to the component.

1 B&W's QA provisions for Midland Plant cover the design, pro-
2 curement, fabrication and testing of the B&W nuclear steam systems,
3 and fuel, including necessary Quality Control requirements. The
4 policies and procedures specified in this Plan are coordinated with
5 the Quality Assurance activities of other departments of the Power
6 Generation Division.

References

1. Midland Plant PSAR, Appendix 1B
2. Midland Plant PSAR, Amendment 6
3. 10 CFR Part 50, Appendix B

1 13.0 COMMENTS ON ACRS REPORTS

2 In its reports of June 18, 1970 and September 23, 1970 to
3 the Chairman of the Atomic Energy Commission favorably reviewing
4 the Midland Plant for construction, the Advisory Committee on
5 Reactor Safeguards (ACRS) identified certain areas for further
6 consideration. These areas as they appear in the ACRS letters
7 are listed below, together with applicant's comments thereon.

1 13.1 "A large volume of liquid chlorine is maintained in a refrigerated storage vessel about one mile from the Midland plant control room. The applicant is continuing his study of the consequences of a major accidental release of chlorine from this vessel. He has included in his criteria for the design of the control room the objective of finding a practical method of maintaining the concentration of chlorine in the control room atmosphere below the eight hour threshold limiting value (TLV) of 1 ppm for the most serious conceivable chlorine accident. The Committee believes that adequate air purification facilities should be provided in the control room ventilation system to reduce chlorine concentration to the eight hour TLV of 1 ppm so that operators can work without respiratory equipment during an extended chlorine emergency. This matter should be resolved during construction in a manner satisfactory to the Regulatory Staff."

Answer:

2 Applicant will review this design during construction with the
3 Regulatory Staff. A system design will provide for supplying air to
4 the control room through a filtration system so as to meet a chlorine
5 concentration criterion of 1 ppm and eliminate the necessity for
6 respiratory equipment.

1 13.2 "The applicant has stated that he will provide additional
evidence obtained by improved multi-node analytical techniques to
assure that the emergency core cooling system is capable of limiting
core temperatures to the limits established at present. He will
also make appropriate plant changes if the further analysis demon-
strates that such changes are required. This matter should be re-
solved during construction in a manner satisfactory to the Regulatory
Staff. The Committee wishes to be kept informed."

Answer:

2 B&W analyzed the ability of the Midland emergency core cooling
3 systems to limit fuel clad temperatures to acceptable values following
4 a loss-of-coolant accident and reported the results of these analyses
5 in the PSAR. Recent work by AEC consultants raised a question about
6 whether the analytical techniques used in the analyses reported in
7 the PSAR were detailed enough.

8 CRAFT, B&W's multinode computer code for analyzing loss-of-coolant
9 accidents, will be used to reevaluate the Midland emergency core cooling
10 system (ECCS) design. This work will be completed in time to make any
11 necessary changes in the ECCS design, should the analysis show that the
12 current design will not limit the fuel clad temperature to acceptable
13 values.

- 1 13.3 "The safety injection system for the Midland plant is actuated
by either low reactor pressure or high containment pressure signals.
However, of these two, the reactor is tripped only by the low reactor
pressure signal. The Committee believes that provision also should
be made to trip the reactor by the high containment pressure signal."

Answer:

- 2 A diverse backup to the low-reactor-coolant-system-pressure
3 trip signal such as a power-flow, low-flow, or high-reactor-building-
4 pressure trip signal will be provided for in the design of the Midland
5 reactors.

- 1 13.4 "The applicant plans to develop more detailed criteria for the installation of protection and emergency power systems together with appropriate procedures to maintain the physical and electrical independence of the redundant portions of these systems. The Committee believes that these criteria and procedures should be reviewed and approved by the Staff prior to actual installation."

Answer:

- 2 Applicant will review the detailed criteria and procedures
- 3 with the Staff and obtain its approval prior to actual installation.

1 13.5 "The applicant considers the possibility of melting and subse-
quent disintegration of a portion of a fuel assembly because of flow
starvation, gross enrichment error, or from other causes to be remote.
However, the resulting effects in terms of local high temperature or
pressure and possible initiation of failure in adjacent fuel elements
are not well known. Appropriate studies should be made to show that
such an incident will not lead to unacceptable conditions."

Answer:

2 B&W has completed a study of fuel and clad temperatures and
3 internal pressures for a fuel rod undergoing sustained departure
4 from nucleate boiling due to flow starvation. The results of that
5 study demonstrated that such an incident would not lead to unaccept-
6 able conditions and were submitted to Division of Reactor Licensing
7 (DRL) in B&W Topical Report, BAW-10014, "Analysis of Sustained
8 Departure From Nucleate Boiling Operation."

9 A B&W study to examine the effects of misplacing a fuel
10 pellet, a fuel rod or a fuel assembly will be completed during 1971
11 and the results will be reported to the DRL staff.

1 13.6 "The Committee believes that consideration should be given to
the utilization of instrumentation for prompt detection of gross
failure of a fuel element."

Answer:

2 The Midland Plant will employ instrumentation to promptly detect
3 gross failure of a fuel element. This instrumentation will be similar
4 to that approved for the applicant's Palisades Plant. The instrumenta-
5 tion will continuously monitor the gamma radioactivity in the reactor
6 coolant after a sufficient decay time to reduce the concentration of
7 very short-lived, nonfission product radionuclides such as N-16.

- 1 13.7 "The Committee has commented in previous reports on the develop-
ment of systems to control the buildup of hydrogen in the containment
which might follow in the unlikely event of a major accident. The
applicant proposes to make use of a technique of purging through filters
after a suitable time delay subsequent to the accident. However, the
Committee recommends that the primary protection in this regard should
utilize a hydrogen control method which keeps the hydrogen concentration
within safe limits by means other than purging. The capability for
purging should also be provided. The hydrogen control system and pro-
visions for containment atmosphere mixing and sampling should have
redundancy and instrumentation suitable for an engineered safety fea-
ture. The Committee wishes to be kept informed of the resolution of
this matter."

Answer:

- 2 Applicant has accepted the Committee recommendation to utilize
3 a hydrogen control method other than purging, in accordance with the
4 above. The method expected to be employed will utilize hydrogen-
5 oxygen recombiners.

1 13.8 "The Committee recommends that the applicant accelerate the
2 study of means of preventing common failure modes from negating scram
3 action and of design features to make tolerable the consequences of
4 failure to scram during anticipated transients. The applicant stated
5 that the engineering design would maintain flexibility with regard to
6 relief capacity of the primary system and to a diverse means of re-
7 ducing reactivity. This matter should be resolved in a manner satis-
8 factory to the Regulatory Staff during construction. The Committee
9 wishes to be kept informed."

Answer:

2 B&W has completed a study of common failure modes. The results
3 of this study have been submitted to DRL in B&W Topical Report,
4 BAW-10019, "Systematic Failure Study of Reactor Protections Systems."

5 B&W has completed a study of anticipated operational transients
6 without trip and reported the results to DRL. Applicant has been ad-
7 vised that the Regulatory Staff is considering issuing guidelines for
8 the further study of operational transients without trip. B&W is
9 waiting for DRL to issue the guidelines before proceeding further.

10 The Midland Plant design does not preclude the possibility of
11 increasing the primary system relief capacity or of providing diverse
12 means of reducing reactivity. However, the common failure modes and
13 anticipated transient without trip studies completed to date do not
14 indicate the need for either revision to the reactor system design.

- 1 13.9 "Other problems related to large water reactors have been
identified by the Regulatory Staff and the ACRS and cited in previous
ACRS reports. The Committee believes that resolution of these items
should apply equally to the Midland Plant Units 1 & 2."

Answer:

- 2 The other matters referred to in this section of the ACRS
3 letter are discussed in Appendix C, "Research and Development Programs
4 of Interest to ACRS First Identified in Earlier Cases."

- 1 13.10 "The Committee believes that the proposed system of reboilers will provide substantial additional assurance that leakage of primary system radioactivity into the export steam can be maintained at an extremely low and insignificant level and that the export steam can be maintained essentially at natural background levels. The detailed procedures for monitoring and control of the reboiler system should be developed during construction in a manner satisfactory to the Regulatory Staff. The Committee wishes to be kept informed."

Answer:


- 2 Applicant will develop detailed procedures for monitoring and
3 control of the reboiler system. These will be developed during con-
4 struction in a manner satisfactory to the Staff.

FIGURE 107

**MIDLAND PLANT UNITS 1 AND 2
NUCLEAR POWER STATION
PROJECT QUALITY ASSURANCE ORGANIZATION**

CHART BELOW SHOWS RELATIONSHIP BETWEEN
ENGINEERING, PROCUREMENT, AND CONSTRUCTION.

CONSUMERS POWER COMPANY






FIGURE -2

1 14.0 FINANCIAL QUALIFICATIONS

2 Applicant has estimated that the total cost of the Midland
3 Plant, including the first-core fuel, is \$394,827,000⁽¹⁾. All items
4 included in the categories comprising the plant cost estimate are the
5 same as those which would be included in the relevant electric plant
6 and nuclear fuel inventory accounts of the Federal Power Commission's
7 Uniform System of Accounts prescribed for Public Utilities and Licen-
8 sees (Class A and Class B).

9 Applicant will finance the Midland Plant as an integral part of
10 its normal construction program, using funds internally generated and
11 from the sale of securities, in the same general manner as it finances
12 other plant additions.

Reference

1. General Information, Page 6, as Amended by Amendment No 13

1 15.0 COMMON DEFENSE AND SECURITY

2 Applicant is a Michigan corporation and conducts its
3 business solely within the State of Michigan. Its directors and
4 principal officers are all citizens of the United States. The
5 Company is not owned, controlled or dominated by an alien, a foreign
6 corporation or foreign government⁽¹⁾.

7 The Company has agreed that it will not permit any individual
8 to have access to restricted data until the Civil Service Commission
9 has made an investigation and report to the AEC on the character,
10 associations and loyalty of such individual, and the AEC has deter-
11 mined that permitting such person to have access to restricted data
12 will not endanger the common defense and security⁽²⁾.

13 As stated in Section 57 of the Atomic Energy Act of 1954, as
14 amended, and 10 CFR, Part 70, Section 70.42, the Company may not
15 transfer special nuclear material except as authorized by the AEC.
16 The Company will, as a licensee, be subject to AEC regulations re-
17 quiring accountability for and physical protection of fissionable
18 material⁽³⁾.

References

1. General Information, Paragraph (d)
2. General Information, Paragraph (i)
3. 10 CFR 70, Paragraphs 70.51 Through 70.56; 10 CFR 73

1 16.0 CONCLUSION

2 On the basis of the foregoing and application, the applicant
3 respectfully submits that:

- 4 1. Applicant has described the proposed design of the
5 Midland Plant facilities, including, but not limited to,
6 the principal architectural and engineering criteria for
7 the design, and has identified the major features or
8 components incorporated therein for the protection of the
9 health and safety of the public.
- 10 2. The application, as amended, identifies the technical and
11 design information necessary to complete the final safety
12 analysis. Such information can reasonably be left for later
13 consideration and will be supplied in the final safety analy-
14 sis report.
- 15 3. Safety features which require further research and develop-
16 ment, and the research and development programs to be carried
17 out, are identified in Section 1.5 of the PSAR. The research
18 and development program is reasonably designed to resolve any
19 safety questions associated with such features at or before
20 the latest dates stated in the application for completion of
21 construction of the facilities.
- 22 4. Taking into consideration the characteristics of the site
23 and environs and the proposed design of the Midland Plant

1 facilities, and the site criteria contained in 10 CFR,
2 Part 100, such facilities can be constructed and op-
3 erated at the proposed location without undue risk to
4 the health and safety of the public.

5 5. Applicant is technically qualified to design and con-
6 struct the proposed facilities.

7 6. Applicant is financially qualified to design and con-
8 struct the proposed facilities.

9 7. The issuance of permits for the construction of the
10 proposed Midland Plant facilities will not be inimical
11 to the common defense and security of the United States
12 or to the health and safety of the public.

APPENDIX A
COMPARISON OF FWR DESIGN PARAMETERS⁽¹⁾

	Midland Unit 1 or 2	*Rancho Seco Unit 1	**Oconee Unit 1	***Zion Unit 1 or 2
1 Initial Core Rated Power, MW _t	2452	2452	2452	3250
2 Nominal Operating Pressure, Psia	2200	2200	2200	2250
3 Nominal Coolant Inlet Temperature, F	555	555	555	539
4 Average Coolant Temperature Rise in Core, F	50	50	50	69
5 Total Coolant Flow Rate, Lb/Hr	131.3x10 ⁶	131.3x10 ⁶	131.3x10 ⁶	135x10 ⁶
6 Average Thermal Output at Rated Power, kW/Ft	5.4	5.4	5.4	6.7
7 Maximum Thermal Output at Design Overpower, kW/Ft	19.2	19.2	19.2	21.2
8 Average Heat Flux at Rated Power, Btu/Hr-Ft ²	163,725	163,725	163,725	207,000
9 Minimum DNBR at Rated Power	2.21(W-3)	2.21(W-3)	2.21(W-3)	1.81(W-3)
10 Minimum DNBR at Design Overpower	1.71(W-3)	1.71(W-3)	1.71(W-3)	1.30(W-3)
11 Number of Fuel Assemblies	177	177	177	193
12 Equilibrium Core Average Fuel Burnup, MWd/MIU	27,490	28,200	28,200	33,000
13 Number of Control Rod Assemblies	57	69	69	61
14 Total Control Rod Worth, % Δk/k	8.0	10.0	10.1	7
15 Number of Reactor Coolant Loops	2	2	2	4
16 Number of Reactor Coolant Pumps	4	4	4	4
17 Number of Steam Generators	2	2	2	4
18 Number of High Head Safety Injection Pumps	2	2	2	2
19 Number of Low Head Safety Injection Pumps	2	2	2	2
20 Number of Core Flooding Tanks	2	2	2	4
21 Number of Reactor Building Air Coolers	4	4	3	5
22 Number of Reactor Building Spray Pumps	2	2	2	3

*As Proposed for the Rancho Seco Unit 1 FSAR (50-312)

**As Extracted From the Oconee Unit 1 FSAR (50-269)

***As Extracted From the Zion PSAR (50-295 and -304)

(1) Note: Differences between this Appendix and Midland PSAR, Table 1-2, are due to the use of more recent information than was available at the time Table 1-2 was prepared.

APPENDIX B

FIGURES

- 1 Figure 1 - Architects' Rendering of the Midland Plant
- 2 Figure 2 - Consumers Power Company System Map
- 3 Figure 3 - Station Arrangement
- 4 Figure 4 - Site Plan
- 5 Figure 5 - Plant Site and Adjacent Area
- 6 Figure 6 - Population - 10 Miles
- 7 Figure 7 - Consumers Power Company - Midland Organization Chart
- 8 Figure 8 - Steam Generator
- 9 Figure 9 - Fuel Assembly
- 10 Figure 10 - Pressurized Water Reactor
- 11 Figure 11 - Nuclear Steam System
- 12 Figure 12 - General Arrangement 599'
- 13 Figure 13 - General Arrangement 614'
- 14 Figure 14 - General Arrangement 634'
- 15 Figure 15 - General Arrangement 659'





FIGURE 1

CONSUMERS POWER COMPANY INTEGRATED ELECTRIC SYSTEM

AS OF DEC. 31, 1969

LEGEND

- | | |
|-----------------------------|----------|
| EXISTING TRANSMISSION LINES | PROPOSED |
| — 345,000 VOLTS | — |
| — 138,000 VOLTS | — |
| — 46,000 VOLTS | — |
| △ PRIMARY SUBSTATION | △ |
| ⊕ HYDRO PLANT | ⊕ |
| ☐ STEAM PLANT - COAL | ☐ |
| ☐ STEAM PLANT - NUCLEAR | ☐ |
| ☐ PEAKING PLANT | ☐ |
| ↔ INTERCHANGE OF POWER | ↔ |








FIGURE 2

DEC. 1962

E-C

H
G
F
E
D
C
B
A





INTAKE LINE FROM
STABROUZZEE RIVER

BASE OF DUNE
ENCLOSURE

RAIL
GRADE

4174.30

COOLING TOWERS

START-UP
TRANSFORMER

CHLORINE STORAGE

RAILGRADE

SERVICE WATER
PUMP STRUCTURE

TYP PERIMETER
AND ROAD SECTION

ADDED REBOILER BLOCK				
ISSUED FOR PROJECT COORDINATION	EX			
ISSUED FOR PHAS AREA 2				
RESERVED FOR NEW PLANT LOCATION				
PRELIMINARY ISSUE				
<p>Scale: 1" = 50' 0"</p> <p>DATE: J. HANE</p> <p>DATE: DICKERMAN</p>				
BECHTEL COMPANY				
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY				

FIGURE # 3

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, altered, exhibited, or used except in the furthering of the project for which they were prepared.



BRINE DISCHARGE FROM POND NO. 7
(TO BE RELOCATED DOWNSTREAM
FROM SOURCE OF WATER
INTAKE)

BRINE POND
NO. 7

NEW MILLER ROAD BRIDGE
3700 CFS
MIN. WATERWAY OPENING

MILLER ROAD

BRINE WELL NO. 6

STEWART ROAD

COOLING & STORAGE POND

WAITTS & DABOLT
CREEK DIVERSION

TOP OF DIKE
EL. 632 (TYP)

20' WASTE BRINE
16' RAW BRINE TO BE RELOCATED

GORDONVILLE ROAD

BRANCH #1 DIVERSION

DIKE ACCESS ROAD

SASSEE ROAD

WASTE BRINE

BRINE WELL NO. 8

FITTARAWASSEE RIVER

PROCESS LINE

BRINE WELL

WASTE WATER
POND STORAGE


PILGR
EL. 634

COOLING TOWER

WASTE WATER
POND
6071 EL. 606


DISCHARGE
CHANNEL

BAFFLE



- NOTES:**
1. BOTTOM ELEVATION +618 EXCEPT WHERE EXISTING GROUND IS LOWER
 2. WATER SURFACE ELEV +627 MAX, 618 MIN.
 3. APPROX. WATER SURFACE +600 ACRES

- LEGEND**
- PROPERTY LINE
 - EXISTING BRINE WELL
 - ▨ CHANNEL WIDENING
 - + 605.0 SPOT ELEVATIONS



500 FOOT GRID BASED ON CIVIL ENGINEER PLANS COORDINATE SYSTEM
VERTICAL DATUM IS MEAN SEA LEVEL

DRAWN BY PHOTOGRAPHY DIVISION 1966

MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY
SITE PLAN
FIGURE #4

H
G
F
E
D
C
B
A

4 3 2 1



N

LOW POPULATION ZONE

MIDLAND CITY LIMITS

MILLER RD

PATTERSON RD

ROSEVILLE RD

STEWART RD

BASSEL RD


GORDONVILLE RD

REACTOR SITE

DOV


1600 M

500



MIDLAND PLANT
CONSUMERS POWER COMPANY
PLANT SITE AND ADJACENT AREA
FIGURE # 5

100 MI



DETAIL "A"



MECOSTA CO.

ISABELLA CO.

MIDLAND CO.


MONTCALM CO.

GRATIOT CO.

IONIA CO.

CLINTON CO.






MIDLAND PLANT
 CONSUMERS POWER COMPANY
 POPULATION DISTRIBUTION
 0-50 MILES
FIGURE # 6

MIDLAND PLANT


Organization



* Pre-critical AEC License
 ** Post-critical AEC License

Total Plant Personnel (78)

FIGURE # 7




*Lengths of Regions Vary with Load

Once-Through Steam Generator


Babcock & Wilcox

FIGURE 8



Fuel Assembly - Cutaway Showing Partially Inserted Control Rod Assembly


Babcock & Wilcox



Pressurized Water Reactor

Babcock & Wilcox

FIGURE 10




SACRAMENTO MUNICIPAL UTILITY DISTRICT
 RANCHO SECO—UNIT NO. 1
 CONSUMERS POWER COMPANY
 MIDLAND NUCLEAR POWER PLANT—UNITS NO. 1 & 2

BARCOCK & WILCOX NUCLEAR STEAM SYSTEMS			
NOMINAL RATING, MW _e	820	STEAM OUTLET PRESSURE, PSIG	910
CAPACITY, LB STEAM PER HOUR	10,600,000	STEAM OUTLET TEMPERATURE, F.	570

FIGURE 11

This drawing and the design it covers are the property of BCCPTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, altered, or used except in the building and use of plants authorized by the written consent of BCCPTEL.




REACTOR BUILDING UNIT 1

FLOOR AT EL. 584'-0"

CONDENSATE PUMPS




REACTOR BUILDING UNIT 2



B

C

C




A

A

A


FLOOR EL-568'-0"

TRANSFER COMPONENT COOLING SYSTEM HEAT EXCHANGERS & PUMPS



A

FLOOR EL-599'-0"




GRAPHIC SCALE

MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY
GENERAL ARRANGEMENT PLANS AT ELEV 568'-0" 584'-0" & 599'-0"
FIGURE #12

H
G
F
E
D
C
B
A



This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, exhibited, or used except in the limited way and periods now permitted by any written consent given by the lender to the borrower.





A


B PLAN





MIDLAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY
 GENERAL ARRANGEMENT
 PLAN AT ELEV 614'0"
FIGURE # 13


SK-M-14

This drawing and the design it carries are the property of BECHTEL. They are hereby loaned and as the borrower's express agreement that they will not be reproduced, copied, issued, exhibited, or used except in the limited way and purpose set forth in the contract given to the owner by the borrower.





90'-0"
75'-0"
152'-0"



GRAPHIC SCALE


436'-0"
A
D



MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

GENERAL ARRANGEMENT
PLAN AT ELEV. 659'-0"

FIGURE # 15

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and as the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and within the limits given in the letter to the borrower.





MIDLAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY
 GENERAL ARRANGEMENT
 PLAN AT ELEV 634' 6"
FIGURE # 14

APPENDIX C

RESEARCH AND DEVELOPMENT PROGRAMS OF INTEREST TO ACRS
FIRST IDENTIFIED IN EARLIER CASES

1 The nuclear steam supply system for the Midland Plant is similar
2 in concept to several projects already in operation, under construc-
3 tion or recently licensed by the Atomic Energy Commission. The pre-
4 liminary design is based on technical data which has been developed
5 in the nuclear industry and on data developed by B&W which is specif-
6 ically related to the Midland Plant nuclear design.

7 Most of the work reported in this section consists of proof-
8 testing of engineered designs, confirmatory tests to confirm ana-
9 lytically predicted conditions, or analytical studies to evaluate
10 design or accident conditions.

11 The following summarizes the status of the research and develop-
12 ment items listed in the PSAR:⁽¹⁾

13 1. Once-Through Steam Generator Tests

14 The design of the once-through steam generator is based on
15 experimental work on boiling heat transfer and data obtained
16 by B&W in full-length model tests of the unit. The testing
17 of a prototype unit by B&W has been completed. It included
18 performance, mechanical, vibration and blowdown tests, and
19 control system development. The results have confirmed the
20 analytical predictions of performance, and sufficient data
21 on the performance and structural design has been obtained
22 from operation of the test models to finalize the design

1 of the steam generators and to confirm the analytical model
2 developed for steam generator depressurization. The results
3 of the tests are reported in B&W Topical Reports^(2,3).

4 2. Control Rod Drive Line Test

5 The design of the control rod drive mechanisms is based on
6 a principle which has been used in operating reactors and
7 which has been extensively tested by B&W. Test programs
8 have included full-scale prototype testing under no-flow
9 conditions, full-scale prototype testing at operating
10 conditions, including flow, and components testing. Proof-
11 testing of a prototype mechanism was carried out for a full-
12 life cycle of strokes and trips at optimum and 100 percent
13 misalignment conditions, and major design parameters were
14 confirmed. Data from these test programs confirmed de-
15 sign requirements indicating that rod drop time require-
16 ments were met, that excessive wear of components did not
17 occur and that corrosion was not significant. These test
18 data have been reported in B&W Topical reports^(4,5).

19 3. Self-Powered Detector Tests

20 The testing to demonstrate the performance and longevity
21 of the self-powered detectors in the B&W test reactor and
22 in the Big Rock Point Nuclear Power Plant has been completed.
23 The tests have demonstrated that the detectors perform accord-
24 ing to specifications and are capable of measuring neutron
25 flux locally in a PWR environment over a period of several

1 years with a relative accuracy of ± 5 percent. At the pres-
2 ent time, the detectors have accumulated operational experi-
3 ence equivalent to approximately six years of full power
4 operation in the Midland Plant reactors. The test results
5 are reported in a B&W Topical Report⁽⁶⁾.

6 4. Thermal and Hydraulic Programs

7 Core thermal performance was evaluated using the W-3 corre-
8 lation for predicting departure from nucleate boiling. This
9 correlation is available in the literature and has been used
10 and found acceptable in establishing thermal design limits
11 for other large PWR. With the use of this correlation,
12 only the vessel model flow tests were necessary to substan-
13 tiate operation of the plant within acceptable thermal limits.
14 These flow tests have been completed and have demonstrated
15 acceptable flow distribution for the rated power level. They
16 are reported in a B&W Topical Report⁽⁷⁾.

17 Other thermal and hydraulic work being done by B&W is directed
18 towards improvement in future core designs.

19 5. Blowdown Forces on Internals

20 The loads on the reactor and internals following a LOCA and
21 the resultant stresses and deflections in the reactor internals
22 have been analyzed for a skirt supported vessel at another
23 site, and the results are reported in two B&W Topical reports^(8,9).
24 Portions of these analyses will be repeated for the Midland
25 Plant vessels and site seismic characteristics and reported to
26 the AEC staff.

1 6. Fuel Rod Clad Failure

2 A B&W program has been conducted to investigate loss-of-
3 coolant accident fuel-clad failure mechanisms in order
4 to insure that none will interfere with the ability of
5 the emergency core cooling systems to accomplish their
6 objectives. The program involved testing and analytical
7 phases. Parametric tests to investigate possible mechan-
8 isms of cladding failure including eutectic formation,
9 cladding embrittlement, and cladding swelling and per-
10 foration have been carried out. Results indicate that the
11 emergency core cooling systems will effectively cool the
12 core, even if substantial fuel rod swelling occurs. This
13 work is described in a B&W Topical Report⁽¹⁰⁾.

14 7. Xenon Oscillations

15 The possibility of the occurrence of xenon oscillations
16 throughout the core life is being evaluated analytically
17 by B&W⁽¹¹⁾. A modal analysis and one, two and three dimen-
18 sional calculations have been carried out for a core design
19 similar to the Midland Plant to evaluate axial, azimuthal,
20 and radial oscillations including methods for controlling
21 possible oscillations^(12,13,14). Xenon oscillations are
22 primarily an operational problem, not a critical safety
23 problem, because the oscillations would be slow (25-30 hours)
24 and can be controlled by operator action. Confirmatory

1 analyses will be carried out on the Midland Plant core de-
2 sign and will be reported to the AEC staff.

3 8. Iodine Removal Spray

4 The design of the iodine removal spray system is based on
5 information obtained from R&D Programs conducted by B&W and
6 others. These programs have demonstrated the ability of the
7 chemical sprays to effectively remove and retain iodine and
8 the stability and chemical compatibility of the spray solu-
9 tion. The results of these programs are reported in B&W
10 Topical Reports^(15,16).

11 9. Internals Vent Valves

12 A test program, including hydrostatic, closing at zero pres-
13 sure, pressure differential verification, functional handling,
14 vibration and prototype testing, has been completed and the
15 test program demonstrated that the vent valve design will
16 perform adequately during both normal operating and accident
17 conditions. The results of the tests on the full-sized valves
18 and on the prototype valves are reported in B&W Topical Re-
19 ports^(7,17).

References

1. PSAR, Volume I, Section 1.5; PSAR Amendment No 5, Item 1.1.
2. BAW-10002, "Once-Through Steam Generator Research and Development Report" (PROPRIETARY).
3. BAW-10002, Supplement 1, "Once-Through Steam Generator Research and Development Report" (PROPRIETARY).
4. BAW-10007, "Control Rod Drive System Test Program."

5. BAW-10007, Supplement 1, "Control Rod Drive System Test Program."
6. BAW-10001, "In-Core Instrumentation Test Program."
7. BAW-10012, "Reactor Vessel Model Flow Tests" (PROPRIETARY).
8. BAW-10008, Part 1, Rev 1, "Reactor Internals Stress and Deflection
Due to Loss-of-Coolant Accident and Maximum Hypothetical Earthquake."
9. BAW-10008, Part 2, Rev 1, "Fuel Assembly Stress and Deflection
Analysis Due to Loss-of-Coolant Accident and Seismic Excitation"
(PROPRIETARY).
10. BAW-10009, "Effect of Fuel Rod Failure on Emergency Core Cooling"
(PROPRIETARY).
11. PSAR, Volume 1, Section 1.5.1 and Section 3.2.2.2.3 and Appendix 3A.
12. BAW-10010, Part 1, "Stability Margin for Xenon Oscillations - Modal
Analysis."
13. BAW-10010, Part 2, "Stability Margin for Xenon Oscillations - One-
Dimensional Digital Analysis."
14. BAW-10010, Part 3, "Stability Margin for Xenon Oscillations -
Two- and Three-Dimensional Digital Analysis."
15. BAW-10017, Rev 1, "Research and Development Report in the Stability
and Compatibility of Sodium Thiosulfate Spray Solutions - R&E
Report" (PROPRIETARY).
16. BAW-10022, "Effectiveness of Sodium Thiosulfate Sprays for Iodine
Removal" (PROPRIETARY).
17. BAW-10005, "Internals Vent Valve Evaluation" (PROPRIETARY).