

Stephen H. Howell
Vice President



CONSUMERS
POWER
COMPANY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201

April 24, 1975
SHH-67-75

Dr. Donald F. Knuth
Office of Inspection and Enforcement
US Nuclear Regulatory Commission
Washington, DC 20545

Dear Dr. Knuth:

In accordance with Condition 4 of Memorandum and Order AIAB-106 dated March 26, 1973, and Amendment No 1 to the Midland Plant Construction Permit, enclosed are two (2) copies of the non-conformance reports for ~~March 1975~~. This report consists of copies of Bechtel Nonconformance Reports, Quality Audit Findings, and Management Corrective Action Reports written or closed during the month; all sheets from the Bechtel Nonconformance Report Log and Status Book which reflect open Bechtel NCR's and Consumers Power Company Nonconformance Reports written or closed during the month.

Yours very truly,

Stephen H. Howell

8006180 693

5

NONCONFORMANCE REPORT (CONT'D)

1. PAGE 2 OF 2

14. NCR NO. 299

Block 19 Continued

Qty	Size	Material	Packing Slip #	MRR #	Inspection Plan #
250	7/8 x 2	Bolts w/nuts	V665-R-27	AEO-766	C-38-R-37 Rev. 0
200	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V664-R-136	AEO-776	C-38-R-37 Rev. 0
200	7/8 X 2 3/4	Bolts w/nuts	V664-R-136	AEO-776	C-38-R-37 Rev. 0
1400	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V863-209	AEO-776	C-38-R-39 Rev. 0
525	7/8 X 3 $\frac{1}{2}$	Bolts w/nuts	V863-209	AEO-776	C-38-R-39 Rev. 0
1200	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V665-R-92	AEO-776	C-38-R-39 Rev. 0
175	7/8 X 3	Bolts w/nuts	V665-R-92	AEO-776	C-38-R-39 Rev. 0
525	7/8 X 3	Bolts w/nuts	V1016-R-70	AEO-776	C-38-R-39 Rev. 0
175	7/8 X 3 $\frac{1}{2}$	Bolts w/nuts	V1016-R-70	AEO-776	C-38-R-39 Rev. 0
175	7/8 X 3	Bolts w/nuts	V664-R-93	AEO-776	C-38-R-39 Rev. 0
900	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V1016-33	AEO-790	C-38-R-41 Rev. 0
800	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V1016-33	AEO-790	C-38-R-41 Rev. 0
675	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V665-61	AEO-790	C-38-R-41 Rev. 0
900	7/8 X 2 $\frac{1}{2}$	Bolts w/nuts	V863-16	AEO-790	C-38-R-41 Rev. 0

Nonconformance noted during receipt inspection. "Q" numbers 1.101 and 1.201. Units 1 & 2.

110 Hold tags applied.

ORIGINATOR