

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

DOCKET NO. 50-320

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 11
License No. DPR-73

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Metropolitan Edison Company, Jersey Central Power and Light Company, and Pennsylvania Electric Company (the Licensee) dated June 23, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the Order for Modification of License dated July 20, 1979, the Order for Modification of License dated October 18, 1979, the Order of February 11, 1980, the Order for Temporary Modification of License dated June 12, 1980, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and,
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, by changing paragraph 2.C.(2) to facility operating License No. DPR-73, to read as follows:

2.C.(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 11, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and all Commission Orders issued subsequent to March 28, 1979.

OFFICE ▶

SURNAME ▶

DATE ▶

8007110280

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

S/

Bernard J. Snyder, Program Director
Three Mile Island Program Office
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 24, 1980

*see also
application to
form*

OFFICE ▶	TMI:PC <i>me</i>	TMI:PC <i>DB</i>	TMI:PO <i>DB</i>	OELD <i>W</i>	DIR/TMI:PO <i>JS</i>
SURNAME ▶	MDuncan/hmt	DBrinkman	OLynch	Wentworth	BSnyder
DATE ▶	6/23/80	6/23/80	6/23/80	6/23/80	6/23/80

ATTACHMENT TO AMENDMENT NO. 11
FACILITY OPERATING LICENSE NO. DPR-73
DOCKET NO. 50-320

Only for the period of the purge of the TMI-2 reactor building atmosphere pursuant to the Commission's Order for Temporary Modification of License dated June 12, 1980, Section 2.1.28.3 of the Appendix B Technical Specifications is superseded by the following:

Unit 1 valves AH-V1A and AH-V1B shall be interlocked to close or recirculate on receipt of a high radiation signal from the Reactor Building Exhaust Monitor RM-A9. The interlocks from the Unit 2 Reactor Building Exhaust Monitors HP-R-225 and HP-R-226 which initiate closure or recirculation of the Unit 2 Dampers D5129 A/D and D5129 B/C may be bypassed in accordance with procedures approved pursuant to Appendix A Technical Specification 6.8.2.

OFFICE ▶
SURNAME ▶
DATE ▶