

NSIC



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20545

MAY 08 1980

Mr. W. F. Naughton  
Nuclear Licensing Administrator  
Pressurized Water Reactors  
Commonwealth Edison Company  
P.O. Box 767  
Chicago, IL 60690

Dear Mr. Naughton:

By letters dated December 20, 1979, February 21, 1980, and April 2, 1980, you submitted Revisions 11, 12, and 13 respectively to the Commonwealth Edison Company (CECO) Topical Report No. CE-1-A, "Commonwealth Edison Company Quality Assurance Program for Nuclear Generating Stations."

We have evaluated these revisions and find additional information is required from CECO to satisfy the enclosed staff position. To maintain our review schedule, your reply by no later than May 30, 1980 is requested.

We are available for a meeting or conference call with CECO to discuss our concerns. Please call W. Belke on (301) 492-7741 to arrange for further discussions.

Sincerely,

*Walter P. Haass*  
Walter P. Haass, Chief  
Quality Assurance Branch  
Division of Engineering

Enclosure:  
Staff Position

8007110499

Commonwealth Edison Company

Staff Position

The response to Q421.7 is not totally acceptable. You have not described the years of experience required for the position of Manager of Quality Assurance. It is an NRC staff position that the years of experience required for this position be at least equal to those described in Section 4.4.5 of ANSI/ANS 3.1-1978, "Selection and Training of Nuclear Power Plant Personnel." In lieu of the above, we would accept a commitment to the education and experience described in the following paragraph 4.4.5 of proposed draft ANS 3.1-1979:

EDUCATION: Bachelor Degree in Engineering or related science.

EXPERIENCE: At the time of initial core loading or appointment to the active position, the responsible person shall have four (4) years experience in the field of quality assurance, or equivalent number of years of nuclear plant experience in a supervisory position preferably at an operating nuclear plant or a combination of the two. At least one (1) year of this four years experience shall be nuclear power plant experience in the implementation of the quality assurance program. Six (6) months of the one year experience shall be obtained within the quality assurance organization.

Provide us with a description to satisfy the above position.