



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

the

June 13, 1980

Docket No. 50-423

Northeast Nuclear Energy Company
ATTN: Mr. W. G. Council
Senior Vice President - Nuclear
Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

Gentlemen:

The enclosed IE Information Notice No. 80-28, "Prompt Reporting of Information in Accordance with 10 CFR 50.55(e)", is forwarded to you for information. No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

Boyce H. Grier
Boyce H. Grier
Director

Enclosures:

1. IE Information Notice No. 80-28
2. List of Recently Issued IE Information Notices

CONTACT: R. W. McGaughy
(215-337-5281)

cc w/encls:

- K. W. Gray, Supervisor of Quality Assurance
- H. R. Nims, Director of Nuclear Projects
- J. F. Opeka, Station Superintendent
- J. R. Himmelwright, Licensing Safeguards Engineer
- D. G. Diedrick, Manager of Quality Assurance

8007280 600

ENCLOSURE 1

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

SSINS No.: 6835
Accession No.:
8005050063

DUPLICATE

IE Information Notice No. 80-28
Date: June 13, 1980
Page 1 of 1

PROMPT REPORTING OF INFORMATION IN ACCORDANCE WITH 10 CFR 50.55(e)

The recently implemented expansion of the NRC Resident Inspection Program at nuclear power plants and fuel facilities, has led to some misunderstandings regarding the required reporting of information to the NRC. In order to clarify this matter, the following is provided for your information.

Some licensees have been making the 24 hour reports required by 10 CFR 50.55(e)(2) orally to NRC resident inspectors. This does not satisfy either the letter or the intent of the regulation. Adherence by all licensees to the explicit requirements of the regulation, which provides for a single focal point for reporting within each Regional Office, minimizes the possibility of inadvertent oversight. While we continue to enlist your cooperation in fully informing our resident inspectors, where appropriate, or any other NRC inspector who may be at your facility at such a time, such informational exchanges do not satisfy the reporting requirements of 10 CFR 50.55(e)(2).

Your cooperation in assuring that the appropriate members of your staff are fully aware of this information will be appreciated.

No written response to this information notice is required. If you require additional information regarding this matter contact the Director of the appropriate NRC Regional Office.

RECENTLY ISSUED
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-27	Degradation of Reactor Coolant Pump Studs	6/11/80	All Pressurized Water Reactor Facilities holding power reactor OLs or CPs
80-26	Evaluation of Contractor QA Programs	6/10/80	All Part 50 Licensees
80-25	Transportation of Pyrophoric Uranium	5/30/80	Material Licensee in Priority/Categories II-A, II-D, III-I and IV-DI; Agreement State Licensees in equivalent categories
80-24	Low Level Radioactive Waste Burial Criteria	5/30/80	All NRC and Agreement State Licensees
80-23	Loss of Suction to to Emergency Feedwater Pumps	5/29/80	All power reactor facilities with an OL or CP
80-22	Breakdown In Contamination Control Programs	5/28/80	All power reactor OLs and near term CPs
80-21	Anchorage and Support of Safety-Related Electrical Equipment	5/16/80	All power reactor facilities with an OL or CP
80-20	Loss of Decay Heat Removal Capability at Davis-Besse Unit 1 While in a Refueling Mode	5/8/80	All light water reactor facilities holding power reactor OLs or CPs
80-19	NIOSH Recall of Recirculating-Mode (Closed-Circuit) Self-Contained Breathing Apparatus (Rebreathers)	5/6/80	All holders of a power reactor OL, Research Reactor License, Fuel Cycle Facility License and Priority I Material License